

Letter to N. C, Moseley from Carolina Power and Light Company dated May 21, 1975.

DISTRIBUTION:

50-261

H. D. Thornburg, IE

IE:HQS (4)

Office of Standards Development

Central Files

Division of Reactor Licensing (4)

PDR

Local PDR

NSIC

TIC

STATE

40  
(4)



**Caroline Power & Light Company**

**H. B. ROBINSON STEAM ELECTRIC PLANT**  
Post Office Box 790  
Hartsville, South Carolina

May 21, 1975

Robinson File No. 2-0-4-n-1

Mr. Norman C. Moseley, Director  
Directorate of Regulatory Operations  
U. S. Nuclear Regulatory Commission  
Region II, Suite 818  
230 Peachtree Street, N.W.  
Atlanta, Georgia 30303

Mr. Donald Knuth, Director  
Directorate of Regulatory Operations  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20545

Dear Sirs:

In accordance with Section 536.2 of the Technical Specifications the following Abnormal Occurrence is reported:

At 0345, May 21, 1975, while recirculating Boric Acid Tank "B" for a sample, Boric Acid Pump "B" was found stopped. It was known to be running ten minutes earlier. Boric Acid Pump "A" was operable and running at this time. Investigation revealed a broken shaft in the keyway area. The plant is in cold shutdown with the Reactor Coolant System partially drained for maintenance.

This event constitutes an Abnormal Occurrence as defined in Technical Specification 1.8.d and was reported to Mr. Neal Bender of NRC by telephone on May 21, 1975.

Yours very truly,

J. H. McGirt, Manager  
H. B. Robinson SEG Plant

ACT:sla