

(7-77) LICENSEE EVENT REPORT

CONTROL BLOCK: (PLEASE PRINT OR TYPE REQUIRED INFORMATION)

01 | S | C | H | B | R | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 0 | 4 | 5
 7 8 9 14 15 25 26 30 37 CAT 53
 LICENSEE CODE LICENSE NUMBER LICENSE TYPE

CON'T
 01 | L | 0 | 5 | 0 | 0 | 0 | 2 | 6 | 1 | 7 | 1 | 0 | 0 | 3 | 7 | 8 | 8 | 1 | 0 | 1 | 6 | 7 | 8 | 9
 7 8 60 61 68 69 74 75 80
 REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | During normal operation, while performing periodic test CPL-PT-3.4C, both "A" and
 03 | "B" Containment Spray Pumps failed to meet the ΔP requirement due to air binding.
 04 | Both pumps were declared inoperable at 2128. This constitutes a reportable
 05 | occurrence in accordance with Technical Specification 6.9.2.a.2 in that the plant
 06 | was operated in a mode less conservative than the least conservative mode allowed
 07 | by Technical Specification 3.3.2.2.b.

08 |
 09 |
 17 | LER/RO REPORT NUMBER 7 8
 SYSTEM CODE 9 10 S B 11
 CAUSE CODE 11 X 12
 CAUSE SUBCODE 12 Z 13
 COMPONENT CODE 13 P U M P X X 14
 COMP. SUBCODE 15 B 16
 VALVE SUBCODE 16 Z
 EVENT YEAR 21 22 7 8
 SEQUENTIAL REPORT NO. 24 26 0 2 6
 OCCURRENCE CODE 28 29 0 1
 REPORT TYPE 30 T
 REVISION NO. 32 0
 ACTION TAKEN 33 X 34 G 35 Z 36 Z 37 0 0 0 0 40
 FUTURE ACTION 34 G 35 Z 36 Z 37 0 0 0 0 40
 EFFECT ON PLANT 35 Z 36 Z 37 0 0 0 0 40
 SHUTDOWN METHOD 36 Z 37 0 0 0 0 40
 HOURS 40 0 0 0 0
 ATTACHMENT SUBMITTED 41 Y 42
 NPRD-4 FORM SUB. 42 N 43
 PRIME COMP. SUPPLIER 43 N 44
 COMPONENT MANUFACTURER 44 I 0 7 5 47 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | It is believed that air became entrained and trapped in the RHR system during cold
 11 | shutdown and following realignment for normal operation the trapped air migrated to
 12 | the Containment Spray Pumps preventing proper operation. The pumps were vented at
 13 | 2150 rendering them operable. Plant operating procedures will be revised to
 14 | incorporate pump venting following RHR System realignment.

15 | FACILITY STATUS 7 8 9 E 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
 % POWER 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
 OTHER STATUS 30 NA
 METHOD OF DISCOVERY 45 B 46 Inservice Inspection
 DISCOVERY DESCRIPTION 32
 ACTIVITY RELEASED 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
 CONTENT 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
 AMOUNT OF ACTIVITY 35 NA
 LOCATION OF RELEASE 36 NA
 PERSONNEL EXPOSURES 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
 NUMBER 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
 TYPE 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
 DESCRIPTION 39 NA
 PERSONNEL INJURIES 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
 NUMBER 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
 DESCRIPTION 41 NA
 LOSS OF OR DAMAGE TO FACILITY 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
 TYPE 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
 DESCRIPTION 43 NA
 PUBLICITY 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
 ISSUED 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
 DESCRIPTION 45 NA

7810270226

NAME OF PREPARER R. B. Starkey, Jr.

PHONE: (803) 332-1351