

1002

REGULATORY INFORMATION DISTRIBUTION SYSTEM

DOCKET NBR: 050-261 H. B. Robinson - 2 DOC DATE: 781025  
 RECIPIENT: O'Reilly, J.P. ACCESSION NBR: 7810310210  
 ORIGINATOR: Banks, H.R. COPIES RECEIVED:  
 COMPANY NAME: Carolina Pwr & Light LTR 1 ENCL 1  
 SUBJECT: SIZE: 1+2

LER#78-024/03L-0 on 781001: Engine Driven Fire Water Pump failed to start due to moisture in distributor cap caused by heavy rains & access door being left open. Moisture removed & engine test started w/satisfactory results on 781006.

DISTRIBUTION CODE: A002  
 DISTRIBUTION TITLE:  
 INCIDENT REPORTS

NOTARIZED \_\_\_\_\_

| NAME                 | ENCL?     |
|----------------------|-----------|
| BR CHIEF             | W/4 ENCL  |
| REG FILE             | W/ENCL    |
| MRC PDR              | W/ENCL    |
| I & E                | W/2 ENCL  |
| MIPC                 | W/3 ENCL  |
| I & C SYSTEMS BR     | W/ENCL    |
| NOVAK/CHECK          | W/ENCL    |
| EEB                  | W/ENCL    |
| AD FOR ENG           | W/ENCL    |
| PLANT SYSTEMS BR     | W/ENCL    |
| HANAUER              | W/ENCL    |
| AD FOR PLANT SYSTEMS | W/ENCL    |
| AD FOR SYS & PROJ    | W/ENCL    |
| REACTOR SAFETY BR    | W/ENCL    |
| ENGINEERING BR       | W/ENCL    |
| KREGER/J. COLLINS    | W/ENCL    |
| POWER SYS BR         | W/ENCL    |
| K SEYFRIT/IE         | W/ENCL    |
| LPDR                 | W/ENCL    |
| NSIC                 | W/ENCL    |
| ACRS                 | W/16 ENCL |

FOR ACTION

• ORB#1 BC

TOTAL NUMBER OF COPIES REQUIRED:  
 LTR  
 ENCL

42  
42

NOV 2 1978

NOTES:

A104 CCP



Carolina Power & Light Company

S

October 25, 1978

FILE: NG-3516 (R)

SERIAL: GD-78-2844

Mr. James P. O'Reilly, Director  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2  
DOCKET 50-261  
LICENSE NO. DPR-23  
LICENSEE EVENT REPORT 78-024

Dear Mr. O'Reilly:

In accordance with Section 6.9.2.b of the Technical Specifications for the H. B. Robinson Steam Electric Plant, Unit 2, the attached Licensee Event Report is submitted. This report fulfills the requirement for a written report within thirty (30) days of a reportable occurrence and is in accordance with the format set forth in NUREG-0161, July, 1977.

Yours very truly,

H. R. Banks  
Manager  
Nuclear Generation

DCS:cp\*

Attachment

cc: Messrs. R. A. Hartfield  
J. G. Davis

RECEIVED  
OCT 27 1978  
NRC

7810310210

A002  
5/11