

CP&L

USNRC REGION 4
ATLANTA, GEORGIA

Carolina Power & Light Company

H. B. ROBINSON STEAM ELECTRIC PLANT
Post Office Box 790
Hartsville, South Carolina 29550

DEC 1 P 2: 29

NOV 25 1981

Robinson File No: 2-O-4-a-4

Serial: RSEP/81-1969

Mr. James P. O'Reilly, Director
U. S. Nuclear Regulatory Commission
Region II, Suite 3100
101 Marietta Street
Atlanta, Georgia 30303

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261
LICENSE NO. DPR-23
RESPONSE TO I.E. INSPECTION REPORT NO. 50-261/81-25

Dear Mr. O'Reilly:

Carolina Power and Light Company (CP&L) has received and reviewed the subject report and provides the following description of actions that will be taken to resolve Open Items 3.b, 16.a, and 16.b as specifically requested in the inspection report transmittal letter.

3.b (OPEN) 79-19-06 - Maintenance History and Trend Evaluations

A Maintenance History file has been implemented beginning with maintenance performed in 1979. 100% of the 1979 and 1980 mechanical maintenance history and 75% of the 1979 electrical maintenance history has been entered into this file. CP&L expects to have the electrical maintenance history through 1980 entered into the history file by December 31, 1981. A formal Trend Evaluation Program using this Maintenance History file will be implemented by March 31, 1982.

16.a (OPEN) 79-19-09 - Calibration Program For Safety Related Instruments

Maintenance Instruction MI-4 describes the calibration program for both safety and non-safety related instruments. Due to the many calibration and surveillance requirements on all instruments, including those designated safety related, a preliminary master instrument list containing pertinent information on over 2500 instruments has been compiled and will be included as Appendix "A" to MI-4. The portion

8203020505 820219
PDR ADOCK 05000261
Q PDR

OFFICIAL COPY

Letter to Mr. James P. O'Reilly
Serial: RSEP/81-1969
Page 2

of Appendix "A" that covers the calibration requirements of safety related components will be finalized and included into MI-4 by March 1, 1982. (The January 1, 1982 completion date discussed with the NRC Inspector cannot be met due to an unscheduled outage in November, 1981.) The remainder of the master instrument list will be finalized by December 31, 1982.

3.b (OPEN) 79-19-06 - Overhead Crane and Gantry Training

The required training on overhead and Gantry cranes will be given on site and be completed by December 31, 1981.

Very truly yours,



R. B. Starkey, Jr.
General Manager

H. B. Robinson SEG Plant

CLW/tm