

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9005080070 DOC. DATE: 90/05/02 NOTARIZED: NO DOCKET #
FACIL: 50-261 H.B. Robinson Plant, Unit 2, Carolina Power & Light Co 05000261
AUTH. NAME AUTHOR AFFILIATION
DIETZ, C.R. Carolina Power & Light Co.
RECIP. NAME RECIPIENT AFFILIATION
Document Control Branch (Document Control Desk)

SUBJECT: Responds to weakness noted in Insp Rept 50-261/90-03.

DISTRIBUTION CODE: IE01D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
TITLE: General (50 Dkt)-Insp Rept/Notice of Violation Response

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-1 PD	1	LO, R	1
INTERNAL:	AEOD	1	AEOD/DEIIB	1
	AEOD/TPAD	1	DEDRO	1
	NRR SHANKMAN, S	1	NRR/DLPQ/LPEB10	1
	NRR/DOEA DIR 11	1	NRR/DREP/PEPB9D	1
	NRR/DRIS/DIR	1	NRR/DST/DIR 8E2	1
	NRR/PMAS/ILRB12	1	NUDOCS-ABSTRACT	1
	OE DIR	1	OGC/HDS1	1
	REG FILE 02	1	RES/DSR/HFB/HFS	1
	RGN2 FILE 01	1		
EXTERNAL:	LPDR	1	NRC PDR	1
	NSIC	1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR • 22 ENCL 220



Carolina Power & Light Company

ROBINSON NUCLEAR PROJECT DEPARTMENT
POST OFFICE BOX 790
HARTSVILLE, SOUTH CAROLINA 29550
MAY 02 1990

Robinson File No: 13510E

Serial: RNP/90-1360

United States Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261
LICENSE NO. DPR-23
NRC INSPECTION REPORT 50-261/90-03: RESPONSE TO WEAKNESS

Gentlemen:

Carolina Power and Light Company (CP&L) provides this response to the weakness identified by NRC Inspection Report No. 50-261/90-03.

The subject inspection report identified a weakness associated with the identification of post-maintenance functional testing. CP&L agrees that applicable post-maintenance test requirements are not often specified or adequately documented, and notes that this concern was also identified by INPO during their evaluation of the Maintenance Work Control System. As a result, specific actions are being considered to address this programmatic deficiency.

Post-maintenance testing guidance and procedures will be developed providing appropriate post-maintenance testing selection criteria. The development of these guidelines and procedures will consider industry guidance as well as the specific items identified in the inspection report regarding post-maintenance functional testing. A plan to formulate the actions necessary to implement these procedures, and the time frame for implementation, is currently being developed, and is expected to be completed during June, 1990. In addition, interim guidance, to avoid any concerns that may arise during implementation of the plan, will be adopted, and will be in place upon completion of the plan development.


9005080070 900502
PDR ADUCK 05000241
Q PDC

IEO1
1/0

Memorandum to U. S. NRC
Serial: RNP/90-1360
Page 2

Should you have any questions concerning this submittal, please contact
Mr. J. D. Kloosterman at (803) 383-1491.

Very truly yours,



C. R. Dietz
Manager
Robinson Nuclear Project Department

RDC:sgk

cc: Mr. S. D. Ebnetter
Mr. L. W. Garner
INPO