

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9403070175 DOC. DATE: 93/12/31 NOTARIZED: NO DOCKET #
 FACIL: 50-261 H.B. Robinson Plant, Unit 2, Carolina Power & Light C 05000261
 AUTH. NAME AUTHOR AFFILIATION
 KRICH, R.M. Carolina Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: "Statistical Summary Rept, HB Robinson Steam Electric Plant,
 1993, Jan-Dec." W/940222 ltr.

DISTRIBUTION CODE: IE56D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4
 TITLE: 20.407 Annual Personnel Monitoring Rpt/Annual Rad Exposure Rpt by Fun S

NOTES:

	RECIPIENT		COPIES		
	ID CODE/NAME	PD2-1 PD	LTTR	ENCL	
INTERNAL:	ACNW		6	6	
	NMSS/SCDB/SSSS		1	1	
	REG FILE 02		1	1	
	RGN2 01		1	1	
EXTERNAL:	NRC PDR		1	1	

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 17 ENCL 16



10 CFR 20.407

Carolina Power & Light Company
Robinson Nuclear Plant
PO Box 790
Hartsville SC 29550

Robinson File No.: 13510
Serial: RNP/94-0315

FEB 22 1994

Director, Office of Nuclear Regulatory Research
United States Nuclear Regulatory Commission
Washington, DC 20555

H. B. ROBINSON STEAM ELECTRIC PLANT
DOCKET NO. 50-261
LICENSE NO. DPR-23
1993 PERSONNEL EXPOSURE AND MONITORING REPORT

Gentlemen:

In accordance with 10CFR20.407, Carolina Power and Light Company herewith submits the Report of Individual Whole Body Exposures for the Year 1993 associated with the H. B. Robinson Steam Electric Plant.

The total whole body exposure reported on the Statistical Summary Report is an adjusted thermoluminescent dosimeter reading due to the separate reporting of License No. SNM-2502, Independent Spent Fuel Storage Installation.

If you have any question concerning this report, please contact my staff or me.

Very truly yours,

R. M. Krich
Manager - Regulatory Affairs

WMB:lst
Enclosure
c: Document Control Desk
S. D. Ebeneter
W. T. Orders

9403070175 931231
PDR ADOCK 05000261
R PDR

Highway 151 and SC 23 Hartsville SC

JE56 1/

STATISTICAL SUMMARY REPORT
H. B. ROBINSON STEAM ELECTRIC PLANT - 1993
JANUARY THROUGH DECEMBER
LICENSE NO. DPR-23

☐ If personnel monitoring was not required to be provided to any individual during the year, checking this box will constitute a negative report indicating that such personnel monitoring was not required.

<u>WHOLE BODY EXPOSURE RANGE (REM)</u>	<u>NO. OF INDIVIDUALS IN RANGE</u>
--	------------------------------------

Non-Measurable	1,135
Less than 0.1	454
0.1 to 0.25	301
0.25 to 0.50	247
0.50 to 0.75	116
0.75 to 1.00	54
1 to 2	49
2 to 3	0
3 to 4	0
4 to 5	0
5 to 6	0
6 to 7	0
7 to 8	0
8 to 9	0
9 to 10	0
10 to 11	0
11 to 12	0
12 and Over	0

Total 2,356

Total Manrem: 336.871

APPENDIX B
STANDARD FORMAT FOR REPORTING NUMBER OF PERSONNEL AND MANREM BY WORK AND JOB
FUNCTION
LICENSE NO. DPR-23

WORK AND JOB FUNCTION	NUMBER OF PERSONNEL >100 MREM			TOTAL MANREM BY POCKET DOSIMETER		
	STATION EMPLOYEES	UTILITY EMPLOYEES	OTHER EMPLOYEES	STATION EMPLOYEES	UTILITY EMPLOYEES	OTHER WORKERS
Reactor Operations and Surveillance						
Maintenance Personnel	2	0	2	1.085	0.070	0.600
Operating Personnel	8	0	0	3.437	0.000	1.135
Health Physics Personnel	23	0	4	5.167	0.010	0.830
Supervisory Personnel	0	0	0	0.030	0.000	0.035
Engineering Personnel	0	0	3	0.790	0.095	0.790
Routine Maintenance						
Maintenance Personnel	2	0	4	1.405	0.115	2.456
Operating Personnel	0	0	0	0.005	0.000	0.025
Health Physics Personnel	0	0	0	0.080	0.000	0.000
Supervisory Personnel	0	0	0	0.000	0.000	0.000
Engineering Personnel	0	0	0	0.120	0.030	0.175
Inservice Inspection						
Maintenance Personnel	0	0	0	0.050	0.000	0.580
Operating Personnel	0	0	0	0.000	0.000	0.000
Health Physics Personnel	0	0	0	0.020	0.000	0.000
Supervisory Personnel	0	0	0	0.000	0.000	0.000
Engineering Personnel	0	0	1	0.140	0.095	0.750
Special Maintenance						
Maintenance Personnel	24	3	103	8.525	1.065	43.788
Operating Personnel	3	0	1	1.505	0.000	0.655
Health Physics Personnel	5	0	14	1.805	0.000	3.600
Supervisory Personnel	0	0	2	0.040	0.000	0.475
Engineering Personnel	4	1	27	1.640	0.230	7.715

APPENDIX B
STANDARD FORMAT FOR REPORTING NUMBER OF PERSONNEL AND MANREM BY WORK AND JOB
FUNCTION
LICENSE NO. DPR-23

WORK AND JOB FUNCTION	NUMBER OF PERSONNEL >100 MREM			TOTAL MANREM BY POCKET DOSIMETER		
	STATION EMPLOYEES	UTILITY EMPLOYEES	OTHER EMPLOYEES	STATION EMPLOYEES	UTILITY EMPLOYEES	OTHER WORKERS
Waste Processing						
Maintenance Personnel	1	0	0	0.205	0.115	0.295
Operating Personnel	0	0	0	0.000	0.000	0.000
Health Physics Personnel	3	0	0	0.620	0.000	0.015
Supervisory Personnel	0	0	0	0.000	0.000	0.000
Engineering Personnel	0	0	1	0.000	0.000	0.200
Refueling						
Maintenance Personnel	68	38	277	30.922	11.842	109.880
Operating Personnel	36	0	1	11.010	0.000	2.275
Health Physics Personnel	31	0	46	9.471	0.015	19.495
Supervisory Personnel	3	0	6	0.895	0.155	2.410
Engineering Personnel	23	2	160	6.740	1.140	73.227
Total						
Maintenance Personnel	97	41	386	42.192	13.207	157.599
Operating Personnel	47	0	2	15.957	0.000	4.090
Health Physics Personnel	62	0	64	17.163	0.025	23.940
Supervisory Personnel	3	0	8	0.965	0.155	2.920
Engineering Personnel	27	3	192	9.430	1.590	82.857
Grand Total	236	44	652	85.707	14.977	271.406