

# PRIORITY 1

(ACCELERATED RIDS PROCESSING)

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NER:9502210338      DOC.DATE: 95/02/13      NOTARIZED: NO      DOCKET #  
 FACIL:50-261 H.B. Robinson Plant, Unit 2, Carolina Power & Light C      05000261  
 AUTH.NAME      AUTHOR AFFILIATION  
 KRICH,R.M.      Carolina Power & Light Co.  
 RECIP.NAME      RECIPIENT AFFILIATION  
                          Document Control Branch (Document Control Desk)

SUBJECT: Submits response to request for addl info re GL 93-04, "Rod Control Sys Failure & Withdrawal of Rod Control Cluster Assemblies,10CFR50.54(f)."

DISTRIBUTION CODE: A030D      COPIES RECEIVED:LTR 1 ENCL 0 SIZE: 2  
 TITLE: Generic Ltr-93-04-Rod Control System Failure & Withdrawal of Rod Cont

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	MOZAFARI, B	1      1		
INTERNAL:	FILE CENTER 01	1      1	NRR/DRCH/HICB	1      1
	NRR/DRPW/PDIV-1	1      1	NRR/DSSA/SRXB	1      1
EXTERNAL:	NRC PDR	1      1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 504-2083 ) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR      6      ENCL      0

*may*

P  
R  
I  
O  
R  
I  
T  
Y  
  
1  
  
D  
O  
C  
U  
M  
E  
N  
T



**Carolina Power & Light Company**  
Robinson Nuclear Plant  
3581 West Entrance Road  
Hartsville SC 29550

Robinson File No.: 13510I  
Serial: RNP-RA/95-0027

**FEB 13 1995**

United States Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, DC 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2  
DOCKET NO. 50-261/LICENSE NO. DPR-23  
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION  
REGARDING GENERIC LETTER 93-04, "ROD CONTROL SYSTEM FAILURE  
AND WITHDRAWAL OF ROD CONTROL CLUSTER ASSEMBLIES, 10 CFR 50.54 (f)"

Gentlemen:

The NRC issued Generic Letter 93-04, "Rod Control System Failure and Withdrawal of Rod Control Cluster Assemblies, 10 CFR 50.54 (f)," dated June 21, 1993. Carolina Power & Light (CP&L) Company provided responses for H. B. Robinson Steam Electric Plant (HBRSEP), Unit No. 2 by letters dated August 5, 1993 and September 20, 1993. In our letter dated August 26, 1994, we stated that the current order timing will be modified to prevent any uncontrolled asymmetric rod withdrawals in the event of the failure identified at the Salem Nuclear Generating Station, Unit 2, and that the rod control surveillance test is being enhanced to verify that the Rod Control System order timing modification will prevent uncontrolled asymmetric rod withdrawals. By letter dated January 6, 1995, the NRC requested a commitment to implement the current order timing modification and the new current order surveillance test, to be performed at each refueling outage, developed by the Westinghouse Owners Group and approved by the NRC.

The purpose of this letter is to confirm CP&L's commitment for implementation of long-term actions as discussed in our letter dated August 26, 1994. HBRSEP will implement the current order timing modification during refueling outage 16, currently scheduled to begin in April 1995, and the new current order surveillance test by the end of refueling outage 16, as described in WCAP-13864, Rev. 1, "Rod Control System Evaluation Program," Westinghouse Technical Bulletin NSD-TB-94-05-RO, "Rod Control CRDM Timing Change," and "WOG Recommended Rod Control System Surveillance Test." The surveillance test will be performed at each refueling outage.

9502210338 950213  
PDR ADDOCK 05000261  
P PDR

Highway 151 and SC 23 Hartsville SC

A030  
40

RNP-RA/95-0027

Page 2 of 2

Questions regarding this matter may be referred to Mr. K. R. Jury at (803) 857-1363.

Very truly yours,

A handwritten signature in black ink, appearing to read 'R. M. Krich', written in a cursive style.

R. M. Krich

Manager - Regulatory Affairs

Enclosure

c: Mr. S. D. Ebnetter, Regional Administrator, USNRC, Region II  
Ms. B. L. Mozafari, USNRC Project Manager, HBRSEP  
Mr. W. T. Orders, USNRC Senior Resident Inspector, HBRSEP