

PRIORITY 1

(ACCELERATED RIDS PROCESSING)

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9508030108 DOC. DATE: 95/07/28 NOTARIZED: NO DOCKET #
FACIL: 50-261 H.B. Robinson Plant, Unit 2, Carolina Power & Light Co 05000261
AUTH. NAME AUTHOR AFFILIATION
KRICH, R.M. Carolina Power & Light Co.
RECIP. NAME RECIPIENT AFFILIATION
Document Control Branch (Document Control Desk)

SUBJECT: Provides correction to previously submitted info re
containment penetrations.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
TITLE: OR Submittal: General Distribution

NOTES:

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PD2-1 LA	1 1	PD2-1 PD	1 1
MOZAFARI, B	1 1		
INTERNAL: <u>FILE CENTER</u> 01	1 1	NRR/DE/EMCB	1 1
NRR/DRCH/HICB	1 1	NRR/DSSA/SPLB	1 1
NRR/DSSA/SRXB	1 1	NUDOCS-ABSTRACT	1 1
OGC/HDS3	1 1		
EXTERNAL: NOAC	1 1	NRC PDR	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL
DESK, ROOM OWFN 5D8 (415-2083) TO ELIMINATE YOUR NAME FROM
DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 12 ENCL 11 0

may



Carolina Power & Light Company

Robinson Nuclear Plant
3581 West Entrance Road
Hartsville SC 29550

Robinson File No.: 13510

Serial: RNP-RA/95-0139

JUL 28 1995

United States Nuclear Regulatory Commission

Attention: Document Control Desk

Washington, DC 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2

DOCKET NO. 50-261/LICENSE NO. DPR-23

CORRECTION TO PREVIOUSLY SUBMITTED INFORMATION REGARDING
CONTAINMENT PENETRATIONS

Gentlemen:

By letter dated October 30, 1979, the NRC issued a letter to all operating nuclear power plants that provided additional clarification to previously transmitted short term requirements that resulted from the NRC's investigation of the accident at Three Mile Island Nuclear Station, Unit 2, and requested a response from licensees within 15 days of receipt of the letter. Carolina Power & Light (CP&L) Company provided the requested response for the H. B. Robinson Steam Electric Plant, Unit No. 2, by letter dated November 20, 1979, which committed to providing details of the method of implementation for items requiring implementation by January 1, 1980 (i.e., Category A requirements), in a submittal to be provided by December 31, 1979. By letter dated December 31, 1979, we provided documentation of the method of implementation of all Category A requirements consistent with Enclosure 2, "Implementation Schedule," to the NRC's October 30, 1979, letter. By letter dated August 31, 1981, we provided a revision to certain information provided in the December 31, 1979, letter, including corrections to the previously provided Table 1 for item 2.1.4, "Containment Isolation."

During recent work by CP&L to resolve containment isolation issues, we have determined that further corrections to Table 1 for item 2.1.4 are necessary as discussed below.

1. Containment Penetration 21, Excess Letdown Heat Exchanger Cooling Water Inlet, has a normally open valve (i.e., Component Cooling (CC)-737A) identified as the containment isolation valve. There is no automatic isolation provided by a "T" signal (i.e., trip on receipt of an automatic safety injection signal) as indicated in our August 31, 1981, letter.

060053

9508030108 950728
PDR ADDOCK 05000261
P PDR

Highway 151 and SC 23 Hartsville SC

Adol
1/10

United States Nuclear Regulatory Commission

Serial: RNP-RA/95-0139

Page 2 of 2

2. The Main Steam Penetrations, (i.e., penetrations 7, 8, and 9), and Feedwater Penetrations, (i.e., penetrations 10, 11, and 12), are "essential," since they provide the steam to operate the turbine driven auxiliary feedwater pump, and the flow path for injection of auxiliary feedwater from the turbine driven auxiliary feedwater pump to the steam generators. Our August 31, 1981, letter indicated that these penetrations were "non-essential."

This revised information will be reflected in the next periodic revision to the Updated Final Safety Analysis Report in accordance with 10 CFR 50.71(e), "Maintenance of records, making of reports."

Questions regarding this matter may be referred to Mr. A. L. Garrou at (803) 857-1544.

Very truly yours,



R. M. Krich
Manager - Regulatory Affairs

JSK/klb

c: Mr. S. D. Ebnetter, Regional Administrator, USNRC, Region II
Ms. B. L. Mozafari, USNRC Project Manager, HBRSEP
Mr. W. T. Orders, USNRC Senior Resident Inspector, HBRSEP