

ACCELERATED DOCUMENT DISTRIBUTION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9212090059 DOC. DATE: 92/11/30 NOTARIZED: NO DOCKET #
 FACIL: 50-261 H.B. Robinson Plant, Unit 2, Carolina Power & Light C 05000261
 AUTH. NAME AUTHOR AFFILIATION
 DIETZ, C.R. Carolina Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Part 21 rept re six one inch long radius, 90 degree elbows received from Tioga Pipe & Supply Co that were type 304SS in lieu of type 316SS ordered. Fittings mfg & certified to be type 316SS by Taylor Forge Stainless.

DISTRIBUTION CODE: IE19D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: Part 21 Rept (50 DKT)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-1 LA	1 0	PD2-1 PD	1 1
	MOZAFARI, B	1 1		
INTERNAL:	AEOD/DSP/ROAB	1 1	NRR/DOEA/OGCB11	2 2
	NRR/DRIS/RVIB9D	1 1	<u>REG FILE</u> 01	1 1
	RES/DSIR/EIB	1 1	RGN1	1 1
	RGN2	1 1	RGN3	1 1
	RGN4	1 1	RGN5	1 1
	SECY VANDERMEL	1 1		
EXTERNAL:	INPO RECORD CTR	1 1	NRC PDR	1 1
	NSIC SILVER, E	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 18 ENCL 17 ⁰

IA
Ch



Carolina Power & Light Company

ROBINSON NUCLEAR PROJECT DEPARTMENT
POST OFFICE BOX 790
HARTSVILLE, SOUTH CAROLINA 29550

NOV 30 1992

Robinson File No: 13510E

Serial: RNP/92-3057

United States Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

H. B. ROBINSON STEAM ELECTRIC PLANT
DOCKET NO. 50-261
LICENSE NO. DPR-23
REPORT OF DEVIATION PURSUANT TO 10CFR PART 21

Gentlemen:

Carolina Power and Light Company (CP&L) provides this notification as a follow-up to a notification made to the NRC Operations Center at 1553 hours on November 11, 1992. This notification was documented by the NRC Operations Center as Event Report 24583 and identified that the Robinson Nuclear Project Department (RNP) had received six 1 inch, long radius, 90 degree elbows from;

Tioga Pipe and Supply Co.
2450 Wheatsheaf Lane
Philadelphia, PA 19137,

that were type 304SS in lieu of the type 316SS that was ordered. These fittings were manufactured and certified to be type 316SS by;

Taylor Forge Stainless
Post Office Box 610
Somerville, NJ 08876.

Taylor Forge Stainless has provided a report to the NRC Document Control Desk dated November 12, 1992, which provides the information requested by 10CFR Part 21, except for installation information on material supplied to locations other than CP&L.

030064

9212090059 921130
PDR ADOCK 05000261
S PDR

JE19

1/0


Letter to United States Nuclear Regulatory Commission
Serial: RNPDP/92-3057
Page 2

RNPDP has a Fraudulent Material Program that requires the fifth shipment, from each supplier of stainless steel material, to have the material type verified. However, because of the small number of items received at RNPDP it is considered less time consuming to verify each shipment rather than keep records to identify the next shipment requiring verification. Based on the implementation of this program RNPDP is confident that other incorrect material does not exist.

CP&L considers this letter, in conjunction with our previous report to the NRC Operations Center and the Taylor Forge letter, to fulfill the reporting requirements on this issue for CP&L. As stated in the Taylor Forge letter, additional information regarding the location and use of other suspect components will be provided formally at a later date.

Should you have any questions regarding this submittal, please contact Mr. J. L. Harrison at (803) 383-1433.

Very truly yours,



Charles R. Dietz
Vice President
Robinson Nuclear Project Department

DHB:lst

cc: Mr. S. D. Ebnetter
Mr. L. W. Garner
INPO