

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9709170178 DOC. DATE: 97/09/12 NOTARIZED: NO DOCKET #
 FACIL: 50-261 H.B. Robinson Plant, Unit 2, Carolina Power & Light C 05000261
 AUTH. NAME AUTHOR AFFILIATION
 MOYER, J.W. Florida Power Corp.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards LER 97-005-02 re condition outside design basis.

DISTRIBUTION CODE: IE22T COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1 + 5
 TITLE: 50.73/50.9 Licensee Event Report (LER), Incident Rpt, etc.

NOTES:

RECIPIENT ID CODE/NAME	COPIES	L	T	R	ENCL	RECIPIENT ID CODE/NAME	COPIES	L	T	R	ENCL
PD2-1 PD	1				1	MOZAFARI, B	1				1
INTERNAL: <u>AEOD/SPD/RAB</u>	2				2	AEOD/SPD/RRAB	1				1
<u>FILE CENTER</u>	1				1	NRR/DE/ECGB	1				1
NRR/DE/EELB	1				1	NRR/DE/EMEB	1				1
NRR/DRCH/HHFB	1				1	NRR/DRCH/HICB	1				1
NRR/DRCH/HOLB	1				1	NRR/DRCH/HQMB	1				1
NRR/DRPM/PECB	1				1	NRR/DSSA/SPLB	1				1
NRR/DSSA/SRXB	1				1	RES/DET/EIB	1				1
RGN2 FILE 01	1				1						
EXTERNAL: L ST LOBBY WARD	1				1	LITCO BRYCE, J H	1				1
NOAC POORE, W.	1				1	NOAC QUEENER, DS	1				1
NRC PDR	1				1	NUDOCS FULL TXT	1				1

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

FULL TEXT CONVERSION REQUIRED
 TOTAL NUMBER OF COPIES REQUIRED: LTR 24 ENCL 24

**Carolina Power & Light Company**

Robinson Nuclear Plant
3581 West Entrance Road
Hartsville SC 29550

Robinson File No: 13510C

Serial: RNP-RA/97-0191

SEP 12 1997

United States Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261/LICENSE NO. DPR-23
LICENSEE EVENT REPORT NO. 97-05-02

Gentlemen:

The attached supplemental Licensee Event Report (LER) is submitted in accordance with 10 CFR 50.73. Revision 1 to this LER, dated June 26, 1997, stated that an unreviewed safety question submittal, with the results of an evaluation of the off-site doses resulting from a spent fuel shipping cask drop with cask that does not have full shipping integrity, would be submitted to the NRC by August 31, 1997, and that the results of the final evaluation would be included in a supplement to this LER. By letter dated August 28, 1997, Carolina Power & Light (CP&L) Company submitted a request for NRC review of this issue. Results of the final evaluation concluded that the off-site doses resulting from a postulated cask drop with a less than fully secured cask are a small fraction of the 10 CFR 100 limits and the acceptance criteria in the Standard Review Plan.

The revised information in this LER is denoted with a revision bar.

Should you have any questions regarding this matter, please contact Mr. H. K. Chernoff at (803) 857-1437.

Very truly yours,

W. W. Moyer
Plant General Manager

9709170178 970912
PDR ADDCK 05000261
S PDR

Attachment

- c: Mr. L. A. Reyes, Regional Administrator, USNRC, Region II
Ms. B. L. Mozafari, USNRC Project Manager, HBRSEP
Mr. B. B. Desai, USNRC Senior Resident Inspector, HBRSEP

