

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
NRC DOCKET NO. 50-261/LICENSE NO. DPR-23
REQUEST FOR LICENSE AMENDMENT

TECHNICAL SPECIFICATION PAGE

9212020037 921120
PDR ADOCK 05000261
P PDR

(1815RNP)

TABLE 4.1-1 (Continued)

MINIMUM FREQUENCIES FOR CHECKS, CALIBRATIONS AND TEST OF INSTRUMENT CHANNELS

<u>Channel Description</u>	<u>Check</u>	<u>Calibration</u>	<u>Test</u>	<u>Remarks</u>
32. Loss of Power				
a. 480 Emerg. Bus Undervoltage (Loss of Voltage)	N.A.	R	R	
b. 480 Emerg. Bus Undervoltage (Degraded Voltage)	N.A.	R	R	
33. Auxiliary Feedwater Flow**** Indication	M	R	N.A.	
34. Reactor Coolant System** Subcooling Monitor	M	R	N.A.	
35. PORV Position Indicator***	N.A.	N.A.	R	
36. PORV Blocking Valve*** Position Indicator	N.A.	N.A.	R	
37. Safety Relief Valve Position*** Indicator	N.A.	N.A.	R	
38. Noble Gas Effluent Monitors***** a. Main Steam Line	D	R	Q	

** Instrument for Detection of Inadequate Core Cooling - NUREG 0578 Item 2.1.3.b.

*** Direct Indication of Power Operated Relief Valve and Safety Valve Position - NUREG 0578 Item 2.1.3.a.

**** Auxiliary Feedwater Flow Indication to Steam Generator - NUREG 0578 Item 2.1.7.b.

***** Noble Gas Effluent Monitors - NUREG-0737 Item II.F.1.1.

4.1-8

Amendment No.