

ENCLOSURE 1

REVISED TECHNICAL SPECIFICATION PAGE  
OVERTIME LIMITS

9301050206 921228  
PDR ADOCK 05000261  
P PDR

- d) At least one licensed operator shall be in the control room when fuel is in the reactor.
- e) At least two licensed operators shall be present in the control room during reactor start-up, scheduled reactor shutdown, and during recovery from reactor trips.
- f) An individual qualified in radiation protection procedures shall be on site when fuel is in the reactor.
- g) ALL CORE ALTERATIONS after the initial fuel loading shall be directly supervised by either a licensed Senior Reactor Operator or Senior Reactor Operator limited to fuel handling who has no other concurrent responsibilities during this operation.
- h) The shift complement may be one less than the minimum requirement of Section 6.2.3.a and 6.2.3.b for a period of time not to exceed 2 hours in order to accommodate unexpected absence of on-duty shift members provided immediate action is taken to restore the shift complement to within the minimum requirements of Section 6.2.3.a and 6.2.3.b. This provision does not permit any shift member position to be unmanned upon shift change due to an oncoming shift member being late or absent.