

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
NRC DOCKET NO. 50-261/LICENSE NO. DPR-23
REQUEST FOR LICENSE AMENDMENT
ELIMINATION OF REQUIREMENT
FOR ACCELERATED TESTING

TECHNICAL SPECIFICATION PAGES

Techn

- i. Power operation with less than three loops in service is prohibited.

3.3.1.2

During power operation, the requirements of 3.3.1.1 may be modified to allow any one of the following components to be inoperable. If the system is not restored to meet the requirements of 3.3.1.1 within the time period specified, the reactor shall be placed in the hot shutdown condition utilizing normal operating procedures. If the requirements of 3.3.1.1 are not satisfied within an additional 48 hours, the reactor shall be placed in the cold shutdown condition utilizing normal operating procedures.

- a. One accumulator may be isolated or otherwise inoperable relative to the requirements of 3.3.1.1.b for a period not to exceed four hours.
- b. If one safety injection pump becomes inoperable during normal reactor operation, the reactor may remain in operation for a period not to exceed 24 hours.
- c. If one residual heat removal pump becomes inoperable during normal reactor operation, the reactor may remain in operation for a period not to exceed 24 hours.

- d. If one residual heat exchanger becomes inoperable during normal reactor operation, the reactor may remain in operation for a period not to exceed 24 hours.
- e. If any one flow path including valves of the safety injection or residual heat removal system is found to be inoperable during normal reactor operation, the reactor may remain in operation for a period not to exceed 24 hours. The hot leg injection paths of the Safety Injection System, including valves, are not subject to the requirements of this specification.
- f. Power or air supply may be restored to any valve referenced in 3.3.1.1.g. and 3.3.1.1.h. for the purpose of valve testing or maintenance providing no more than one valve has power restored and provided that testing and maintenance is completed and power removed within 24 hours except for accumulator isolation valves (MOV 865 A,B,&C) which will have this time period limited to four hours.

3.3.2.2

During power operation, the requirements of 3.3.2.1 may be modified to allow any one of the following components to be inoperable. If the system is not restored to meet the requirements of 3.3.2.1 within the time period specified, the reactor shall be placed in the hot shutdown condition utilizing normal operating procedures. If the requirements of 3.3.2.1 are not satisfied within an additional 48 hours, the reactor shall be placed in the cold shutdown condition utilizing normal operating procedures.

- a. If one fan cooler unit or the flow path for a fan cooler unit becomes inoperable during normal reactor operation, the reactor may remain in operation for a period not to exceed 24 hours, provided both containment spray pumps are operable.
- b. If one containment spray pump becomes inoperable during normal reactor operation, the reactor may remain in operation for a period not to exceed 24 hours, provided the four fan cooler units are operable.
- c. If either containment spray system flow path including valves becomes inoperative during normal operation, the reactor may remain in operation for a period not to exceed 24 hours.

3.3.2.3

When the reactor is in the hot shutdown condition, the requirements of 3.3.2.1 and 3.3.2.2 shall be met. Except that any one component as defined in 3.3.2.2 may be inoperable for a period equal to the time period specified in the subparagraphs of 3.3.2.2 plus 48 hours, after which the plant shall be placed in the cold shutdown condition utilizing normal operating procedures.

When it is determined that maintenance to restore components or systems to an operable condition will last longer than periods specified, the circumstances of the extended maintenance and the estimated date for returning the components or systems to an operable condition shall be promptly reported to the Director - Office of Nuclear Reactor Regulation and to the Director - Region II Office of Inspection and Enforcement. The purpose of prompt reporting is to allow the NRC to review the circumstances of the request for extended outage and to render a timely decision on whether to extend the specified out-of-service period while reactor operations continue.

Basis

During low temperature physics tests, there is a negligible amount of stored energy in the reactor coolant, therefore an accident comparable in severity to a Design Basis Accident is not possible, and the engineering safety features systems are not required.

The operable status of the various systems and components is to be demonstrated by periodic tests, defined by Specification 4.5. A large fraction of these tests will be performed while the reactor is operating in the power range. If a component is found to be inoperable, it will be possible in most cases to effect repairs and restore the system to full operability within a relatively short time. For a single component to be inoperable does not negate the ability of the system to perform its function, but it reduces the redundancy provided in the system design and thereby limits the ability to tolerate additional equipment failures. For this reason, the unit is allowed to operate only for a limited time as specified when this condition occurs.