

ENCLOSURE 6

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
NRC DOCKET NO. 50-261/LICENSE NO. DPR-23
REQUEST FOR LICENSE AMENDMENT
DELETION OF AUXILIARY COOLANT SYSTEM HYDROSTATIC TEST
TECHNICAL SPECIFICATION PAGES

TABLE 4.1-3

FREQUENCIES FOR EQUIPMENT TESTS

		<u>Check</u>	<u>Frequency</u>	<u>Maximum Time Between Tests</u>
1.	Control Rods	Rod drop times of all full length rods	Each refueling shutdown	NA*
2.	Control Rod	Partial movement of all full length rods	Every 2 weeks during reactor critical operations	20 days
3.	Pressurizer Safety Valves	Set point	Each refueling shutdown	NA
4.	Main Steam Safety Valves	Set point	Each refueling shutdown	NA
5.	Containment Isolation Trip	Functioning	Each refueling shutdown	NA
6.	Refueling System Interlocks	Functioning	Prior to each refueling shutdown	NA
7.	Service Water System	Functioning	Each refueling shutdown	NA
8.	DELETED			
9.	Primary System Leakage	Evaluate	Daily when reactor coolant system is above cold shutdown condition	NA
10.	Diesel Fuel Supply	Fuel Inventory	Weekly	10 days
11.	Critical Headers of Auxiliary Coolant System	100 Psig Hydrostatic Test	Every five years	6 years
12.	Turbine Steam Stop, Control, Reheat Stop, and Interceptor Valves	Closure	Monthly during power operation and prior to startup	45 days

TABLE 4.1-3

FREQUENCIES FOR EQUIPMENT TESTS

		<u>Check</u>	<u>Frequency</u>	<u>Maximum Time Between Tests</u>
1.	Control Rods	Rod drop times of all full length rods	Each refueling shutdown	NA*
2.	Control Rod	Partial movement of all full length rods	Every 2 weeks during reactor critical operations	20 days
3.	Pressurizer Safety Valves	Set point	Each refueling shutdown	NA
4.	Main Steam Safety Valves	Set point	Each refueling shutdown	NA
5.	Containment Isolation Trip	Functioning	Each refueling shutdown	NA
6.	Refueling System Interlocks	Functioning	Prior to each refueling shutdown	NA
7.	Service Water System	Functioning	Each refueling shutdown	NA
8.	DELETED			
9.	Primary System Leakage	Evaluate	Daily when reactor coolant system is above cold shutdown condition	NA
10.	Diesel Fuel Supply	Fuel Inventory	Weekly	10 days
11.	DELETED			
12.	Turbine Steam Stop, Control, Reheat Stop, and Interceptor Valves	Closure	Monthly during power operation and prior to startup	45 days