

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9607100193 DOC.DATE: 96/07/01 NOTARIZED: NO DOCKET #
FACIL:50-261 H.B. Robinson Plant, Unit 2, Carolina Power & Light C 05000261
AUTH.NAME AUTHOR AFFILIATION
KRICH,R.M. Carolina Power & Light Co.
RECIP.NAME RECIPIENT AFFILIATION
Document Control Branch (Document Control Desk)

SUBJECT: Documents info re request for TS change concerning refueling
filter sys fans at plant.

DISTRIBUTION CODE: A001D COPIES RECEIVED:LTR 1 ENCL 0 SIZE: 2
TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-1 LA	1	PD2-1 PD	1
	MOZAFARI,B	1		
INTERNAL:	<u>FILE CENTER-01</u>	1	NRR/DE/EMCB	1
	NRR/DRCH/HICB	1	NRR/DSSA/SPLB	1
	NRR/DSSA/SRXB	1	NUDOCS-ABSTRACT	1
	OGC/HDS3	1		
EXTERNAL:	NOAC	1	NRC PDR	1

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T

NOTE TO ALL "RIDS" RECIPIENTS:
PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
ROOM OWFN 5D-5(EXT. 415-2083) TO ELIMINATE YOUR NAME FROM
DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 12 ENCL 0



Carolina Power & Light Company

Robinson Nuclear Plant
3581 West Entrance Road
Hartsville SC 29550

Robinson File No: 13510H

Serial: RNP-RA/96-0121

JUL 01 1996

United States Nuclear Regulatory Commission

Attn: Document Control Desk

Washington, DC 20555

**H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261/LICENSE NO. DPR-23
ADDITIONAL INFORMATION REGARDING A REQUEST
FOR A TECHNICAL SPECIFICATIONS CHANGE**

Gentlemen:

This letter is being submitted to document information discussed during a conference call between representatives of Carolina Power & Light (CP&L) Company and the NRC on June 21, 1996. This information is related to our request for a Technical Specifications change submitted on July 17, 1995, concerning the refueling filter system fans at the H. B. Robinson Steam Electric Plant (HBRSEP), Unit No. 2.

During the conference call we informed the NRC representatives that we have concluded that the analyses documented in Updated Final Safety Analysis Report (UFSAR) Section 15.7.4, "Design Basis Fuel Handling Accidents," were performed using the assumptions delineated in NRC Safety Guide 25, "Assumptions Used For Evaluating The Potential Radiological Consequences Of A Fuel Handling Accident In The Fuel Handling And Storage Facility For Boiling And Pressurized Water Reactors," dated March 1972. Furthermore, the analyses for the fuel handling accident in containment and in the Spent Fuel Pool Building did not include credit for atmospheric mixing in the calculation of the off-site dose. This conclusion was substantiated by several documents, including Supplement 2 to the NRC Safety Evaluation dated May 20, 1974, supporting approval of a power upgrade that was transmitted by NRC letter dated March 30, 1979. We also informed the NRC that Spent Fuel Building Heating and Ventilation Exhaust (HVE) fan -15, the fan used during normal operation is not safety related; however, fan HVE - 15A, used for refueling operations, is safety related. The containment purge fans, HVE - 1A, and HVE - 1B, are not safety related; however, the two containment purge isolation valves are safety related, therefore, the ability to isolate the containment during a fuel handling accident is ensured.

9607100193 960701
PDR ADOCK 05000261
P PDR

Adel
1/0

United States Nuclear Regulatory Commission
Serial: RNP-RA/96-0121
Page 2 of 2

Questions regarding this matter may be referred to me at (803) 857-1802.

Very truly yours,

A handwritten signature in black ink, appearing to read 'R. M. Krich', written in a cursive style.

R. M. Krich
Manager - Regulatory Affairs

JSK/klb

c: Mr. S. D. Ebnetter, Regional Administrator, USNRC, Region II
Ms. B. L. Mozafari, USNRC Project Manager, HBRSEP
Mr. W. T. Orders, USNRC Senior Resident Inspector, HBRSEP