

United States Nuclear Regulatory Commission
Enclosure 2 to Serial: RNP-RA/96-0128

Enclosure 2
Marked-up And Re-typed Technical Specifications Pages

9608120313 960801
PDR ADDCK 05000261
P PDR

REACTOR TRIP INSTRUMENTATION LIMITING OPERATING CONDITIONSTABLE NOTATIONS

- reactor trip breakers closed
- * With the ~~control rod drive system capable of rod withdrawal~~.
 - ** Below the P-10 (Low Setpoint Power Range Neutron Flux Interlock) setpoint.
 - *** Below the P-6 (Intermediate Range Neutron Flux Interlock) setpoint.
 - **** Above the P-10 (Low Setpoint Power Range Neutron Flux Interlock) setpoint or P-7 (Turbine First Stage Pressure Interlock) setpoint and below the P-8 (Low Setpoint Power Range Neutron Flux Interlock) setpoint.
 - ***** Above the P-10 (Low Setpoint Power Range Neutron Flux Interlock) setpoint or P-7 (Turbine First Stage Pressure Interlock) setpoint.

ACTION STATEMENTS

- ACTION 1 - With the number of OPERABLE channels one less than the Minimum Channels OPERABLE requirement, restore the inoperable channel to OPERABLE status within 12 hours, or be in the Hot Shutdown Condition within the next 8 hours.
- ACTION 2 - With the number of OPERABLE channels one less than the Total Number of Channels, Startup and/or Power Operation may proceed provided the following Conditions are satisfied:
- a. The inoperable channel is placed in the tripped condition within 1 hour.
 - b. Either, thermal power is restricted to less than or equal to 75% of rated power and the Power Range Neutron Flux trip setpoint is reduced to less than or equal to 85% of rated power within 4 hours; or, the Quadrant Power Tilt Ratio is monitored within 12 hours and every 12 hours thereafter, using the movable incore detectors to confirm that the normalized symmetric power distribution is consistent with the indicated Quadrant Power Tilt Ratio.
- ACTION 3 - With the number of channels OPERABLE one less than the Minimum Channels OPERABLE requirement and with the thermal power level:
- a. Below the P-6 (Intermediate Range Neutron Flux Interlock) setpoints, restore the inoperable channel to OPERABLE status prior to increasing thermal power above the P-6 setpoint.
 - b. Above the P-6 (Intermediate Range Neutron Flux Interlock) setpoint but below 10% of rated power, restore the inoperable channel to OPERABLE status prior to increasing thermal power above 10% of rated power.

REACTOR TRIP INSTRUMENTATION LIMITING OPERATING CONDITIONSTABLE NOTATIONS

- ACTION 4 - With the number of OPERABLE channels one less than the Minimum Channels OPERABLE requirement, suspend all operations involving positive reactivity changes.
- ACTION 5 - With the number of OPERABLE channels one less than the Minimum Channels OPERABLE requirement, verify compliance with Shutdown Margin within 1 hour and at least once per 12 hours thereafter.
- ACTION 6 - With the number of OPERABLE channels one less than the Total Number of Channels, Startup and/or Power Operation may proceed until performance of the next required operational test provided the inoperable channel is placed into the tripped condition within 1 hour.
- ACTION 7 - With the number of OPERABLE channels one less than the Total Number of Channels; place the inoperable channel into the tripped condition within 1 hour, and restore the inoperable channel to OPERABLE status within 7 days or be in at least the Hot Shutdown Condition within the next 8 hours.
- ACTION 8 - With the number of OPERABLE channels one less than the Minimum Channels OPERABLE requirement, restore the inoperable channel to OPERABLE status within 48 hours or render the control rods incapable of withdrawal.
Open the Reactor Trip Breakers
- ACTION 9 - Log individual rod position within 1 hour and every hour thereafter, and following load changes of >10% of rated power, or after >30 inches of control rod motion. In addition to the above ACTIONS, if both rod misalignment monitors (15.A and 15.B) are inoperable with reactor power >50% of rated power for 2 hours or more, the nuclear overpower trip shall be reset to $\leq 93\%$ of rated power.
- ACTION 10 - Log individual upper and lower ion chamber currents within 1 hour and every hour thereafter, and following load changes of >10% of rated power, or after >30 inches of control rod motion. In addition to the above ACTIONS, if both rod misalignment monitors (15.A and 15.B) are inoperable with reactor power >50% of rated power for two hours or more, the nuclear overpower trip shall be reset to ≤ 93 percent of rated power.

TABLE 3.5-3

ENGINEERED SAFETY FEATURES INSTRUMENTATION LIMITING OPERATING CONDITIONS

<u>NO.</u>	<u>FUNCTIONAL UNIT</u>	<u>1 TOTAL NO. OF CHANNELS</u>	<u>2 MINIMUM CHANNELS OPERABLE</u>	<u>3 OPERATOR ACTION IF COLUMN 1 OR 2 CANNOT BE MET</u>	<u>APPLICABLE CONDITIONS</u>
1.	SAFETY INJECTION				
A.	Manual	2	2	ACTION 11	>200°F
B.	High Containment Pressure (Hi Level)	3	2	ACTION 12	>200°F
C.	High Differential Pressure between Any Steam Line and the Steam Header	3/Steam Line	2/Steam Line	ACTION 12	#
D.	Pressurizer Low Pressure	3	2	ACTION 12	#
E.	High Steam Flow In 2/3 Steam Lines Coincident with Low T_{avg} in 2/3 loops	2/Steam Line and 1 T_{avg} /Loop	1/Steam Line and 1 T_{avg} in 2 Loops OR 2/Steam Line and 1 T_{avg}	ACTION 12	≥350 °F ##
F.	High Steam Flow In 2/3 Steam Lines Coincident with Low Steam Pressure in 2/3 lines	2/Steam Line and 1 Press/Line	1/Steam Line and 1 Press in 2 Lines OR 2/Steam Line and 1 Press	ACTION 12	≥350 °F ##
2.	CONTAINMENT SPRAY				
A.	Manual	2	2	ACTION 11 ⁽¹³⁾	>200 °F
B.	High Containment Pressure (Hi Hi Level)	3/Set	2/Set	ACTION 12	>200 °F

TABLE 3.5-3 (Continued)

ENGINEERED SAFETY FEATURES INSTRUMENTATION LIMITING OPERATING CONDITIONS



<u>NO.</u>	<u>FUNCTIONAL UNIT</u>	<u>1</u> <u>TOTAL NO.</u> <u>OF</u> <u>CHANNELS</u>	<u>2</u> <u>MINIMUM</u> <u>CHANNELS</u> <u>OPERABLE</u>	<u>3</u> <u>OPERATOR ACTION IF</u> <u>COLUMN 1 OR 2</u> <u>CANNOT BE MET</u>	<u>APPLICABLE</u> <u>CONDITIONS</u>
3.	LOSS OF POWER				
A.	480V Emerg. Bus Undervoltage (Loss of Voltage)	2/Bus	1/Bus	ACTION 	Reactor Critical
B.	480V Emerg. Bus Undervoltage (Degraded Voltage)	3/Bus	2/Bus	ACTION 	Reactor Critical ###

TABLE 3.5-3 (Continued)

ENGINEERED SAFETY FEATURES INSTRUMENTATION LIMITING OPERATING CONDITIONS

TABLE NOTATIONS

- # Above ~~P11~~ Low Pressure SI Block Permit ~~Interlock~~
 ## Trip function may be blocked below ~~P12~~ Low T_{avg} Interlock ~~setpoint~~
 ### The reactor may remain critical below the Power Operating conditions with this feature inhibited for the purpose of starting reactor coolant pumps

ACTION 11 With the number of OPERABLE channels one less than the Minimum Channels OPERABLE requirement, restore the inoperable channel to OPERABLE status within 48 hours or be in at least the Hot Shutdown Condition within the next 8 hours and the Cold Shutdown Condition within the following 30 hours.

ACTION 12 With the number of OPERABLE channels one less than the Total Number of Channels, Power Operation may proceed until performance of the next required operational test provided the inoperable channel is placed into the tripped condition within 1 hour.

ACTION ~~13~~ ¹⁴ With the number of OPERABLE channels one less than the Total Number of Channels; place the inoperable channel into the blocked condition within 1 hour, and restore the inoperable channel to OPERABLE status within 48 hours or be in at least the Hot Shutdown Condition within the next 8 hours and the Cold Shutdown Condition within the following 30 hours.

ACTION 13 With the number of OPERABLE channels one less than the Minimum Channels OPERABLE requirement, restore the inoperable channel to OPERABLE status within 1 hour or be in at least the Hot Shutdown Condition within the next 8 hours and the Cold Shutdown Condition within the following 30 hours.

TABLE 3.5-4

ISOLATION FUNCTIONS INSTRUMENTATION LIMITING OPERATING CONDITIONS

<u>NO.</u>	<u>FUNCTIONAL UNIT</u>	<u>1</u> <u>TOTAL NO.</u> <u>OF</u> <u>CHANNELS</u>	<u>2</u> <u>MINIMUM</u> <u>CHANNELS</u> <u>OPERABLE</u>	<u>3</u> <u>OPERATOR ACTION IF</u> <u>COLUMN 1 OR 2</u> <u>CANNOT BE MET</u>	<u>APPLICABLE</u> <u>CONDITIONS</u>
1.	CONTAINMENT ISOLATION				
	A. Phase A				
	i. Safety Injection	See Item No. 1 of Table 3.5-3 for all Safety Injection initiating functions and requirements			
	ii. Manual	2	2	ACTION 11	>200 °F
	B. Phase B	See Item No. 2 of Table 3.5-3 for all Containment Spray initiating functions and requirements			
	C. Ventilation Isolation				
	i. High Containment Activity, Gaseous	1	0	ACTION 14	During Containment Purge
	ii. High Containment Activity, Particulate	1	0	ACTION 14	During Containment Purge
	iii. Phase A	See Item No. 1.A of Table 3.5-4 for all Phase A initiating functions and requirements			

TABLE 3.5-4 (Continued)

ISOLATION FUNCTIONS INSTRUMENTATION LIMITING OPERATING CONDITIONS

NO.	FUNCTIONAL UNIT	1 TOTAL NO. OF CHANNELS	2 MINIMUM CHANNELS OPERABLE	3 OPERATOR ACTION IF COLUMN 1 OR 2 CANNOT BE MET	APPLICABLE CONDITIONS
2. STEAM LINE ISOLATION					
A. High Steam Flow in 2/3 Steam Lines Coincident with Low T_{avg} in 2/3 loops		See Item No. 1.E of Table 3.5-3 for initiating functions and requirements			
B. High Steam Flow in 2/3 Steam Lines Coincident with Low Steam Pressure in 2/3 lines		See Item No. 1.F of Table 3.5-3 for initiating functions and requirements			
C. High Containment Pressure (Hi Hi Level)		See Item No. 2.B of Table 3.5-3 for initiating functions and requirements			
D. Manual		1/Line	1/Line	ACTION 15 16	≥ 350 °F
3. FEEDWATER LINE ISOLATION					
A. Safety Injection		See Item No. 1 of Table 3.5-3 for all Safety Injection initiating functions and requirements			

TABLE 3.5-4 (Continued)

ISOLATION FUNCTIONS INSTRUMENTATION LIMITING OPERATING CONDITIONS

TABLE NOTATIONS

- ACTION ~~14~~ ¹⁵ - With less than the Total Number of Channels. Power Operation may continue provided the Containment Ventilation Purge and Exhaust valves are maintained closed.
- ACTION ~~15~~ ¹⁶ - With the number of channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 48 hours or declare the associated valve inoperable and take the ACTION required by Specification 3.4.3.

REACTOR TRIP INSTRUMENTATION LIMITING OPERATING CONDITIONSTABLE NOTATIONS

- * With the reactor trip breakers closed.
- ** Below the P-10 (Low Setpoint Power Range Neutron Flux Interlock) setpoint.
- *** Below the P-6 (Intermediate Range Neutron Flux Interlock) setpoint.
- **** Above the P-10 (Low Setpoint Power Range Neutron Flux Interlock) setpoint or P-7 (Turbine First Stage Pressure Interlock) setpoint and below the P-8 (Low Setpoint Power Range Neutron Flux Interlock) setpoint.
- ***** Above the P-10 (Low Setpoint Power Range Neutron Flux Interlock) setpoint or P-7 (Turbine First Stage Pressure Interlock) setpoint.

ACTION STATEMENTS

- ACTION 1 With the number of OPERABLE channels one less than the Minimum Channels OPERABLE requirement, restore the inoperable channel to OPERABLE status within 12 hours, or be in the Hot Shutdown Condition within the next 8 hours.
- ACTION 2 With the number of OPERABLE channels one less than the Total Number of Channels, Startup and/or Power Operation may proceed provided the following Conditions are satisfied:
- a. The inoperable channel is placed in the tripped condition within 1 hour.
 - b. Either, thermal power is restricted to less than or equal to 75% of rated power and the Power Range Neutron Flux trip setpoint is reduced to less than or equal to 85% of rated power within 4 hours; or, the Quadrant Power Tilt Ratio is monitored within 12 hours and every 12 hours thereafter, using the movable incore detectors to confirm that the normalized symmetric power distribution is consistent with the indicated Quadrant Power Tilt Ratio.
- ACTION 3 With the number of channels OPERABLE one less than the Minimum Channels OPERABLE requirement and with the thermal power level:
- a. Below the P-6 (Intermediate Range Neutron Flux Interlock) setpoints, restore the inoperable channel to OPERABLE status prior to increasing thermal power above the P-6 setpoint.
 - b. Above the P-6 (Intermediate Range Neutron Flux Interlock) setpoint but below 10% of rated power, restore the inoperable channel to OPERABLE status prior to increasing thermal power above 10% of rated power.

REACTOR TRIP INSTRUMENTATION LIMITING OPERATING CONDITIONSTABLE NOTATIONS

- ACTION 4 With the number of OPERABLE channels one less than the Minimum Channels OPERABLE requirement, suspend all operations involving positive reactivity changes.
- ACTION 5 With the number of OPERABLE channels one less than the Minimum Channels OPERABLE requirement, verify compliance with Shutdown Margin within 1 hour and at least once per 12 hours thereafter.
- ACTION 6 With the number of OPERABLE channels one less than the Total Number of Channels, Startup and/or Power Operation may proceed until performance of the next required operational test provided the inoperable channel is placed into the tripped condition within 1 hour.
- ACTION 7 With the number of OPERABLE channels one less than the Total Number of Channels, place the inoperable channel into the tripped condition within 1 hour, and restore the inoperable channel to OPERABLE status within 7 days or be in at least the Hot Shutdown Condition within the next 8 hours.
- ACTION 8 With the number of OPERABLE channels one less than the Minimum Channels OPERABLE requirement, restore the inoperable channel to OPERABLE status within 48 hours or open the Reactor Trip Breakers.
- ACTION 9 Log individual rod position within 1 hour and every hour thereafter, and following load changes of >10% of rated power, or after >30 inches of control rod motion. In addition to the above ACTIONS, if both rod misalignment monitors (15.A and 15.B) are inoperable with reactor power >50% of rated power for 2 hours or more, the nuclear overpower trip shall be reset to $\leq 93\%$ of rated power.
- ACTION 10 Log individual upper and lower ion chamber currents within 1 hour and every hour thereafter, and following load changes of >10% of rated power, or after >30 inches of control rod motion. In addition to the above ACTIONS, if both rod misalignment monitors (15.A and 15.B) are inoperable with reactor power >50% of rated power for two hours or more, the nuclear overpower trip shall be reset to ≤ 93 percent of rated power.

TABLE 3.5-3

ENGINEERED SAFETY FEATURES INSTRUMENTATION LIMITING OPERATING CONDITIONS

<u>NO.</u>	<u>FUNCTIONAL UNIT</u>	<u>1 TOTAL NO. OF CHANNELS</u>	<u>2 MINIMUM CHANNELS OPERABLE</u>	<u>3 OPERABLE ACTION IF COLUMN 1 OR 2 CANNOT BE MET</u>	<u>APPLICABLE CONDITIONS</u>
1.	SAFETY INJECTION				
A.	Manual	2	2	ACTION 11	>200°F
B.	High Containment Pressure (Hi Level)	3	2	ACTION 12	>200°F
C.	High Differential Pressure between Any Steam Line and the Steam Header	3/Steam Line	2/Steam Line	ACTION 12	#
D.	Pressurizer Low Pressure	3	2	ACTION 12	#
E.	High Steam Flow In 2/3 Steam Lines Coincident with Low T_{avg} in 2/3 loops	2/Steam Line and 1 T_{avg} Loop	1/Steam Line and 1 T_{avg} in 2 Loops OR 2/Steam Line and 1 T_{avg}	ACTION 12	$\geq 350^\circ\text{F}$ ##
F.	High Steam Flow In 2/3 Steam Lines Coincident with Low Steam Pressure in 2/3 lines	2/Steam Line and 1 Press/Line	1/Steam Line and 1 Press in 2 Lines OR 2/Steam Line and 1 Press	ACTION 12	$\geq 350^\circ\text{F}$ ##
2.	CONTAINMENT SPRAY				
A.	Manual	2	2	ACTION 13	>200°F
B.	High Containment Pressure (Hi Hi Level)	3/Set	2/Set	ACTION 12	>200°F

TABLE 3.5-3 (Continued)

ENGINEERED SAFETY FEATURES INSTRUMENTATION LIMITING OPERATING CONDITIONS

<u>NO.</u>	<u>FUNCTIONAL UNIT</u>	¹ <u>TOTAL NO. OF CHANNELS</u>	² <u>MINIMUM CHANNELS OPERABLE</u>	³ <u>OPERABLE ACTION IF COLUMN 1 OR 2 CANNOT BE MET</u>	<u>APPLICABLE CONDITIONS</u>
3.	LOSS OF POWER				
A.	480V Emerg. Bus Undervoltage (Loss of Voltage)	2/Bus	1/Bus	ACTION 14	Reactor Critical
B.	480V Emerg. Bus Undervoltage (Degraded Voltage)	3/Bus	2/Bus	ACTION 14	Reactor Critical ###

ENGINEERED SAFETY FEATURES INSTRUMENTATION LIMITING OPERATING CONDITIONSTABLE NOTATIONS

- # Above Low Pressure SI Block Permit interlock.
 ## Trip function may be blocked below Low T_{avg} Interlock setpoint.
 ### The reactor may remain critical below the Power Operating conditions with this feature inhibited for the purpose of starting reactor coolant pumps.

- ACTION 11 With the number of OPERABLE channels one less than the Minimum Channels OPERABLE requirement, restore the inoperable channel to OPERABLE status within 48 hours or be in at least the Hot Shutdown Condition within the next 8 hours and the Cold Shutdown Condition within the following 30 hours.
- ACTION 12 With the number of OPERABLE channels one less than the Total Number of Channels. Power Operation may proceed until performance of the next required operational test provided the inoperable channel is placed into the tripped condition within 1 hour.
- ACTION 13 With the number of OPERABLE channels one less than the Minimum Channels OPERABLE requirement, restore the inoperable channel to OPERABLE status within 1 hour or be in at least the Hot Shutdown Condition within the next 8 hours and the Cold Shutdown Condition within the following 30 hours.
- ACTION 14 With the number of OPERABLE channels one less than the Total Number of Channels; place the inoperable channel into the blocked condition within 1 hour, and restore the inoperable channel to OPERABLE status within 48 hours or be in at least the Hot Shutdown Condition within the next 8 hours and the Cold Shutdown Condition within the following 30 hours.

TABLE 3.5-4

ISOLATION FUNCTIONS INSTRUMENTATION LIMITING OPERATING CONDITIONS

<u>NO.</u>	<u>FUNCTIONAL UNIT</u>	<u>1</u> <u>TOTAL NO.</u> <u>OF</u> <u>CHANNELS</u>	<u>2</u> <u>MINIMUM</u> <u>CHANNELS</u> <u>OPERABLE</u>	<u>3</u> <u>OPERABLE ACTION IF</u> <u>COLUMN 1 OR 2</u> <u>CANNOT BE MET</u>	<u>APPLICABLE</u> <u>CONDITIONS</u>
1.	CONTAINMENT ISOLATION				
A.	Phase A				
i.	Safety Injection	See Item No. 1 of Table 3.5-3 for all Safety Injection initiating functions and requirements			
ii.	Manual	2	2	ACTION 11	>200°F
B.	Phase B	See Item No. 2 of Table 3.5-3 for all Containment Spray initiating functions and requirements			
C.	Ventilation Isolation				
i.	High Containment Activity, Gaseous	1	0	ACTION 15	During Containment Purge
ii.	High Containment Activity, Particulate	1	0	ACTION 15	During Containment Purge
iii.	Phase A	See Item No. 1.A of Table 3.5-4 for all Phase A initiating functions and requirements			

TABLE 3.5-4 (Continued)

ISOLATION FUNCTIONS INSTRUMENTATION LIMITING OPERATING CONDITIONS

<u>NO.</u>	<u>FUNCTIONAL UNIT</u>	<u>1</u> <u>TOTAL NO.</u> <u>OF</u> <u>CHANNELS</u>	<u>2</u> <u>MINIMUM</u> <u>CHANNELS</u> <u>OPERABLE</u>	<u>3</u> <u>OPERABLE ACTION IF</u> <u>COLUMN 1 OR 2</u> <u>CANNOT BE MET</u>	<u>APPLICABLE</u> <u>CONDITIONS</u>
2.	STEAM LINE ISOLATION				
	A. High Steam Flow in 2/3 Steam Lines Coincident with Low T_{avg} in 2/3 loops	See Item No. 1.E of Table 3.5-3 for initiating functions and requirements			
	B. High Steam Flow in 2/3 Steam Lines Coincident with Low Steam Pressure in 2/3 lines	See Item No. 1.F of Table 3.5-3 for initiating functions and requirements			
	C. High Containment Pressure (Hi Hi Level)	See Item No. 2.B of Table 3.5-3 for initiating functions and requirements			
	D. Manual	1/Line	1/Line	ACTION 16	$\geq 350^{\circ}\text{F}$
3.	FEEDWATER LINE ISOLATION				
	A. Safety Injection	See Item No. 1 of Table 3.5-3 for all Safety Injection initiating functions and requirements			

ISOLATION FUNCTIONS INSTRUMENTATION LIMITING OPERATING CONDITIONSTABLE NOTATIONS

- | | |
|-----------|---|
| ACTION 15 | With less than the Total Number of Channels, Power Operations may continue provided the Containment Ventilation Purge and Exhaust valves are maintained closed. |
| ACTION 16 | With the number of channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 48 hours or declare the associated valve inoperable and take the ACTION required by Specification 3.4.3. |