

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8001040565 DOC DATE: 79/12/31 NOTARIZED: NO DOCKET #
 FACIL:50-261 H. B. Robinson Plant, Unit 2, Carolina Power and Light 05000261
 AUTH NAME: AUTHOR AFFILIATION
 UTLEY, E.E. Carolina Power & Light Co.
 RECIP NAME: RECIPIENT AFFILIATION
 EISENHUT, D.G. Office of Nuclear Reactor Regulation

SUBJECT: Forwards updated emergency plan in response to 791010 request. Revision 15 does not meet latest emergency planning guidance in technical support ctr, early alert sys & disseminating evacuation info to public areas.

See Rpts
 DISTRIBUTION CODE: A043S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2+125
 TITLE: Emergency Planning Implementation (OL Stage)

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID	CODE/NAME	LTTR	ENCL		ID	CODE/NAME	LTTR	ENCL
ACTION:	7	BC ORB # 1	7	7					
INTERNAL:	1	REG FILE	1	1	15	I & E	2	2	
	17	TA/EDO	1	1	18	CORE PERF BR	1	1	
	19	ENGR BR	1	1	2	NRC PDR	1	1	
	20	REAC SFTY BR	1	1	21	PLANT SYS BR	1	1	
	22	EEB	1	1	23	EFLT TRT SYS	1	1	
	24	BRINKMAN	1	1	3	LPDR	1	1	
	4	NSIC	1	1	5	EPB-DOR	2	2	
		OELD	1	0		STATE PROGRAMS	2	2	
EXTERNAL:	16	ACRS	16	16					

JAN 7 1980

TOTAL NUMBER OF COPIES REQUIRED: LTTR

42

ENCL

41

39

KB
MAY



Carolina Power & Light Company

December 31, 1979

FILE: NG-3514 (B)

SERIAL: GD-79-3305

Mr. D. G. Eisenhut, Acting Director
Division of Operating Reactors
United States Nuclear Regulatory Commission
Washington, D.C. 20555

H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2
DOCKET NO. 50-261
LICENSE NO. DPR-23
UPGRADED SITE EMERGENCY PLAN

Dear Mr. Eisenhut:

In your letter of October 10, 1979, you requested that an upgraded emergency plan for the H. B. Robinson Plant be submitted for NRR review prior to the Emergency Planning Review Team site visit, which is scheduled for early February 1980. In response to your request, Carolina Power & Light Company hereby submits the attached copy of our Carolina Power & Light Company, H. B. Robinson Steam Electric Plant Unit No. 2 Emergency Plan, Revision Number 15 (December 27, 1979).

Areas where Revision Number 15 of our plan does not fully meet the latest emergency planning guidance are:

1) Technical Support Center.

At the present time, we have designated an area for Technical Support that meets present criteria; as defined in Mr. H. R. Denton's letter of October 30, 1979, for NUREG-0578 Item 2.2.2.b, except for instrumentation. A closed circuit television camera that can scan and focus onto pertinent control room instrumentation is being investigated to ascertain its feasibility. It will be installed during 1980 if it is feasible.

2) Disseminating Evacuation Information To The Public.

At this time, we are planning to meet with the local Civil Preparedness Officials to obtain their concurrence with the most efficient and effective methods for accomplishing this task. This information will be incorporated in a subsequent revision to this plan once concurrence is reached.

A043
1/1

F

565


3) Early Alert System.

As in Item 2, we wish to accomplish this in a means that is satisfactory to the NRC, ourselves and the local Civil Preparedness Officials. We have begun to evaluate the present capabilities and the needs for upgrading the necessary equipment. This information will also be incorporated in a subsequent revision to this plan, once the means are found satisfactory by all parties involved.

Revision 15 of the H. B. Robinson Emergency Plan includes changes that are required for it to meet the new Carolina Power & Light Company Emergency Plan, as well as the latest NRC guidance. It is intended that the Plant's plan and the new Corporate Plan will work in concert to pull together company resources to effectively protect the public health and safety in case of an accident involving the plant.

We trust this information is suitable for your use.

Very truly yours,



F. E. E. Utley

Executive Vice President
Power Supply and Customer Services

DBW:jga*

Attachment