5137-E-6311 5

LOCAL CNTRL 'C'

LOCAL CNTRL 'B'

LOCAL CNTRL 'A'

CHARGING PUMPS

C

B

A

CONTROL PANEL 2

DETAIL 1

CONT ON 5137-E-6311 SH. 1

THESE CONDUITS ARE ROUTED WRONG (SEE DIR.)

CONT. ON DWG. 5137-E-6311 SH. 1 OF 6

NOTES:
1. CONTRACTOR TO USE CONDULETS OR OTHER CONDUIT FITTINGS AS REQUIRED
2. ALL CONDUIT RUNS ARE SHOWN DIAGRAMMATICALLY AND FINAL LOCATION TO BE DETERMINED BY FIELD.

NO.	DESCRIPTION
A	ESTABLISHED FOR CLIENT REVIEW
1	INCORP. CLIENT COMMENTS & CONSID. ADVANCED FOR CONSTRUCTION. C. Mack 11/9/79 A. Smith 11/9/79 E. Walker 11/8/79 C. Gould 11/9/79 R. Knott 11/9/79
2	INCORP. CLIENT COMMENT PER MARKED UP DRAWINGS. G. Gould 2-27-79 A. Smith 2-27-79 C. Mack 2-27-79 C. Gould 2-27-79 R. Knott 2-27-79
3	RELOCATED SRV INVERTER, ADDED AND DELETED CONDUITS. R. Knott 5/14/79 A. Smith 5/14/79 E. Walker 5/14/79 GRANTED 5/18/79 CO-01476
4	INCORPORATED DCN-187 REROUTED CONDUITS DS116 & DS117. ADDED CONDUIT DS127. A. Smith 6/4/79 E. Walker 6/4/79 GRANTED 6/4/79 CO-01591
5	INCORP. AS-BUILTS PER MARKED DWG. SDG3113GR2 REV. 1 R. Knott 11-4-79 [illegible] 11-7-79

2ND LEVEL REVIEW COMPLETED

REV.	ENGR.	DATE
A	[illegible]	
1	[illegible]	
2	[illegible]	
3	[illegible]	
4	[illegible]	

SAFETY RELATED

APPROVED FOR CONSTRUCTION

CAROLINA POWER & LIGHT COMPANY
H.B. ROBINSON STEAM ELECTRIC PLANT
CHARGING PUMP ROOM
CONDUIT & GROUNDING

NO. 5137-E-6311 REV. 5

SCALE: 1" = 3'-7"

LEPS

454

800 2110