

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8211090210 DOC. DATE: 82/11/04 NOTARIZED: NO DOCKET #
 FACIL: 50-261 H. B. Robinson Plant, Unit 2, Carolina Power and Light 05000261
 AUTH. NAME AUTHOR AFFILIATION
 ZIMMERMAN, S.R. Carolina Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 VARGA, S.A. Operating Reactors Branch 1

SUBJECT: Forwards "PWR Safety & Relief Valve Test Program, PORV Block
 Valve Adequacy Rept for Carolina Power & Light Co, HB
 Robinson Unit 2," submitted per NUREG-0737, Item II.D.1.3.

DISTRIBUTION CODE: A046S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+7
 TITLE: OR Submittal: TMI Action Plan Rgmt NUREG-0737 & NUREG-0660

NOTES:

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
NRR ORB1 BC 01	7 7		
INTERNAL: ELD/HDS1	1 0	IE/DEP DIR 33	1 1
IE/DEP EPDS	1 1	IE/DEP/EPLB	3 3
NRR/DHFS/DEPY29	1 1	NRR/DL DIR 14	1 1
NRR/DL/ADL 16	1 1	NRR/DL/ADOR 15	1 1
NRR/DL/ADSA 17	1 1	NRR/DL/ORAB 18	3 3
NRR/DSI/ADRP 26	1 1	NRR/DSI/ADRS 27	1 1
NRR/DSI/AEB	1 1	NRR/DSI/RAB	1 1
NRR/DST DIR 30	1 1	REG FILE 04	1 1
RGN2	1 1		
EXTERNAL: ACRS 34	10 10	FEMA-REP DIV	1 1
INPO, J. STARNES	1 1	LPDR 03	1 1
NRC PDR 02	1 1	NSIC 05	1 1
NTIS	1 1		

TOTAL NUMBER OF COPIES REQUIRED: LTTR 44 ENCL 43



Carolina Power & Light Company

NOV 04 1982

Office of Nuclear Reactor Regulation
ATTN: Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1
United States Nuclear Regulatory Commission
Washington, D.C. 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261
LICENSE NO. DPR-23
NUREG-0737, ITEM II.D.1.3
PORV BLOCK VALVE ADEQUACY REPORT

Dear Mr. Varga:

As requested in NUREG-0737, Item II.D.1.3, PORV Block Valve Adequacy, Carolina Power & Light Company (CP&L) hereby submits the PORV Block Valve Adequacy Report for the H. B. Robinson Steam Electric Plant Unit 2 (HBR2). The report is enclosed for your review.

This report indicates that the PORV block valves for HBR2 are bounded by the valves and test parameters and confirm the ability of the PORV block valves to open and close on demand.

If you have any questions regarding this report, please contact a member of my staff.


Yours very truly,

S. R. Zimmerman
Manager

Licensing & Permits

SRZ/lr (5680C4T4b)
Enclosure

cc: Mr. J. P. O'Reilly (NRC-RII)
Mr. G. Requa (NRC)
Mr. Steve Weise (NRC-HBR)



A046