

6-RJ-
request returned
3/7/83
NRC
CP&L

PRP
D-1111

Carolina Power & Light Company

JAN 31 1983

TE HQ FILE COPY

Mr. James P. O'Reilly, Regional Administrator
United States Nuclear Regulatory Commission
Region II
101 Marietta Street, N.W., Suite 3100
Atlanta, GA 30303

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261/K
LICENSE NO. DPR-23
BRUNSWICK STEAM ELECTRIC PLANT, UNIT NOS. 1 AND 2
DOCKET NOS. 50-325 AND 50-324
LICENSE NOS. DPR-71 AND DPR-62
RESPONSE TO CONFIRMATION OF ACTION -
EMERGENCY PREPAREDNESS PROGRAM

Dear Mr. O'Reilly:

Carolina Power & Light Company (CP&L) has received your letter dated November 1, 1982, regarding Confirmation of Action - Emergency Preparedness Program for the H. B. Robinson Steam Electric Plant, Unit 2 (HBR2) and the Brunswick Steam Electric Plant (BSEP). The confirmation of action letter confirms our plan to resolve the concerns over Emergency Action Level format. This letter is to report the status of our actions to correct these concerns.

The understood actions, to resolve apparent deficiencies in the Emergency Preparedness Program, follow with our response to each action.

Understood Action

1. "Revise plant procedure PEP-2.1 entitled Initial Emergency Actions to facilitate prompt review and classification of an accident condition. The revised procedure should be organized such that the user can quickly find the Emergency Action Level (EAL) of interest and make the appropriate classification based on the EAL."

CP&L Response

A review of procedure PEP-2.1 was conducted at HBR2 and BSEP to determine an appropriate format to identify EALs which could aid personnel in more readily and accurately classifying emergency events. Subsequently, procedure PEP-2.1 was revised on December 21, 1982 and December 22, 1982 for HBR2 and BSEP respectively. These procedures were submitted to your office on January 17, 1983 and January 10, 1983 for HBR2 and BSEP respectively.

83-17
OFFICIAL COPY

| |
|--------------------|
| 8306140708 830331 |
| PDR ADOCK 05000261 |
| Q PDR |

Understood Action

2. "Conduct a training program for control room operators and key members of the Technical Support Center staff on use of the revised procedure, PEP-2.1."

CP&L Response

A training program to familiarize appropriate plant personnel with the revised procedure was completed on January 15, 1983 for HBR2 and January 27, 1983 for BSEP, with the exception of one employee who is away from the plant due to emergency family circumstances. This employee will complete the applicable training before resuming his duties at the plant.

Understood Action

3. "It is our understanding that these actions are scheduled for completion by February 1, 1983. Submit a written report to the Regional Administrator, NRC Region II, by that date describing actions taken in the above areas and for those actions not complete, providing the planned completion schedule."


CP&L Response

See responses to Understood Action Items 1 and 2.

Carolina Power & Light Company believes that these concerns have been satisfactorily resolved at HBR2 and BSEP.

If you have any further questions regarding this matter, please contact a member of my staff.

Yours very truly,



E. E. Utley
Executive Vice President
Power Supply and
Engineering & Construction

DCW/kjr (6078C10T4)

cc: Messrs. D. O. Myers (NRC-BSEP)
G. Requa (NRC)
S. D. MacKay (NRC)
S. Weise (NRC-HBR)