

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9011010221 DOC. DATE: 90/10/26 NOTARIZED: NO DOCKET #
 FACIL: 50-261 H.B. Robinson Plant, Unit 2, Carolina Power & Light C 05000261
 AUTH. NAME AUTHOR AFFILIATION
 SHEPPARD, J.J. Carolina Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Informs that util will do work effecting equipment covered under plant Fire Protection Tech Specs on 901026.

DISTRIBUTION CODE: A006D COPIES RECEIVED: LTTR 1 ENCL 0 SIZE: 2
 TITLE: OR/Licensing Submittal: Fire Protection

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES		
	ID	CODE/NAME	LTTR	ENCL		ID	CODE/NAME	LTTR	ENCL	
	PD2-1	LA	1	0		PD2-1	PD	1	1	
	LO,R		2	2						
INTERNAL:	NRR	WERMEIL, J	1	0		NRR/DET/ECMB	9H	2	2	
	NRR/DST	8E2	1	1		NRR/DST/SPLB8D1		1	1	
	NUDOCS-ABSTRACT		1	1		OC/LEMB		1	0	
	OGC/HDS1		1	0		REG FILE	01	1	1	
EXTERNAL:	NRC	PDR	1	1		NSIC		1	1	

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 15 ENCL 0

MA 24



Carolina Power & Light Company

ROBINSON NUCLEAR PROJECT DEPARTMENT
POST OFFICE BOX 790
HARTSVILLE, SOUTH CAROLINA 29550

OCT. 26 1990

Robinson File No: 13510C

Serial: RNP/90-3573

United States Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

H. B. ROBINSON STEAM ELECTRIC PLANT
DOCKET NO. 50-261
LICENSE NO. DPR-23
INFORMATION REPORT ON ACTIVITIES AFFECTING A FIRE BARRIER

Gentlemen:

The purpose of this letter is to inform the NRC of Carolina Power and Light Company's intent regarding work which will affect equipment covered under the Plant Fire Protection Technical Specifications. Specifically, in order to accomplish reconditioning of the Component Cooling Water (CCW) heat exchangers, it is necessary to remove a section of a block wall located at the south end of the CCW heat exchanger room, which is in the Reactor Auxiliary Building. This wall constitutes an Appendix R fire barrier in Fire Area "C" (Fire Zone 5), as described in the Updated FSAR, Appendix 9.5.1A.

The fire barrier is scheduled to be removed from service on or about October 26, 1990 in order to allow for heat exchanger tube removal and replacement activities. This work is being performed with the Plant in a refueling outage, and is scheduled to be performed twenty-four hours a day until the fire barrier can be returned to service.

With the fire barrier inoperable, the compensatory actions required by Technical Specification 3.14.7.2 will be taken. It should be noted that at the present Plant condition this Technical Specification is not applicable because the equipment in this room is not required to be in service.

9011010221 901026
PDR ADOCK 05000261
F PNU

000034

A006
1/0

Memorandum


Serial: RNP/90-3573

Page 2

Exceeding the Action Statement of Technical Specification 3.14.7 would require that a 30 Day Special Report be submitted identifying the reason the equipment was out of service, compensatory actions taken, and the plans for restoring the equipment to operable status. This letter provides such report in advance. Carolina Power and Light Company will keep the NRC Resident Office informed of activities associated with the above project while the equipment is out of service.

If you have any questions regarding this subject, please contact Mr. J. D. Kloosterman, 803-383-1491.

Very truly yours,



J. J. Sheppard
General Manager

H. B. Robinson S. E. Plant

RDC:kgs

cc: Mr. S. D. Ebnetter
Mr. L. W. Garner