

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

SUBJECT: Submits 1990 Annual Rept on Primary Coolant Iodine Spikes.

NOTES:

RECIPIENT		COPIES		RECIPIENT		COPIES	
ID CODE/NAME		LTTR	ENCL	ID CODE/NAME		LTTR	ENCL
PD2-1 LA		1	1	PD2-1 PD		1	1
LO, R		2	2				
INTERNAL: NRR/DET/ECMB 9H		1	1	NRR/DET/ESGB		1	1
NRR/DOEA/OTSB11		1	1	NRR/DST 8E2		1	1
NRR/DST/SELB 8D		1	1	NRR/DST/SICB 7E		1	1
NRR/DST/SRXB 8E		1	1	NUDOCS-ABSTRACT		1	1
OC/LEMB		1	0	OGC/HDS1		1	0
REG FILE 01		1	1	RES/DSIR/EIB		1	1
EXTERNAL: NRC PDR		1	1	NSIC		1	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 18 ENCL ~~16~~

R
I
D
S
/
A
D
D
S

R
I
D
S
/
A
D
D
S



Carolina Power & Light Company

ROBINSON NUCLEAR PROJECT DEPARTMENT
POST OFFICE BOX 790
HARTSVILLE, SOUTH CAROLINA 29550

JAN 15 1991

Robinson File No. 13510C

Serial: RNP/91-0059

United States Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261
LICENSE NO. DPR-23
1990 ANNUAL REPORT - PRIMARY COOLANT IODINE SPIKES

Dear Sir:

Carolina Power and Light Company submits the 1990 Annual Report on Primary Coolant Iodine Spikes. This annual report is submitted as required by Technical Specification 6.9.1.b.

During 1990, the primary coolant did not exceed 1.0 $\mu\text{Ci}/\text{gram}$ dose equivalent I-131 nor did the Gross Activity exceed 100/E-Bar $\mu\text{Ci}/\text{gram}$ as set forth in Technical Specification 3.1.4.

If you have any questions concerning this report, please contact my staff or me.

Very truly yours,

J. J. Sheppard
General Manager
H. B. Robinson S. E. Plant

KTK:lht

cc: S. D. Ebnetter
L. W. Garner

9101230149 910115
PDR ADOCK 05000261
R PDR

A001
70