

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9102250242 DOC. DATE: 91/02/19 NOTARIZED: NO DOCKET #
 FACIL: 50-261 H.B. Robinson Plant, Unit 2, Carolina Power & Light Co 05000261
 AUTH. NAME AUTHOR AFFILIATION
 FLOYD, S.D. Carolina Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards "Maint Surveillance Test Procedure Station Battery
 Svc Test," per 900919 amend application.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 147
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-1 LA	1 1	PD2-1 PD	1 1
	LO, R	2 2		
INTERNAL:	NRR/DET/ECMB 9H	1 1	NRR/DET/ESGB	1 1
	NRR/DOEA/OTSB11	1 1	NRR/DST 8E2	1 1
	NRR/DST/SELB 8D	1 1	NRR/DST/SICB 7E	1 1
	NRR/DST/SRXB 8E	1 1	NUDOCS-ABSTRACT	1 1
	OC/LFMB	1 0	OGC/HDS2	1 0
	<u>REG FILE 01</u>	1 1	RES/DSIR/EIB	1 1
EXTERNAL:	NRC PDR	1 1	NSIC	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 18 ENCL 16

MA4/ub



Carolina Power & Light Company

FEB 19 1991

SERIAL: NLS-90-265

United States Nuclear Regulatory Commission
ATTENTION: Document Control Desk
Washington, DC 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261/LICENSE NO. DPR-23
STATION BATTERY TEST RESULTS

Gentlemen:

Carolina Power & Light Company (CP&L) submitted a license amendment request dated September 19, 1990 which would require the performance of a station battery service test at refueling intervals. Although the amendment had not yet been approved, CP&L committed to perform the test during Refueling Outage No. 13 (fall 1990). Because of NRC questions regarding the adequacy of the batteries, CP&L committed to provide results of the test.

Please note that each battery's service test was conducted with the design load profile, including additional design margins. As reflected in the enclosed test results documentation, both batteries performed satisfactorily.

Questions regarding this matter may be referred to Mr. R. W. Prunty at (919) 546-7318.

Yours very truly,

S. D. Floyd
Manager

Nuclear Licensing Section

RNP/mew/jbw (944RNP)

Enclosure

cc: Mr. S. D. Ebnetter
Mr. L. Garner (NRC-HBR)
Mr. R. Lo

Handwritten: A001
11/11

411 Fayetteville Street • P. O. Box 1551 • Raleigh, N. C. 27602

9102250242-910219
PDR ADOCK 05000261
PDR