

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9202040333 DOC. DATE: 92/01/28 NOTARIZED: NO DOCKET #  
 FACIL: 50-261 H.B. Robinson Plant, Unit 2, Carolina Power & Light Co 05000261  
 AUTH. NAME AUTHOR AFFILIATION  
 ROBINSON, H.B. Carolina Power & Light Co.  
 CHAMBERS, R.H. Carolina Power & Light Co.  
 RECIP. NAME RECIPIENT AFFILIATION  
 Document Control Branch (Document Control Desk)

SUBJECT: Submits 1991 annual rept on primary coolant iodine spikes.  
 Primary coolant did not exceed 1 uCi/gram dose equivalent  
 I-131 nor did gross activity exceed 100/E-Bar uCi/gram.

DISTRIBUTION CODE: IE47D COPIES RECEIVED: LTR / ENCL 0 SIZE:             
 TITLE: 50.59 Annual Report of Changes, Tests or Experiments Made W/out Approv /

### NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES		
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL	
	PD2-1 LA		1	0		PD2-1 PD		5	5	
	LO, R		1	0						
INTERNAL:	AEOD/DOA		1	1		AEOD/DSP/TPAB		1	1	
	NRR/DLPO/LHFB11		1	1		NRR/DOEA/OEAB11		1	1	
	REG FILE 02		1	1		RGN2 FILE 01		1	1	
EXTERNAL:	NRC PDR		1	1		NSIC		1	1	

### NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 15 ENCL 13  
0

*MA*  
*2/2/92*



Carolina Power & Light Company

ROBINSON NUCLEAR PROJECT DEPARTMENT  
POST OFFICE BOX 790  
HARTSVILLE, SOUTH CAROLINA 29550

JAN 28 1992

Robinson File No. 13510C

Serial: RNP/92-0139

United States Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D.C. 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2  
DOCKET NO. 50-261  
LICENSE NO. DPR-23  
1991 ANNUAL REPORT - PRIMARY COOLANT IODINE SPIKES

Dear Sir:

Carolina Power and Light Company submits the 1991 Annual Report on Primary Coolant Iodine Spikes. This annual report is submitted as required by Technical Specification 6.9.1.b.

During 1991, the primary coolant did not exceed 1.0  $\mu\text{Ci}/\text{gram}$  dose equivalent I-131 nor did the Gross Activity exceed 100/E-Bar  $\mu\text{Ci}/\text{gram}$  as set forth in Technical Specification 3.1.4.

If you have any questions concerning this report, please contact my staff or me.

Very truly yours,

R. H. Chambers  
General Manager  
H. B. Robinson S. E. Plant

MLM:sgk

cc: S. D. Ebnetter  
L. W. Garner

030162

9202040333 920128  
PDR ADOCK 05000261  
R PDR

TE47  
1/2