

# ACCELERATED DOCUMENT DISTRIBUTION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9302230048      DOC. DATE: 93/02/17      NOTARIZED: NO      DOCKET #  
FACIL: 50-261 H.B. Robinson Plant, Unit 2, Carolina Power & Light Co      05000261  
AUTH. NAME      AUTHOR AFFILIATION  
CHAMBERS, R.H.      Carolina Power & Light Co.  
RECIP. NAME      RECIPIENT AFFILIATION  
Document Control Branch (Document Control Desk)

SUBJECT: Submits 1992 Annual Rept on Primary Coolant Iodine Spikes,  
per TS 6.9.1.2, Item 2. During 1992, primary coolant did not  
exceed 1.0 uCi/gam dose equivalent I-131, nor did gross  
activity exceed 100/E-Bar uCi/gram, per TS 3.1.4.

DISTRIBUTION CODE: A001D      COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1  
TITLE: OR Submittal: General Distribution

## NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-1 LA	1 1	PD2-1 PD	1 1
	MOZAFARI, B	2 2		
INTERNAL:	NRR/DET/ESGB	1 1	NRR/DOEA/OTSB11	1 1
	NRR/DST/SELB 7E	1 1	NRR/DST/SICB8H7	1 1
	NRR/DST/SRXB 8E	1 1	NUDOCS-ABSTRACT	1 1
	OC/LEMB	1 0	OGC/HDS2	1 0
	<u>REG FILE</u> 01	1 1		
EXTERNAL:	NRC PDR	1 1	NSIC	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 15 ENCL 13



Carolina Power & Light Company

ROBINSON NUCLEAR PLANT  
POST OFFICE BOX 790  
HARTSVILLE, SOUTH CAROLINA 29551

FEB 17 1993

Robinson File No. 13510C

Serial: RNP/93-0346

United States Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D.C. 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2  
DOCKET NO. 50-261  
LICENSE NO. DPR-23  
1992 ANNUAL REPORT - PRIMARY COOLANT IODINE SPIKES

Dear Sir:

Carolina Power and Light Company submits the 1992 Annual Report on Primary Coolant Iodine Spikes. This annual report is submitted as required by Technical Specification 6.9.1.2 Item 2.

During 1992, the primary coolant did not exceed 1.0  $\mu\text{Ci}/\text{gram}$  dose equivalent I-131, nor did the Gross Activity exceed 100/E-Bar  $\mu\text{Ci}/\text{gram}$  as set forth in Technical Specification 3.1.4.

If you have any questions concerning this report, please contact me or my staff.

Very truly yours,

R. H. Chambers  
General Manager  
H. B. Robinson S. E. Plant

MLM:lst

cc: S. D. Ebnetter  
L. W. Garner

020089  
9302230048 930217  
PDR ADDCK 05000261  
R PDR

A001  
1/10