

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8711190163 DOC DATE: 87/11/13 NOTARIZED: NO DOCKET #
 FACIL: 50-261 H. B. Robinson Plant, Unit 2, Carolina Power & Light Co 05000261
 AUTH. NAME AUTHOR AFFILIATION
 ZIMMERMAN, S. R. Carolina Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Advises that full compliance w/IE Bulletin 85-03 per 860730
 until ltr will be delayed because of need to adjust switch
 settings. Final rept will address outstanding items & will be
 submitted by 880115.

DISTRIBUTION CODE: IE11D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: Bulletin Response (50 DKT)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-1 LA	1	PD2-1 PD	1
	ECCLESTON, K	1		
INTERNAL:	AEOD/DOA	1	AEOD/DSP	1
	AEOD/DSP/TPAB	1	NRR/DEST/ADE	1
	NRR/DEST/ADS	1	NRR/DEST/MEB	1
	NRR/DOEA/EAB	1	NRR/DOEA/GCB	1
	NRR/DRER/EPB	1	NRR/PMAS/ILRB	1
	<u>REG FILE</u> 02	1	RES/DE/EIB	1
	RGN2 FILE 01	1		
EXTERNAL:	LPDR	1	NRC PDR	1
	NSIC	1		

TOTAL NUMBER OF COPIES REQUIRED: LTTR 19 ENCL 2



Carolina Power & Light Company

NOV 13 1987

SERIAL: NLS-87-259

United States Nuclear Regulatory Commission
ATTENTION: Document Control Desk
Washington, DC 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261/LICENSE NO. DPR-23
INFORMATION REGARDING IE BULLETIN 85-03

Gentlemen:

Carolina Power & Light Company's letter dated July 30, 1986 described the program and compliance schedule for IE Bulletin 85-03 (IEB 85-03). The letter also committed to provide a final report within 60 days of completion of the IEB 85-03 requirements.

The Bulletin actions are essentially complete; however, recent comparison of certain calculated switch-settings with actual settings as determined by field inspection and testing have resulted in the need for additional evaluation to ensure proper adjustment of switches. This evaluation will delay full implementation of the program.

Outstanding items will be addressed in the final report to be submitted by January 15, 1988.

Questions regarding this matter may be referred to Mr. Robert W. Prunty at (919) 836-7318.

Yours very truly,

S. R. Zimmerman / RWP

S. R. Zimmerman
Manager
Nuclear Licensing Section

JSK/bmc (5341JSK)

cc: Dr. J. Nelson Grace
Mr. K. Eccleston
NRC Resident Inspector - RNP

8711190163 871113
PDR ADDCK 05000261
Q PDR

IEB
1/0