

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8907170396 DOC.DATE: 89/06/30 NOTARIZED: NO DOCKET #
 FACIL:50-261 H.B. Robinson Plant, Unit 2, Carolina Power & Light C 05000261
 AUTH.NAME AUTHOR AFFILIATION
 HAYNESWORTH,V. Carolina Power & Light Co.
 MORGAN,R.E. Carolina Power & Light Co.
 RECIP.NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Monthly operating rept for Jun 1989 for H.B.Robinson,Unit 2.
 W/890706 Ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 3
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-1 LA	3 3	PD2-1 PD	1 1
	LO,R	1 1		
INTERNAL:	AEOD/DOA	1 1	AEOD/DSP/TPAB	1 1
	IRM TECH ADV	2 2	NRR/DLPQ/PEB 10	1 1
	NRR/DOEA/EAB 11	1 1	NRR/DREP/RPB 10	1 1
	NUDOCS-ABSTRACT	1 1	REG <u>FILE</u> 01	1 1
	RGN2	1 1		
EXTERNAL:	EG&G SIMPSON,F	1 1	LPDR	1 1
	NRC PDR	1 1	NSIC	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 19 ENCL 19

*Monthly Rpt
exp*

R
I
D
S
/
A
D
D
S

R
I
D
S
/
A
D
D
S



Carolina Power & Light Company

ROBINSON NUCLEAR PROJECT DEPARTMENT
POST OFFICE BOX 790
HARTSVILLE, SOUTH CAROLINA 29550

JUL 06 1989

Robinson File: 15505

Serial: RNP/89-2329

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261
LICENSE NO. DPR-23
MONTHLY OPERATIONS REPORT

Gentlemen:

In accordance with Technical Specifications 6.9.1.c for the H. B. Robinson Steam Electric Plant, Unit No. 2, Carolina Power and Light Company herewith submits the report of operation statistics and shutdown experience for the month of June 1989.

Very truly yours,

R. E. Morgan
General Manager
H. B. Robinson S. E. Plant

VFH:lko

Enclosure

cc: S. D. Ebnetter
L. W. Garner

8907170396 890700
PDR ADOCK 05000261
R PNU

IE24
1/1

CP&L CO
RUN DATE 07/05/89
RUN TIME 10:54:19

PLANT PERFORMANCE DATA SYSTEM
OPERATING DATA REPORT
ROBINSON UNIT 2

PAGE 1
RPD36-000

Enclosure to Serial: RNPd/89-2329

Page 1 of 2

OPERATING STATUS

DOCKET NO. 050-0261

COMPLETED BY V.F. HAYNESWORTH

TELEPHONE (803)383-4524

	NOTES
1. UNIT NAME: ROBINSON UNIT 2	
2. REPORTING PERIOD: JUNE 89	
3. LICENSED THERMAL POWER (MWT): 2300	There are presently 310 fuel
4. NAMEPLATE RATING (GROSS MWE): 739.0	assemblies in the Spent Fuel Pool,
5. DESIGN ELECTRICAL RATING (NET MWE): 700.0	and 56 fuel assemblies in the
6. MAX DEPENDABLE CAPACITY (GROSS MWE): 700.0	Horizontal Storage Modules.
7. MAX DEPENDABLE CAPACITY (NET MWE): 665.0	
8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS 3 THRU 7) SINCE LAST REPORT, GIVE REASONS: N/A	

9. POWER LEVEL TO WHICH RESTRICTED IF ANY (NET MWE): None
10. REASONS FOR RESTRICTION IF ANY: N/A

	THIS MONTH	YR TO DATE	CUMUL ATIVE
11. HOURS IN REPORTING PERIOD	720.00	4343.00	160727.00
12. NUMBER OF HOURS REACTOR CRITICAL	720.00	2773.91	114095.48
13. REACTOR RESERVE SHUTDOWN HRS	.00	.00	3314.65
14. HOURS GENERATOR ON LINE	720.00	2658.19	111404.55
15. UNIT RESERVE SHUTDOWN HOURS	.00	.00	23.20
16. GROSS THERMAL ENERGY GEN. (MWH)	1640715.12	5805389.52	224514937.92
17. GROSS ELEC. ENERGY GEN. (MWH)	530424.00	1901503.00	72666225.00
18. NET ELEC. ENERGY GENERATED (MWH)	505578.00	1795042.00	68600728.00
19. UNIT SERVICE FACTOR	100.00	61.21	69.31
20. UNIT AVAILABILITY FACTOR	100.00	61.21	69.33
21. UNIT CAP. FACTOR (USING MDC NET)	105.59	62.15	64.18
22. UNIT CAP. FACTOR (USING DER NET)	100.31	59.05	60.97
23. UNIT FORCED OUTAGE RATE	.00	11.75	14.49
24. SHUTDOWNS SCHED. OVER NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH):			

None

25. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF START UP:

26. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION): FORECAST ACHIEVED

INITIAL CRITICALITY

INITIAL ELECTRICITY

COMMERCIAL OPERATION

CP&L CO
RUN DATE 07/05/89
RUN TIME 10:54:16

PLANT PERFORMANCE DATA SYSTEM
APPENDIX B - AVERAGE DAILY POWER LEVEL
ROBINSON UNIT 2

PAGE 1
RPD39-000

Enclosure to Serial: RNP/89-2329
Page 2 of 2

DOCKET NO. 050-0261
COMPLETED BY V.F. HAYNESWORTH
TELEPHONE (803)383-4524

JUNE 1989

DAY	AVG. DAILY POWER LEVEL (MWE-NET)	DAY	AVG. DAILY POWER LEVEL (MWE-NET)
1	711	17	708
2	710	18	708
3	711	19	704
4	652	20	706
5	712	21	707
6	709	22	708
7	709	23	706
8	709	24	609
9	709	25	701
10	708	26	700
11	706	27	701
12	708	28	703
13	709	29	706
14	710	30	703
15	712		
16	710		

1.16 - 8

* Note: There are no unit shutdowns or power reductions reportable for June.