

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9001220006 DOC. DATE: 89-12-31 NOTARIZED: NO DOCKET #
 FACIL: 50-261 H.B. Robinson Plant, Unit 2, Carolina Power & Light Co 05000261
 AUTH. NAME AUTHOR AFFILIATION
 HAYNESWORTH, V. Carolina Power & Light Co.
 MORGAN, R.E. Carolina Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Dec 1989 for HB Robinson Unit 2.
W/900109 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTTR 1 ENCL 1 SIZE: 4
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-1 LA	3 3	PD2-1 PD	1 1
	LO, R	1 1		
INTERNAL:	AEOD/DOA	1 1	AEOD/DSP/TPAB	1 1
	IRM TECH ADV	2 2	NRR/DLPQ/LPEB10	1 1
	NRR/DOEA/OEAB11	1 1	NRR/DREP/PRPB11	1 1
	NUDOCS-ABSTRACT	1 1	<u>REG FILE</u> 01	1 1
	RGN2	1 1		
EXTERNAL:	EG&G SIMPSON, F	1 1	LPDR	1 1
	NRC PDR	1 1	NSIC	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 19 ENCL 19

mo. Rpt.



Carolina Power & Light Company

ROBINSON NUCLEAR PROJECT DEPARTMENT
POST OFFICE BOX 790
HARTSVILLE, SOUTH CAROLINA 29550
JAN. 9 1990

Robinson File: 15505

Serial: RNP/90-0033

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261
LICENSE NO. DPR-23
MONTHLY OPERATIONS REPORT

Gentlemen:

In accordance with Technical Specification 6.9.1.c for the H. B. Robinson Steam Electric Plant, Unit No. 2, Carolina Power and Light Company herewith submits the report of operation statistics and shutdown experience for the month of December 1989.

Very truly yours,

R. E. Morgan
General Manager
H. B. Robinson S. E. Plant

VFH:jch

Enclosure

cc: S. D. Ebnetter
L. W. Garner

9001220006 891231
FDR ADOCK 05000261
R PDC

JE24
11

CP&L CO.
RUN DATE 01/03/90
RUN TIME 14:23:55

PLANT PERFORMANCE DATA SYSTEM
OPERATING DATA REPORT
ROBINSON UNIT 2

PAGE 1
RPD36-000

Enclosure to Serial: RNPD/90-0033

Page 1 of 3
OPERATING STATUS

DOCKET NO. 050-0261
COMPLETED BY V.F. HAYNESWORTH
TELEPHONE (803)383-4524

1. UNIT NAME: ROBINSON UNIT 2		NOTES	There are presently	
2. REPORTING PERIOD: DECEMBER 89		310 fuel assemblies in the		
3. LICENSED THERMAL POWER (MWT): 2300		Spent Fuel Pool and 56 fuel		
4. NAMEPLATE RATING (GROSS MWE): 739.0		assemblies in the Horizontal		
5. DESIGN ELECTRICAL RATING (NET MWE): 700.0		Storage Modules.		
6. MAX DEPENDABLE CAPACITY (GROSS MWE): 700.0				
7. MAX DEPENDABLE CAPACITY (NET MWE): 665.0				
8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS 3 THRU 7) SINCE LAST REPORT, GIVE REASONS: N/A				

9. POWER LEVEL TO WHICH RESTRICTED IF ANY (NET MWE): None
10. REASONS FOR RESTRICTION IF ANY: N/A

	THIS MONTH	YR TO DATE	CUMUL ATIVE
11. HOURS IN REPORTING PERIOD	744.00	8760.00	165144.00
12. NUMBER OF HOURS REACTOR CRITICAL	237.80	4262.04	115583.61
13. REACTOR RESERVE SHUTDOWN HRS	.00	.00	3314.65
14. HOURS GENERATOR ON LINE	201.75	4109.71	112856.07
15. UNIT RESERVE SHUTDOWN HOURS	.00	.00	23.20
16. GROSS THERMAL ENERGY GEN. (MWH)	406895.76	9062255.76	227771804.16
17. GROSS ELEC. ENERGY GEN. (MWH)	135864.00	2948972.00	73713694.00
18. NET ELEC. ENERGY GENERATED (MWH)	125121.00	2778551.00	69584237.00
19. UNIT SERVICE FACTOR	27.12	46.91	68.34
20. UNIT AVAILABILITY FACTOR	27.12	46.91	68.35
21. UNIT CAP. FACTOR (USING MDC NET)	25.29	47.70	63.36
22. UNIT CAP. FACTOR (USING DER NET)	24.02	45.31	60.19
23. UNIT FORCED OUTAGE RATE	72.88	44.68	16.21
24. SHUTDOWNS SCHED. OVER NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH):			

None

25. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF START UP:
26. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION): FORECAST ACHIEVED

INITIAL CRITICALITY

INITIAL ELECTRICITY

COMMERCIAL OPERATION

CP&L CO
RUN DATE 01/03/90
RUN TIME 14:22:18

PLANT PERFORMANCE DATA SYSTEM
APPENDIX B - AVERAGE DAILY POWER LEVEL
ROBINSON UNIT 2

PAGE 1
RPD39-000

Enclosure to Serial: RNP/90-0033
Page 2 of 3

DOCKET NO. 050-0261
COMPLETED BY V.F. HAYNESWORTH
TELEPHONE (803)383-4524

DECEMBER 1989

DAY	AVG. DAILY POWER LEVEL (MWE-NET)	DAY	AVG. DAILY POWER LEVEL (MWE-NET)
1	-4	17	-5
2	-4	18	-11
3	-4	19	-22
4	-4	20	-19
5	-4	21	-21
6	-4	22	-22
7	-4	23	51
8	-4	24	426
9	-4	25	633
10	-4	26	632
11	-3	27	669
12	-4	28	738
13	-4	29	740
14	-4	30	742
15	-4	31	745
16	-5		

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH December

DOCKET NO. 050-0261
 UNIT NAME H. B. Robinson
 DATE 01/03/90
 COMPLETED BY V. F. Haynesworth
 TELEPHONE (803) 383-4524

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
0801*	890822	F	542.25	D	1	89-010	WG	PIPEXX	<p>The unit was forced offline due to a 24-hour LCO involving the Auxiliary Feedwater System. The outage was extended into December to resolve an Electrical Distribution System problem. After repairs and modifications, the unit was returned to service on 12/23/89.</p> <p>* Continued from previous month</p>

¹
 F: Forced
 S: Scheduled

²
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance of Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³
 Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

⁴
 Exhibit G - Instructions
 for Preparation of Data
 Entry Sheets for Licensee
 Event Report (LER) File (NUREG-
 0161)

⁵
 Exhibit I - Same Source