

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9102280209 DOC. DATE: 91/02/22 NOTARIZED: NO DOCKET #  
 FACIL: 50-261 H.B. Robinson Plant, Unit 2, Carolina Power & Light C 05000261  
 AUTH. NAME AUTHOR AFFILIATION  
 SHEPPARD, J.J. Carolina Power & Light Co.  
 RECIP. NAME RECIPIENT AFFILIATION  
 Document Control Branch (Document Control Desk)

SUBJECT: Special rept: on 910124, discovered that spare conduit penetration, used to pass hydrostatic test hoses from reactor auxiliary bldg hallway to outside, exceeded LCO time limit. Caused by breakdown in communication.

DISTRIBUTION CODE: IE22D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2  
 TITLE: 50.73/50.9 Licensee Event Report (LER), Incident Rpt, etc.

### NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-1 LA	1 1	PD2-1 PD	1 1
	LO, R	1 1		
INTERNAL:	ACNW	2 2	AEOD/DOA	1 1
	AEOD/DSP/TPAB	1 1	AEOD/ROAB/DSP	2 2
	NRR/DET/ECMB 9H	1 1	NRR/DET/EMEB 7E	1 1
	NRR/DLPQ/LHFB11	1 1	NRR/DLPQ/LPEB10	1 1
	NRR/DOEA/OEAB	1 1	NRR/DREP/PRPB11	2 2
	NRR/DST/SELB 8D	1 1	NRR/DST/SICB 7E	1 1
	NRR/DST/SPLB8D1	1 1	NRR/DST/SRXB 8E	1 1
	REG FILE 02	1 1	RES/DSIR/EIB	1 1
	RGN2 FILE 01	1 1		
EXTERNAL:	EG&G BRYCE, J.H	3 3	L ST LOBBY WARD	1 1
	NRC PDR	1 1	NSIC MAYS, G	1 1
	NSIC MURPHY, G.A	1 1	NUDOCS FULL TXT	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 31 ENCL ~~31~~ 0

IA 2/10/91



Carolina Power & Light Company

ROBINSON NUCLEAR PROJECT DEPARTMENT  
POST OFFICE BOX 790  
HARTSVILLE, SOUTH CAROLINA 29550

FEB 22 1991

Robinson File No: 13510H

Serial: RNP/91-0490

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D. C. 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2  
DOCKET NO. 50-261  
LICENSE NO. DPR-23

SPECIAL REPORT REGARDING INOPERABLE FIRE BARRIER PENETRATION SEAL

Gentlemen:

Carolina Power and Light Company hereby submits this Special Report in accordance with H. B. Robinson Unit No. 2 Plant Technical Specification 3.14.7.2.c and 6.9.3.1.d.

Specifically, Fire Barrier Penetration SP-6297.00-FL, located in the Reactor Auxiliary Building outside wall, was inoperable for three hours and ten minutes beyond the seven day Limiting Condition for Operation (LCO) as specified in the Plants Technical Specifications. Technical Specification 3.14.7.2.c requires that a thirty day special report be submitted.

On January 24, 1991, at 0800 hours, with Unit. No. 2 in cold shutdown for refueling, Licensee Fire Protection personnel discovered that a spare conduit penetration which was being used to pass hydrostatic test hoses from the Reactor Auxiliary Building hallway to the outside had exceeded its LCO allowable time limit. The hose was immediately removed, the pipe caps installed, and the penetration was returned to service at 0820 hours.

When the hydrostatic test that utilized the hoses passing through the penetration was completed, the personnel conducting the test did not promptly return the penetration to service, thus causing the LCO to be exceeded. Therefore, the cause of the LCO being exceeded is attributed to a breakdown in communication with regard to follow-up of a Fire Penetration under LCO condition.


9102280209 910222  
FDR ADOCK 05000261  
S FDR

IE22  
1/0

Letter to United States Nuclear Regulatory Commission  
Serial: RNP/91-0490  
Page 2

If you have any questions regarding this matter, please contact  
Mr. J. D. Kloosterman, 803-383-1491.

Very truly yours,

  
J. J. Sheppard  
General Manager  
H. B. Robinson S. E. Plant

RDC:lht

cc: Mr. S. D. Ebner  
Mr. L. W. Garner