

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8906260305 DOC.DATE: 89/06/14 NOTARIZED: NO DOCKET #
 FACIL:50-261 H.B. Robinson Plant, Unit 2, Carolina Power & Light C 05000261
 AUTH.NAME AUTHOR AFFILIATION
 LOFLIN,L.I. Carolina Power & Light Co.
 RECIP.NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards notification of 890314 event re daily max permit
 limit for fecal coliform being exceeded.

DISTRIBUTION CODE: IE23D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 2
 TITLE: Environmental Event Report (per Tech Specs)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-1 LA	4 4	PD2-1 PD	1 1
	LO,R	1 1		
INTERNAL:	AEOD/DSP/TPAB	1 1	AEOD/PTB	1 1
	NRR/DEST/ADE 8H	1 1	NRR/DREP/EPB 10	1 1
	NRR/DREP/RPB 10	1 1	NRR/PMAS/ILRB12	1 1
	NUDOCS-ABSTRACT	1 1	OGC/HDS1	1 1
	<u>REG FILE</u>	1 1	RGN2 FILE 01	1 1
	RGN2/DRSS/EPRPB	1 1		
EXTERNAL:	LPDR	1 1	NRC PDR	1 1
	NSIC	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 20 ENCL 20

R
I
D
S
/
A
D
S

R
I
D
S
/
A
D
D
S

L/C-1
ev



Carolina Power & Light Company

JUN 14 1989

SERIAL: NLS-89-158

United States Nuclear Regulatory Commission
ATTENTION: Document Control Desk
Washington, DC 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261/LICENSE NO. DPR-23
NPDES PERMIT NOTIFICATION

Gentlemen:

Pursuant to the commitment made in our January 27, 1989 letter, CP&L is providing a copy of a recent notification regarding the NPDES Permit No. SC0002925 for the H. B. Robinson site.

Yours very truly,

L. I. Loflin
Manager

Nuclear Licensing Section

JSK/lah (343CRS)

cc: Mr. S. D. Ebnetter
Mr. L. Garner (NRC - HBR)
Mr. R. Lo

411 Fayetteville Street • P. O. Box 1551 • Raleigh, N. C. 27602

8906260305 890614
PDR ADOCK 05000261
S FDC

IE23
11



Carolina Power & Light Company

Shearon Harris Energy & Environmental Center
Route 1, Box 327
New Hill, North Carolina 27562

SERIAL: ESS-89-291

MAR 30 1989

Mr. Jack W. Wilkinson
Environmental Quality Manager
South Carolina Department of Health
and Environmental Control
2600 Bull Street
Columbia, SC 29201

RE: Robinson Steam Electric Plant
NPDES Permit No. SC0002925

Dear Mr. Wilkinson:

As required by the NPDES permit for Carolina Power & Light's Robinson Plant, this is intended to provide written notification of a recent noncompliance of the sewage treatment facility Serial No. 004. Mr. Ed Hart of SCDHEC's Pee Dee Regional Office was notified of the incident by Ms. B. W. Stephens of CP&L on March 21, 1989.

Analytical results of the sewage treatment plant effluent sample (grab) collected on March 14, 1989, exceeded the daily maximum permit limit of 400 colonies/100 ml for fecal coliform with a reading of 1300 colonies/100 ml. Additional samples are being collected; therefore, the monthly average may be within limits. It is believed that solids carryover into the chlorine contact chamber caused the elevated coliform readings. Rain and cool temperatures at the time of sampling may have adversely affected plant operation resulting in the solids carryover. Free and total residual chlorine results were 0.2 mg/l and 0.7 mg/l which should have provided adequate disinfection under normal circumstances.

Corrective actions taken included adding a third tube of chlorine tablets to the Sanuril Chlorinator and checking the chlorine tablet level in the tubes more frequently.

If there are any questions concerning this notification, please call Mr. J. M. McDowell at (919) 546-6920.

Yours very truly,

G. H. Warriner
Manager
Environmental Services

BWS:dcs (89-39BWS)
cc: Mr. E. E. Hart
bcc: Mr. C. V. Bailes
Mr. M. R. Greeson
Mr. L. R. King
Mr. R. E. Morgan
Mr. W. R. Murray ✓
Mr. W. T. Traylor