

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8704010107 DOC. DATE: 87/03/27 NOTARIZED: NO DOCKET #
 FACIL: 50-261 H. B. Robinson Plant, Unit 2, Carolina Power & Light C 05000261
 AUTH. NAME AUTHOR AFFILIATION
 CUTTER, A. B. Carolina Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Informs that util will upgrade instrumentation to Category 2, in response to Reg Guide 1.97, "Component Cooling Water temp to ESF Sys Components." Mods will be performed during Refueling Outage 11 scheduled to begin 870328.

DISTRIBUTION CODE: A003D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: OR/Licensing Submittal: Suppl 1 to NUREG-0737 (Generic Ltr 82-33)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PWR-A ADTS	1	PWR-A EB	1
	PWR-A EICSB	2	PWR-A FOB	1
	PWR-A PD2 LA	1	PWR-A PD2 PD	7
	REQUA, G	1	PWR-A PSB	1
	PWR-A RSB	1		
INTERNAL:	ADM/LFMB	1	IE/DEPER/EPB	3
	NRR BWR ADTS	1	NRR PWR-B ADTS	1
	NRR/DSRO EMRIT	1	NRR/DSRO/EIB	1
	NRR/DSRO/RSIB	1	<u>REG FILE</u> 01	1
EXTERNAL:	LPDR	1	NRC PDR	1
	NSIC	1		

TOTAL NUMBER OF COPIES REQUIRED: LTTR 29 ENCL 28



Carolina Power & Light Company

P. O. Box 1551 • Raleigh, N. C. 27602
(919) 836-6231

MAR 27 1987

A. B. CUTTER
Vice President
Nuclear Engineering & Licensing

SERIAL: NLS-87-065
TAC NO.: 51127

United States Nuclear Regulatory Commission
ATTENTION: Document Control Desk
Washington, DC 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261/LICENSE NO. DPR-23
COMPONENT COOLING WATER TEMPERATURE INSTRUMENTATION FOR
REGULATORY GUIDE 1.97

Dear Sir:

Mr. Glode Requa's letter dated March 5, 1987 transmitted a safety evaluation of Carolina Power & Light Company's submittals regarding Regulatory Guide 1.97 for H. B. Robinson Steam Electric Plant, Unit 2. The letter requests a written resolution to an open item regarding "Component Cooling Water Temperature to Engineered Safety Feature System Components" (Item 3.3.18).

The Regulatory Guide 1.97 requirement is for Category 2 instrumentation; Carolina Power & Light Company currently provides Category 3 instrumentation. The existing instrumentation will be modified to upgrade it to the requirements of Category 2. The modification will be performed during Refueling Outage 11 currently scheduled to begin on March 28, 1987.

Questions regarding this matter may be referred to Mr. R. W. Prunty at (919) 836-7318.

Yours very truly,

A. B. Cutter

JSK/lah (5160JSK)

cc: Dr. J. Nelson Grace (NRC-RII)
Mr. H. Krug (NRC Resident Inspector - RNP)
Mr. G. Requa (NRC)

8704010107 870327
PDR ADDCK 05000261
P PDR

A003
1/0