

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8707220341 DOC. DATE: 87/07/15 NOTARIZED: NO DOCKET #  
 FACIL: 50-261 H. B. Robinson Plant, Unit 2, Carolina Power & Light C 05000261  
 AUTH. NAME AUTHOR AFFILIATION  
 ZIMMERMAN, S. R. Carolina Power & Light Co.  
 RECIP. NAME RECIPIENT AFFILIATION

Document Control Branch (Document Control Desk)

SUBJECT: Forwards Rev 10 to Drawing CP-380-5379-3244, "Protection Sys," including mods to bypass breaker position status lights on main control board & inclusion of cell switch interlock for bypass breaker position indication.

DISTRIBUTION CODE: *as attached* 40550 COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+3  
 TITLE: OR/Licensing Submittal: Salem ATWS Events GL-83-28

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-1 LA	1 0	PD2-1 PD	3 3
	ECCLESTON, K	1 1		
INTERNAL:	ARM/DAF/LFMB	1 0	NRR LASHER, D	1 1
	NRR/DEST/ICSB	1 1	NRR/DEST/PSB	1 0
	NRR/DEST/RSB	1 1	NRR/DLPQ/QAB	1 0
	NRR/DOEA/GCB	1 0	NRR/PMAS/ILRB	1 0
	NRR/PMAS/PMSB	1 0	OGC/HDS1	1 0
	<u>REG FILE</u> 01	1 1	RES/DE/EIB	1 1
EXTERNAL:	LPDR	1 1	NRC PDR	1 1
	NSIC	1 1		

TOTAL NUMBER OF COPIES REQUIRED: LTTR 20 ENCL 12



Carolina Power & Light Company  
JUL 15 1987

SERIAL: NLS-87-131

United States Nuclear Regulatory Commission  
ATTENTION: Document Control Desk  
Washington, DC 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2  
DOCKET NO. 50-261/LICENSE NO. DPR-23  
ADDITIONAL INFORMATION CONCERNING GENERIC LETTER 83-28

Gentlemen:

Our May 20, 1985 letter committed to submit to your staff revised electrical schematics showing:

- (i) provision of bypass breaker position status lights on the main control board and
- (ii) inclusion of cell switch interlock for bypass breaker position indication.

These modifications have been completed and the schematics are enclosed.

Questions regarding this matter may be directed to Mr. J. S. Kozyra at (919) 836-7924.

Yours very truly,

S. R. Zimmerman  
Manager  
Nuclear Licensing Section

JRH/pp (5223JSK)

Enclosure

cc: Dr. J. Nelson Grace (NRC-RII)  
Mr. K. Eccleston (NRC)  
Mr. H. Krug (NRC Resident Inspector - RNP)

8707220341 870715  
PDR ADDOCK 05000261  
P PDR

ADSS  
1/1