

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8901030253 DOC. DATE: 88/12/30 NOTARIZED: NO DOCKET #
 FACIL: 50-261 H.B. Robinson Plant, Unit 2, Carolina Power & Light C 05000261
 AUTH. NAME AUTHOR AFFILIATION
 LOFLIN, L.I. Carolina Power & Light Co. *See Rpt.*
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards portions of Plant Mod M-958, "Add Auto Start to B SI Pump."

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 15
 TITLE: OR Submittal: General Distribution

NOTES:

| | RECIPIENT | | COPIES | | | RECIPIENT | | COPIES | |
|-----------|-----------------|--|--------|------|--|--------------------|--|--------|------|
| | ID CODE/NAME | | LTTR | ENCL | | ID CODE/NAME | | LTTR | ENCL |
| | PD2-1 LA | | 1 | 0 | | PD2-1 PD | | 2 | 2 |
| | LO, R | | 1 | 1 | | | | | |
| INTERNAL: | ARM/DAF/LFMB | | 1 | 0 | | NRR/DEST/ADS 7E | | 1 | 1 |
| | NRR/DEST/CEB 8H | | 1 | 1 | | NRR/DEST/ESB 8D | | 1 | 1 |
| | NRR/DEST/MTB 9H | | 1 | 1 | | NRR/DEST/RSB 8E | | 1 | 1 |
| | NRR/DEST/SICB | | 1 | 1 | | NRR/DOEA/TSB 11 | | 1 | 1 |
| | NRR/PMAS/ILRB12 | | 1 | 1 | | NUDOCS-ABSTRACT | | 1 | 1 |
| | OGC/HDS1 | | 1 | 0 | | <u>REG FILE</u> 01 | | 1 | 1 |
| | RES/DSIR/EIB | | 1 | 1 | | | | | |
| EXTERNAL: | LPDR | | 1 | 1 | | NRC PDR | | 1 | 1 |
| | NSIC | | 1 | 1 | | | | | |

m/A-2

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 20 ENCL 17

R
I
D
S
/
A
D
D
S

et



Carolina Power & Light Company

DEC 30 1988

SERIAL: NLS-88-289
10CFR50.

United States Nuclear Regulatory Commission
ATTENTION: Document Control Desk
Washington, DC 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261/LICENSE NO. DPR-23
FINAL CONFIGURATION FOR SAFETY INJECTION PUMP B

Gentlemen:

As discussed in Dr. R. Lo's meeting summary dated October 31, 1988, Carolina Power & Light Company (CP&L) is forwarding pertinent portions of Plant Modification M-958 "Add Auto Start to "B" SI Pump." Completion of this modification will result in Safety Injection Pump B (SI-B) in a configuration whereby SI-B is capable of automatically starting after initiation of a safety injection signal, but without the automatic bus transfer feature. The intent is to use SI-B as an automatically started maintenance pump which will have the capability to replace the "A" or "C" pumps when they are temporarily out of service for maintenance. While not in use, operability surveillance as required by the In-Service Inspection Program, and similar to that conducted for SI-A and SI-C pumps, will continue. Carolina Power & Light Company has determined that implementation of this modification requires no changes to the existing Technical Specifications.

Questions regarding this matter may be referred to Mr. R. W. Prunty at (919) 836-7318.

Yours very truly,

L. I. Loflin
Manager

Nuclear Licensing Section

JSK/crs (151CRS)

Attachment

cc: Mr. M. L. Ernst
Mr. R. Lo
Mr. L. Garner (NRC - HBR)

8901030253 881230
PDR ADOCK 05000261
P PDC

A001
1/1