

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9002270237 DOC. DATE: 90/02/16 NOTARIZED: NO DOCKET #
 FACIL: 50-261 H.B. Robinson Plant, Unit 2, Carolina Power & Light C 05000261
 AUTH. NAME AUTHOR AFFILIATION
 MORGAN, R.E. Carolina Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Submits 1989 annual rept on primary coolant iodine spikes
 per Tech Spec 6.9.1.b.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: OR Submittal: General Distribution

NOTES:

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PD2-1 LA	1	PD2-1 PD	1
LO, R	5		
INTERNAL: NRR/DET/ECMB 9H	1	NRR/DOEA/OTSB11	1
NRR/DST 8E2	1	NRR/DST/SELB 8D	1
NRR/DST/SICB 7E	1	NRR/DST/SRXB 8E	1
NUDOCS-ABSTRACT	1	OC/LFMB	1
OGC/HDS1	1	<u>REG FILE</u> 01	1
RES/DSIR/EIB	1		
EXTERNAL: LPDR	1	NRC PDR	1
NSIC	1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 21 ENCL 0

MA 14

R
I
D
S
/
A
D
D
S

R
I
D
S
/
A
D
D
S



Carolina Power & Light Company

ROBINSON NUCLEAR PROJECT DEPARTMENT
POST OFFICE BOX 790
HARTSVILLE, SOUTH CAROLINA 29550
FEB. 16 1990

Robinson File No. 13510C

Serial: RNP/90-0551

United States Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261
LICENSE NO. DPR-23
1989 ANNUAL REPORT - PRIMARY COOLANT IODINE SPIKES

Dear Sir:

Carolina Power and Light Company submits the 1989 Annual Report on Primary Coolant Iodine Spikes. This annual report is submitted as required by Technical Specification 6.9.1.b.

During 1989, the primary coolant did not exceed 1.0 $\mu\text{Ci}/\text{gram}$ dose equivalent I-131 nor did the Gross Activity exceed 100/E-Bar $\mu\text{Ci}/\text{gram}$ as set forth in Technical Specification 3.1.4.

If you have any questions concerning this report, please contact my staff or me.

Very truly yours,

R. E. Morgan
General Manager
H. B. Robinson S. E. Plant

SAG:lht

cc: S. D. Ebnetter
L. W. Garner

9002270237 900216
PDR ADDCK 05000261
PNU

9001
110