

970310096

TABLE 1	
RADIATION MONITORS	
4. R-12 *	
5. R-32A	
6. R-32B	

TABLE 2
USE FUNCTIONS

PAGE 228 of 229

H.B. ROBINSON STEAM ELECTRIC PLANT UNIT #2	
REVISION	RECOMMENDED BY
NO. DATE	ORIGINAL SIGNED BY GLENN JOHNSON
18	SUPERVISOR-EMERGENCY PREPAREDNESS DATE
	APPROVED BY
	ORIGINAL SIGNED BY ROD KIRCH
	MANAGER-REGULATORY AFFAIRS DATE

CONTROLLED
RECIPIENT
1D

GENERAL EMERGENCY
SITE AREA EMERGENCY
ALERT
UNUSUAL EVENT

FUNCTIONS REQUIRED FOR SHUTDOWN

	HOT SHUTDOWN	COLD SHUTDOWN
CAPABILITY FOR PP FLOW >300 GPM	X	IF RCS PRESS. > 400 PSIG
DR. 5.2 X 10 ⁵ PPM		
RHR CAPABILITY	X	
CCW CAPABILITY		X
SERVICE WATER CAPABILITY	X	
CHARGING CAPABILITY	X	
STEAM GENERATOR SAFETY VALVES		
BORATION CAPABILITY	X	X
RCS PRESS. CONTROL CAPABILITY	X	
ACCUMULATOR ISOLATION CAPABILITY		X

X = REQUIRED

