

ACCESSION NBR: 7910040228 DC. DATE: 79/09/28 NOTARIZED: NO 9/28/79 DOCKET #  
 FACIL: 50-261 H. B. Robinson Plant, Unit 2, Carolina Power and Light 05000261  
 AUTH. NAME: UTLEY, E. E. AUTHOR AFFILIATION: Carolina Power & Light Co.  
 RECIP. NAME: SCHWENCER, A. RECIPIENT AFFILIATION: Operating Reactors Branch 1

SUBJECT: Requests amend to License DPR-23 adding license condition requiring implementation of secondary water chemistry monitoring program. Revision replaces 760924 amend request & 760924 request withdrawn.

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR 3 ENCL 3 SIZE: 2  
 TITLE: General Distribution for After Issuance of Operating Lic

## NOTES:

ACTION:	RECIPIENT	COPIES		RECIPIENT	COPIES	
	ID CODE/NAME	LTTR	ENCL		ID CODE/NAME	LTTR
	05 BC <u>OR B#1</u>	7	7			
INTERNAL:	01 <u>REG FILE</u>	1	1	02 NRC PDR	1	1
	12 I&E	2	2	14 TA/EDO	1	1
	15 CORE PERF BR	1	1	17 ENGR BR	1	1
	18 REAC SFTY BR	1	1	19 PLANT SYS BR	1	1
	20 EEB	1	1	21 EFLT TRT SYS	1	1
	22 BRINKMAN	1	1	OELD	1	0
EXTERNAL:	03 LPDR	1	1	04 NSIC	1	1
	23 ACRS	16	16			

OCT 5 1979

TOTAL NUMBER OF COPIES REQUIRED: LTTR 38 ENCL 37

K.B.  
App'l 2



Carolina Power & Light Company

September 28, 1979

FILE: NG-3514(R)

SERIAL: GD-79-2441

Office of Nuclear Reactor Regulation  
ATTENTION: Mr. Albert Schwencer, Chief  
Operating Reactors Branch No. 1  
United States Nuclear Regulatory Commission  
Washington, D.C. 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2

DOCKET NO. 50-261

LICENSE NO. DPR-23

REQUEST FOR LICENSE AMENDMENT - SECONDARY WATER CHEMISTRY MONITORING PROGRAM

Dear Mr. Schwencer:

In accordance with the Code of Federal Regulations, Title 10, Part 50.90 and Part 2.101, and as requested in your letter of August 1, 1979, Carolina Power & Light Company (CP&L) hereby requests a revision to the facility license number DPR-23 for its H. B. Robinson Steam Electric Plant, Unit No. 2. The revision adds a license condition requiring the implementation of a Secondary Water Chemistry Monitoring Program. This revision replaces in total the amendment request submitted by CP&L September 24, 1976 and the September 24, 1976 request is hereby withdrawn. As stated in the September 24, 1976 request, a Secondary Water Chemistry Monitoring Program has been in effect at H. B. Robinson since 1971. The proposed license condition is attached.

As outlined in your letter, because CP&L made an earlier submittal on this subject, no license fee is required.

If you have any questions on this issue, please contact our staff.

Yours very truly,

E. E. Utley  
Executive Vice President  
Power Supply & Customer Services

EEU/jcb

Enclosure

Sworn to and subscribed before me this 28th day of September 1979.

*Franklin Murray*  
Notary Public

My Commission Expires October 4, 1981.

411 Fayetteville Street • P. O. Box 1551 • Raleigh, N. C. 27602



P 7910040228

3.G The Licensee shall implement a secondary water chemistry monitoring program to inhibit steam generator tube degradation. This program shall include: the identification of critical parameters, their sampling frequency, sampling points, and control bank limits; requirements for the documentation and review of sample results; the identification of the authority responsible for the interpretation of sample results; the procedures used to measure the critical parameters; and the procedures which identify the administrative events and corrective actions required to return the secondary chemistry to its normal control band following an out of control band condition.