

TABLE 3.5-3 (Continued)

<u>NO.</u>	<u>FUNCTIONAL UNIT</u>	1 MINIMUM CHANNELS <u>OPERABLE</u>	2 MINIMUM DEGREE OF <u>REDUNDANCY</u>	3 OPERATOR ACTION IF CONDITIONS OF COLUMN 1 OR 2 <u>CANNOT BE MET</u>
3	Loss of Power			
	a. 480V Emerg. Bus Undervoltage (Loss of Voltage)	1/Bus	0/Bus.	Maintain Hot Shutdown
	b. 480V Emerg. Bus Undervoltage (Degraded Voltage)	2/Bus	1/Bus	Maintain Hot Shutdown

8010150

425

3.5-10A

Amendment No.

TABLE 4.1-1 (Continued)

<u>NO.</u>	<u>CHANNEL DESCRIPTION</u>	<u>CHECK</u>	<u>CALIBRATE</u>	<u>TEST</u>	<u>REMARKS</u>
32	Loss of Power				
a.	480V Emerg. Bus Undervoltage (Loss of Voltage)	NA	R	R	
b.	480V Emerg. Bus Undervoltage (Degraded Voltage)	NA	R	R	

4.1-6A

Amendment No.