

# REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8010170547 DOC.DATE: 80/10/15 NOTARIZED: YES DOCKET #  
 FACIL:50-261 H. B. Robinson Plant, Unit 2, Carolina Power and Light 05000261  
 AUTH.NAME AUTHOR AFFILIATION  
 UTLEY,E.E. Carolina Power & Light Co.  
 RECIP.NAME RECIPIENT AFFILIATION  
 VARGA,S.A. Operating Reactors Branch 1

SUBJECT: Application for amend of License DPR-23, deleting Tech Spec  
 4.14.6 containing surveillance requirements for propane  
 engine-driven pump. Revised Tech Specs will be submitted.

DISTRIBUTION CODE: A006S COPIES RECEIVED: LTR 3 ENCL 0 SIZE: 2  
 TITLE: Fire Protection Information (After Issuance of OP. Lic.)

## NOTES:

	RECIPIENT ID CODE/NAME		COPIES LTR ENCL		RECIPIENT ID CODE/NAME		COPIES LTR ENCL
ACTION:	VARGA,S.	04	3				
INTERNAL:	CHEM ENG BR-A	7	5		I&E	06	2
	NRC PDR	02	1		OELD		1
	REG FILE	01	1		WAMBACH,T.	10	1
EXTERNAL:	ACRS	09	16	1	LPDR	03	1
	NSIC	05	1				

OCT 20 1980

TOTAL NUMBER OF COPIES REQUIRED: LTR 32 ENCL 0



Carolina Power & Light Company

October 15, 1980

File: NG-3514(R)

Serial No.: NO-80-1545

Office of Nuclear Reactor Regulation  
Attention: Mr. Steven A. Varga, Chief  
Operating Reactors Branch No. 1  
United States Nuclear Regulatory Commission  
Washington, D. C. 20555

H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2  
DOCKET NO. 50-261  
LICENSE NO. DPR-23

REQUEST FOR LICENSE AMENDMENT - PROPANE ENGINE-DRIVEN FIRE PUMP

Dear Mr. Varga:

As committed to in Carolina Power & Light Company's (CP&L) letter of March 18, 1980 and discussed with Mr. W. J. Ross of your staff on October 10, 1980, CP&L is in the process of replacing the H. B. Robinson Unit No. 2 propane engine-driven fire pump with a diesel engine-driven fire pump. The replacement process will require approximately three weeks to complete. During the interim period, the electric fire pump will continue to be available and back-up will be provided using the Unit No. 1 fire pumps.

With the propane engine-driven fire pump removed, H. B. Robinson Unit No. 2 Technical Specification 4.14.6 containing surveillance requirements for the propane pump is no longer valid and should be immediately deleted. Revised Technical Specifications for the new pump will be submitted in a package containing Technical Specifications for other modifications completed during the H. B. Robinson Unit No. 2 1980 refueling outage. Because this change was dictated by the NRC staff in the course of the Fire Protection review, CP&L has determined that no license fee is required.

Approved  
5/10

8010170547

If you have any questions on this matter please contact our staff.

Yours very truly,




E. E. Utley  
Executive Vice President  
Power Supply and  
Engineering & Construction

JHE/dk

cc: Mr. J. D. Neighbors (NRC)  
Mr. J. P. O'Reilly (NRC-I&E)

Sworn to and subscribed before me this 15th day of October, 1980



Notary Public

My Commission expires October 4, 1981.

