

TABLE 3.5-3 (Continued)

<u>NO.</u>	<u>FUNCTIONAL UNIT</u>	<u>1 MINIMUM CHANNELS OPERABLE</u>	<u>2 MINIMUM DEGREE OF REDUNDANCY</u>	<u>3 OPERATOR ACTION IF CONDITIONS OF COLUMN 1 OR 2 CANNOT BE MET</u>
3	Loss of Power			
a.	480V Emerg. Bus Undervoltage (Loss of Voltage)	1/Bus	0/Bus	Maintain Hot Shutdown
b.	480V Emerg. Bus Undervoltage (Degraded Voltage)	2/Bus	1/Bus	Maintain Hot Shutdown *

* The reactor may remain critical below the Power Operating Condition with this feature inhibited for the purpose of starting Reactor Coolant Pumps.

8010200476

3.5-10A

Amendment No.