

Table 3.13-1 (cont'd)
SAFETY RELATED HYDRAULIC SNUBBERS

<u>Snubber No.</u>	<u>Location</u>	<u>Elevation</u>	<u>Snubbers in High Radiation Area During Shutdown*</u>	<u>Snubbers Especially Difficult to Remove</u>	<u>Snubbers Inaccessible During Normal Operation</u>	<u>Snubbers Accessible During Normal Operation</u>
21	RWST to RHR Pumps	222'				X
22	RWST to RHR Pumps	222'				X
23	Charging Line Loop 2 Cold Leg	239'				X
24	Charging Line Loop 2 Cold Leg	239'				X
25	Auxiliary Spray Line	241'				X
26	Letdown to Non-regen- erative Heat Exchanger	229'				X
27	Charging Pumps Discharge Line	234'				X
28	"A" Feedwater Line	254'				X
29	"B" Feedwater Line	250'				X
30	Steam Supply to Auxiliary Feed- water Pump	257'				X

*Modifications to this table due to changes in high radiation areas should be submitted to the NRC as part of the next license amendment.

B202010206 B20127
PDR ADDCK 05000261
PDR