

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8210060013 DOC. DATE: 82/10/01 NOTARIZED: YES DOCKET #
 FACIL: 50-261 H. B. Robinson Plant, Unit 2, Carolina Power and Light 05000261
 AUTH. NAME: EURY, L.W. AUTHOR AFFILIATION: Carolina Power & Light Co.
 RECIP. NAME: VARGA, S.A. RECIPIENT AFFILIATION: Operating Reactors Branch 1

SUBJECT: Application to amend License PR-23 consisting of revision to Tech Specs providing three auxiliary feedwater pumps operable prior to exceeding RCS temp of 350 F.

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2+5
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME		COPIES LTTR ENCL		RECIPIENT ID CODE/NAME		COPIES LTTR ENCL
	NRR ORB1 BC 01		7 7				
INTERNAL:	ELD/HDS1		1 0		NRR/DHFS DEPY08		1 1
	NRR/DL DIR		1 1		NRR/DL/ORAB		1 0
	NRR/DSI/RAB		1 1		REG FILE 04		1 1
	RGN2		1 1				
EXTERNAL:	ACRS 09		6 6		LPDR 03		1 1
	NRC PDR 02		1 1		NSIC 05		1 1
	NTIS		1 1				

A5A
52



Carolina Power & Light Company

OCT 01 1982

Office of Nuclear Reactor Regulation
ATTN: Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1
United States Nuclear Regulatory Commission
Washington, D.C. 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261
LICENSE NO. DPR-23
REQUEST FOR LICENSE AMENDMENT -
LIMITING CONDITIONS FOR OPERATION

Dear Mr. Varga:

SUMMARY

In accordance with the Code of Federal Regulations, Title 10, Part 50.90 and Part 2.101, Carolina Power & Light Company (CP&L) hereby requests revisions to the Technical Specifications (TS) for the H. B. Robinson Steam Electric Plant (HBR) Unit No. 2. These revisions revise the specification requirements for the Auxiliary Feedwater Pumps.

DETAILS

Technical Specification 3.4.1.b presently requires two auxiliary feedwater pumps to be operable when the Reactor Coolant system (RCS) temperature is above 350°F. Following considerable discussion regarding this issue with members of your staff, we request that TS 3.4.1.b be changed to provide for three auxiliary feedwater pumps to be operable prior to exceeding an RCS temperature of 350°F. Additionally, we request revisions to specification 3.4.3, incorporate new specifications 3.4.4 and 3.4.5, and renumber the existing specification 3.4.4 to specification 3.4.6.

As a consequence of the new specification 3.4.4.a, we request a revision to specification 6.9.3, Special Reports, to include a new specification, 6.9.3.f, for Auxiliary Feedwater Pumps.

A001

8210060013 821001
PDR ADDCK 05000261
PDR

Mr. Steven A. Varga

-2-

These revisions supplement CP&L's previous amendment request, dated November 5, 1980, required by your staff, therefore, no amendment fee is required. The affected pages, with changes denoted by vertical bars in the right margin, are enclosed for your review.

Should you have any questions regarding this matter, please contact my staff.

Yours very truly,




L. W. Eury
Senior Vice President
Power Supply

DCW/lr (4333C6T3)

cc: Mr. J. P. O'Reilly (NRC-RII)
Mr. G. Requa (NRC)
Mr. Steve Weise (NRC-HBR)

L. W. Eury, having been first duly sworn, did depose and say that the information contained herein is true and correct to his own personal knowledge or based upon information and belief.


Notary (Seal)

My commission expires: OCT 04 1986

