

REGULATORY INFORMATION DISTRIBUTION SYSTEM (GRIDS)

hA EA  
32

ACCESSION NBR: 8210260475 DOC. DATE: 82/10/22 NOTARIZED: YES DOCKET #: 05000261  
 FACIL: 50-261 H. B. Robinson Plant, Unit 2, Carolina Power and Light  
 AUTH. NAME: EURY, L.W. AUTHOR AFFILIATION: Carolina Power & Light Co.  
 RECIP. NAME: VARGA, S.A. RECIPIENT AFFILIATION: Operating Reactors Branch 1

SUBJECT: Application to amend License DPR-23 revising Tech Specs to clarify in-place testing criteria used on safety-related HEPA filter sys & compliance w/more recent ANSI std.

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2+2  
 TITLE: OR Submittal: General Distribution

NOTES: w/check 1,200

RECIPIENT			COPIES		RECIPIENT			COPIES	
ID CODE/NAME			LTR	ENCL	ID CODE/NAME			LTR	ENCL
NRR ORB1 BC 01			7	7					
INTERNAL: ELD/HDS1			1	0	NRR/DHFS DEPY08			1	1
NRR/DL DIR			1	1	NRR/DL/ORAB			1	0
NRR/DSI/RAB			1	1	REG FILE 04			1	1
RGN2			1	1					
EXTERNAL: ACRS			09	6	LPDR			03	1
NRC PDR			02	1	NSIC			05	1
NTIS			1	1					

4



Carolina Power & Light Company

OCT 22 1982

Office of Nuclear Reactor Regulation  
ATTN: Mr. Steven A. Varga, Chief  
Operating Reactors Branch No. 1  
United States Nuclear Regulatory Commission  
Washington, D.C. 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2  
DOCKET NO. 50-261  
LICENSE NO. DPR-23  
REQUEST FOR LICENSE AMENDMENT -  
REFUELING AND CONTROL ROOM FILTER SYSTEMS

Dear Mr. Varga:

SUMMARY

In accordance with the Code of Federal Regulations, Title 10, Part 50.90 and Part 2.101, Carolina Power & Light Company (CP&L) hereby requests revisions to the Technical Specifications for the H. B. Robinson Steam Electric Plant (HBR) Unit 2. These revisions will clarify the in-place testing criteria used on safety-related HEPA filter systems and will comply with a more recent ANSI standard.

DETAILS

The present in-place testing criteria used for testing the safety-related HEPA filter systems complies with ANSI-N101.1 (1972). The DOP particle generators supplied by the vendor and those available from other industry suppliers for the testing have a particle distribution that will not meet the testing criteria of ANSI-N101.1 (1972), but complies with a more recent ANSI standard, N510 (1975). The distribution from these generators is fixed and therefore cannot be adjusted. ANSI standard N510 (1975) is approved for use by the Nuclear Regulatory Commission via Regulatory Guide 1.52.

The affected pages are enclosed for your review.

The requested changes to the Technical Specifications constitute one Class II amendment, in accordance with 10 CFR 170.22. Accordingly, our check for \$1,200.00 is enclosed.

411 Fayetteville Street • P. O. Box 1551 • Raleigh, N. C. 27602

B210260475 B21022  
PDR ADDCK 05000261  
PDR

*Acc'd  
w/ check  
\$1,200*

Mr. Varga

-2-

Should you have any questions regarding this matter, please contact my staff.

Yours very truly,



L. W. Eury  
Senior Vice President  
Power Supply

DCW/lr (5003C6T3)

Enclosures

cc: Mr. J. P. O'Reilly (NRC-RII)  
Mr. G. Requa (NRC)  
Mr. Steve Weise (NRC-HBR)

L. W. Eury, having been first duly sworn, did depose and say that the information contained herein is true and correct to his own personal knowledge or based upon information and belief.

  
Notary (Seal)

My commission expires: **OCT 04 1986**

