

valves, are not subject to the requirements of this specification.

- f. Power or air supply may be restored to any valve referenced in 3.3.1.1.g. and 3.3.1.1.h. for the purpose of valve testing or maintenance providing no more than one valve has power restored and provided that testing and maintenance is completed and power removed within 24 hours except for accumulator isolation valves (MOV 865 A,B,&C) which will have this time period limited to four hours.

8609040087 860828
PDR ADOCK 05000261
P PDR