

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8808160251 DOC.DATE: 88/08/09 NOTARIZED: YES DOCKET #  
 FACIL:50-261 H.B. Robinson Plant, Unit 2, Carolina Power & Light C 05000261  
 AUTH.NAME AUTHOR AFFILIATION  
 EURY,L.W. Carolina Power & Light Co.  
 RECIP.NAME RECIPIENT AFFILIATION

Document Control Branch (Document Control Desk)

SUBJECT: Application for amend to License DPR-23,adding operability & surveillance requirements for core exit thermocouples.

DISTRIBUTION CODE: A046D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 2+4  
 TITLE: OR Submittal: TMI Action Plan Rgmt NUREG-0737 & NUREG-0660

### NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	PD2-1 LA		1	0		PD2-1 PD		5	5
	LO,R		1	1					
INTERNAL:	AEOD/DOA		1	1		AEOD/DSP/TPAB		1	1
	ARM/DAF/LFMB		1	0		NRR/DEST/ADE 8H		1	0
	NRR/DEST/ADS 7E		1	0		NRR/DEST/MEB 9H		1	1
	NRR/DREP/EPB 10		1	1		NRR/DREP/RPB 10		1	1
	NUDOCS-ABSTRACT		1	1		OGC/HDS1		1	0
	<u>REG FILE</u> 01		1	1		RES/DSIR/EIB		1	1
	RES/DSR DEPY		1	1					
EXTERNAL:	LPDR		1	1		NRC PDR		1	1
	NSIC		1	1					

w/Check \$ 150  
 # 964719

TOTAL NUMBER OF COPIES REQUIRED: LTTR 23 ENCL 18

R  
I  
D  
S  
/  
A  
D  
D  
S  
  
R  
I  
D  
S  
/  
A  
D  
D  
S



**Carolina Power & Light Company**

P. O. Box 1551 • Raleigh, N. C. 27602

SERIAL: NLS-88-177

AUG 9 1988

LYNN W. EURY  
Senior Vice President  
Operations Support

United States Nuclear Regulatory Commission  
ATTENTION: Document Control Desk  
Washington, DC 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2  
DOCKET NO. 50-261/LICENSE NO. DPR-23  
REQUEST FOR LICENSE AMENDMENT  
CORE EXIT THERMOCOUPLES (NUREG-0737, ITEM II.F.2)

Gentlemen:

In accordance with the Code of Federal Regulations, Title 10, Parts 50.90 and 2.101, Carolina Power & Light Company (CP&L) hereby requests a revision to the Technical Specifications (TS) for the H. B. Robinson Steam Electric Plant, Unit No. 2. The proposed change adds operability and surveillance requirements for the Core Exit Thermocouples. The change is adapted from the guidance of Generic Letter 83-37 and is similar to specifications for other accident monitoring equipment. This change request is submitted as a supplement to our Implementation Letter/Amendment Request dated September 16, 1987. The changed TS pages submitted herein supersede those attached to the previous submittal.

SIGNIFICANT HAZARDS ANALYSIS

Carolina Power & Light Company has reviewed the subject TS change request in accordance with the standards set forth in 10CFR50.92 and determined that this change does not constitute a significant hazard based upon the following considerations.

1. Operation of the facility, in accordance with the proposed amendment, would not involve a significant increase in the probability or consequences of an accident previously analyzed because the proposed amendment involves new surveillance and operability requirements on existing equipment.
2. Operation of the facility in accordance with the proposed amendment would not create the possibility of a new or different kind of accident from any accident previously evaluated because the proposed amendment involves new surveillance and operability requirements on existing equipment.

8808160251 880809  
PDR ADOCK 05000261  
P PDC

A046  
w/11  
check #150  
#964719

3. Operation of the facility, in accordance with the proposed amendment, would not involve a significant reduction in a margin of safety because the proposed amendment involves new surveillance and operability requirements on existing equipment.


ADMINISTRATIVE

The TS pages reflecting the changes are provided for your use; changes are indicated by a single bar in the right margin.

In accordance with 10CFR170.12, a check in the amount of \$150 in payment of a license amendment application fee is enclosed.

If you have any questions concerning this request, please contact Mr. L. I. Loflin at (919) 836-6242.

Yours very truly,

  
L. W. Eury

LWE/JSK/crs (061CRS)

Enclosure

cc: Dr. J. Nelson Grace  
Mr. R. Lo  
Mr. L. Garner (NRC - HBR)  
Mr. Heyward G. Shealy (SC)  
Attorney General (SC)

L. W. Eury, having been first duly sworn, did depose and say that the information contained herein is true and correct to the best of his information, knowledge and belief; and the sources of his information are officers, employees, contractors, and agents of Carolina Power & Light Company.

My commission expires:

11/27/89

  
Notary (Seal)

