

Table 4.1-2 (Continued)

Frequencies For Sampling Tests

	<u>Check</u>	<u>Frequency</u>	<u>Maximum Time Between Tests</u>
11. U-2 Diesel Generator Fuel Oil Storage Tank	API or Specific Gravity, Water and Sediment, Viscosity	Monthly	45 Days
12. U-1 I-C Turbine Fuel Oil Storage Tanks or Tank Truck	API or Specific Gravity, Water and Sediment, Viscosity	Prior to transfer to U-2	N/A

8905110231 890505  
PDR ADDCK 05000261  
P PDC