

9206120253 920605  
PDR ADDCK 05000261  
PDR

TABLE 4.1-1 (Continued)

48.	Reactor Vessel Level Instrumentation System (RVLIS)	M	R	N.A.	
49.	Incore Thermocouple Temperature Instrumentation	M	R	N.A.	
+	Containment Water Level Monitor - NUREG-0737 Item II.F.1.5				
++	Containment Pressure Monitor - NUREG-0737 Item II.F.1.4				
+++	Containment Hydrogen Monitor - NUREG-0737 Item II.F.1.6				
++++	Containment High-Range Radiation Monitor - NUREG-0737 Item II.F.1.3				
#	CP&L's letter dated April 28, 1982, S. R. Zimmerman to S. A. Varga, provides an acceptable alternate calibration methodology.				
S	-	At least once per 12 hours	Q	-	At least once per 92 days
D	-	At least once per 24 hours	S/U	-	Prior to each reactor startup if not performed in the previous seven (7) days
W	-	At least once per 7 days			
B/W	-	At least once per 14 days	R	-	At least once per 18 months
M	-	At least once per 31 days	N.A.	-	Not applicable

TABLE 4.1-1 (Continued)

48.	Reactor Vessel Level Instrumentation System (RVLIS)	M	R	N.A.
49.	Incore Thermocouple Temperature Instrumentation	M	R	N.A.

- + Containment Water Level Monitor - NUREG 0737 Item II.F.1.5
- ++ Containment Pressure Monitor - NUREG-0737 Item II.F.1.4
- +++ Containment Hydrogen Monitor - NUREG-0737 Item II.F.1.6
- ++++ Containment High-Range Radiation Monitor - NUREG-0737 Item II.F.1.3
- # ~~Calibration performed in accordance with CP&L's letter dated April 28, 1982~~ S. R. Zimmerman to S. A. Varga, *provides an acceptable alternate calibration methodology.*

S - At least once per 12 hours  
 D - At least once per 24 hours  
 W - At least once per 7 days  
 B/W - At least once per 14 days  
 M - At least once per 31 days

Q - At least once per 92 days  
 S/U - Prior to each reactor startup if not performed in the previous seven (7) days  
 R - At least once per 18 months  
 N.A. - Not applicable