DWG. NO. SW-9 SHT 5



TYPE OF ANALYSIS

■ SEISMIC ☐ NON-SEISMIC ■ B31.1 ☐ ASME

PIPE PROPERTIES

LINE NO.	LINE SPEC	O.D.	THK	MATERIAL	INSUL THK	OPER TEMP	DES PRESS	DES TEMP
6CW-39	M027	6.625	.240	AL6XN	1"	105	150	250
6CW-39	M027	6.625	.134	AL6XN	1"	105	150	250

VALVE PROPERTIES

VALVE NO.	SIZE	VALVE WEIGHT	OPERATOR WT	OPERATOR C.G.
SW-505	3/4"			

ANCHOR MOVEMENTS

NODE NO.	MOVEMENTS	OPERATING CONDITIONS		
NA	Δ X Δ Y Δ Z			
	SOURCE			

REFERENCE DOCUMENTS

FLOW DIAG. G-190199 SHTS 1,4 REV 39,40 0 3

PIPE DWG SK-10B2-M-2001,2002,2003 G-190225 SHTS 3,4,5 REV 1,1,0

STRESS CALC SW-9-71098 REV 7

RESPONSE SPECTRA REACTOR CONT BLDG EL 289
REACTOR INNER STRUCT EL 232.5,248,272.5

NOTES & REFERENCES

1. UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE GIVEN TO CENTERLINE OF TEES AND ELBOWS.
2. TRANSITION PIECE IS 6" SCH 10S TO 6" (t = .24").
3. AL6XN MATERIAL IS:
   6" SCH 10S — PIPE ASTM B-688, FABR ASTM A358 CL 2 FITTINGS ASTM B-366 CL WP-S OR WP-W
   6" (t = .24") — PIPE ASTM B-688, FABR ASTM A358 CL2 FITTINGS ASTM B-366 CL WP-S OR WP-W ELBOWS t = .268"
4. PIPING BETWEEN TRANSITION PIECES (INCLUSIVE) WAS REPLACED BY MOD 1082. ALL OTHER PIPING EXCEPT AT PENETRATION ASSEMBLY WAS REPLACED BY PLANT MOD 858 REV. 1. 3

APERTURE CARD

NOTE: THIS DRAWING SUPERSEDES ISO SW-9 SHT'S 5-8 REV. 1 AND ISO SW-9P SHT'S 5-8 REV. 0.

SUPPORT LEGEND

RIGID SNUBBER ANCHOR
SPRING AXIAL DW SUPPORT

INFO ONLY

THIS DRAWING IS A PRODUCT OF THE NED CAD/E SYSTEM. ANY PERSONNEL REVISING THIS DOCUMENT SHOULD ENSURE THAT SUCH CHANGES ARE INCORPORATED INTO THE ELECTRONIC DRAWING DATABASE BEFORE FINAL APPROVAL. CONTACT THE APPROPRIATE NED DISCIPLINE IF THERE ARE ANY QUESTIONS.

NUCLEAR SAFETY RELATED (Q-LIST)
YES ■ NO ☐ PARTIAL ☐ F.P.-Q ☐ R.W.-Q ☐

REV	DATE	DESCRIPTION	CHK	RE	DPE	DPPE	LE
3	6/4/93	AS-BUILT RECONCILIATION PM 1082	MJL JRE	AWW	DMD	GMV JCVS	
2	9-21-91	FIRST ISSUE PER MOD 1082	MJL PV	AWW	VKS	VKS	

CAROLINA POWER & LIGHT COMPANY
NUCLEAR ENGINEERING DEPARTMENT - RALEIGH, N.C.

CP&L

PLANT: ROBINSON NUCLEAR PLANT UNIT 2

SCALE NTS

TITLE: REACTOR CONTAINMENT BUILDING SERVICE WATER FROM HVH-4 STRESS ISOMETRIC

DWG NO. SW-9

SHT 5 OF 6 REV 3

FORM: SK-CAD-A-0130

RNP-SW9-71098 SHT 3

9403-9-71098 REV. 7 PG. 66

9903030269