

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8011070498 DOC. DATE: 80/11/03 NOTARIZED: NO DOCKET #
 FACIL: 50-261 H. B. Robinson Plant, Unit 2, Carolina Power and Light 05000261
 AUTH. NAME: AUTHOR AFFILIATION
 UTLEY, E.E. Carolina Power & Light Co.
 RECIP. NAME: RECIPIENT AFFILIATION
 VARGA, S.A. Operating Reactors Branch 1

SUBJECT: Discusses steam generator insp followup. Corrective action re excessive primary-to-secondary leakage will include normal reactor shutdown, identification & repair of any leaking tubes & discussion w/NRC concerning situation.

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: General Distribution for after Issuance of Operating License

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
ACTION:	VARGA, S. 04	13 15		
INTERNAL:	D/DIR, HUM FAC08	1	I&E 06	2
	NRC PDR 02	1	DELD 11	1
	OR ASSESS BR 10	1	<u>REG FILE</u> 01	1
EXTERNAL:	ACRS 09	16 16	LPDR 03	1
	NSIC 05	1		

NOV 10 1980

TOTAL NUMBER OF COPIES REQUIRED: LTR 38 ENCL 0



Carolina Power & Light Company

RECEIVED DISTRIBUTION
SERVICES UNIT

November 3, 1980

FILE: NG-3514(R)

SERIAL NO.: NO-80-1625

1980 NOV 6 AM 10 07

US NRC
DISTRIBUTION SERVICES
BRANCH

Office of Nuclear Reactor Regulation
ATTENTION: Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1
United States Nuclear Regulatory Commission
Washington, D. C. 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261
LICENSE NO. DPR-23
STEAM GENERATOR INSPECTION - FOLLOWUP

Dear Mr. Varga:

Carolina Power & Light Company advised you we would take appropriate corrective action if primary-to-secondary leakage rates exceeded the limits committed to in our letter dated October 22, 1980. We consider appropriate corrective action to include a normal shutdown of the reactor, identification and repair of any leaking tubes, and a discussion with your staff concerning the situation.

If you have any questions regarding the above, please contact my staff.

Yours very truly,

E. E. Utley
Executive Vice President
Power Supply and
Engineering & Construction

SDF/pfb

cc: Mr. J. D. Neighbors (NRC)

Acc'd 5/10

411 Fayetteville Street • P. O. Box 1551 • Raleigh, N. C. 27602

8011070498

P