

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8204120438 DOC. DATE: 82/04/08 NOTARIZED: NO DOCKET #
 FACIL: 50-261 H. B. Robinson Plant, Unit 2, Carolina Power and Light 05000261
 AUTH. NAME AUTHOR AFFILIATION
 HOWE, P.W. Carolina Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 VARGA, S.A. Operating Reactors Branch 1

SUBJECT: Requests permission to use ASME Section XI Summer 1978
 addenda as basis for reactor coolant pump casing review
 during 820415 first 10-yr program insp. Code provides
 specific instructions for performance tests.

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: General Distribution for after Issuance of Operating License

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID	CODE/NAME	LTTR	ENCL		ID	CODE/NAME	LTTR	ENCL
	ORB #1	BC 01	13	13					
INTERNAL:	ELD		1	0	IE	06	1		
	NRR/DHFS	DEPY08	1	1	NRR/DL DIR		1		
	NRR/DL	ORAB	1	0	NRR/DSI/RAB		1		
	REG FILE	04	1	1	RGN2		1		
EXTERNAL:	ACRS	09	10	10	LPDR	03	1		
	NRC PDR	02	1	1	NSIC	05	1		
	NTIS		1						

TOTAL NUMBER OF COPIES REQUIRED: LTTR 35 ENCL 0



Carolina Power & Light Company

APR 08 1982



Office of Nuclear Reactor Regulation
ATTN: Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1
United States Nuclear Regulatory Commission
Washington, D.C. 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261
LICENSE NO. DPR-23
REACTOR COOLANT PUMP CASING INSPECTION

Dear Mr. Varga:

Carolina Power & Light Company (CP&L) has submitted its second ten-year component inspection program for its H. B. Robinson Steam Electric Plant Unit No. 2 to comply with the requirements of the 1977 Edition, Summer 1978 Addenda of Section XI ASME Code (77/78). The first ten-year program is based on the 1974 Edition of Section XI through the Summer 1975 Addenda (74/75). The 77/78 code provides more specific instructions for performing tests than does the previous 74/75 code and therefore provides for more complete testing. CP&L requests to use the 1978 Addenda as the basis for the Reactor Coolant Pump Casing Inspection to be conducted during the first ten-year program, which is presently underway.

In accordance with 10CFR50.55a(g)(4)(iv), the incorporation of subsequent editions and addenda is subject to NRC approval. We hope to commence this inspection on April 15, 1982. Your timely consideration of this matter would be appreciated. Should you have any questions, please contact a member of our staff.

Yours very truly,

P. W. Howe
Vice President
Technical Services

FMG/DCW/lr (n-19)

cc: Mr. J. P. O'Reilly (NRC-RII)
Mr. G. Requa (NRC)

8204120438 820408
PDR ADOCK 05000261
G PDR

it • P. O. Box 1551 • Raleigh, N. C. 27602

*Adol
5/10*