

APPENDIX A

ENG-10

CAROLINA POWER & LIGHT COMPANY

H. B. ROBINSON STEAM ELECTRIC PLANT UNIT 2

IN-SERVICE INSPECTION PROGRAM

INTERVAL 2

MARCH 7, 1981 TO MARCH 7, 1991

8401230248 840113
PDR ADDCK 05000261
Q PDR

TABLE OF CONTENTS

TITLE	PAGE
Abstract	ii
List of Drawings	iii
Attachment A - Pump and Valve Test Program	A-1
Table 1 - Codes and Symbols	1 of 1
Table 2 - Pump Test Program	1 of 2
Table 2 - Specific Requests for Relief	1 of 4
Table 3 - Valve Test Program	- -
Table 3 - Specific Requests for Relief	1 of 8
Table 4 - Additional Valve Information	1 of 6

ABSTRACT
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT 2
IN-SERVICE INSPECTION PROGRAM
INTERVAL 2 - MARCH 7, 1981 TO MARCH 7, 1991

In accordance with 10CFR50.55a(g) (4) (ii) the H. B. Robinson Unit 2 ISI Program is being updated to ASME Section XI, 1977 Edition with addenda through the Summer, 1978, addenda. Steam generator inspections will continue to be inspected under Plant Technical Specifications. Specific reliefs are requested in accordance with 10CFR50.55a(g) (5) (iii).

The interval for which this program is applicable will commence on March 7, 1981, and end on March 7, 1991.

The ISI Program was developed employing the classification guidelines contained in 10CFR50.2(v) for Quality Group A. Regulatory Guide 1.26, Revision 2, was used for classification of items in Quality Groups B and C, along with ANSI N18.2, 1973, and ANSI N18.2a, 1975. Quality Groups A, B, and C are the same as ASME Classes 1, 2 and 3 respectively.

The List of Drawings identifies the drawings used in developing the program.

Attachment A describes the Class 1, 2, and 3 pump and valve inspection program developed in accordance with Subsections IWP and IWV of ASME Section XI.

H. B. ROBINSON STEAM ELECTRIC PLANT UNIT 2
IN-SERVICE INSPECTION PROGRAM
LIST OF DRAWINGS

<u>Drawing #</u>	<u>Sheets</u>	<u>Title</u>
ISI-5379-353		Sampling System
ISI-5379-376	1 of 3	Component Cooling System
	2 of 3	
	3 of 3	
ISI-5379-684		Chemical and Volume Control System
ISI-5379-685	1 of 3	Chemical and Volume Control System
	2 of 3	
	3 of 3	
ISI-5379-686	1 of 2	Chemical and Volume Control System
	2 of 2	
ISI-5379-920	1 of 4	(Liquid) Waste Disposal System
ISI-5379-921	1 of 2	(Gaseous) Waste Disposal System
	2 of 2	
ISI-5379-1082	1 of 2	Safety Injection System
	2 of 2	
ISI-5379-1484		Residual Heat Removal System
ISI-5379-1485		Spent Fuel Pit Coolant System
ISI-5379-1971	1 of 2	Reactor Coolant System
	2 of 2	
ISI-G-190196	1 of 3	Main, Extraction and Aux. Steam Sys.
ISI-G-190197	2 of 3	Feedwater, Condensate and Air Evacuation Sys.
ISI-G-190199	1 of 7	Service & Cooling Water System
	2 of 7	
	3 of 7	
ISI-G-190234	1 of 2	Steam Generator Blow-Down System
ISI-G-190261	3 of 8	Penetration Pressurization System
	7 of 8	
	8 of 8	
ISI-G-190262		Isolation Valve Seal Water
ISI-G-190304	1 of 2	HVAC - Turb, Fuel, Aux, and Reactor Buildings
ISI-HBR2-6490		Post Accident Sampling System
ISI-HBR2-6933		Post Accident Containment Venting System
ISI-HBR2-7063		Flow Diagram Legend
ISI-SK-1		Fire Protection System
ISI-SK-2		Fuel Transfer Tube
ISI-G-190204A	1 of 3	Emergency Diesel Generator System
ISI-G-190200	1 of 3	Instrument and Service Air

Attachment A

ASME SECTION XI PUMP & VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2

The pump and valve testing program shall be conducted in accordance with Subsections IWP and IWV of Section XI of the 1977 Edition of the ASME Boiler and Pressure Vessel Code through the Summer, 1978 Addenda, except for specific relief requested in accordance with 10CFR50.55a(g) (5) (iii), which is identified in Tables 2 and 3 for pumps and valves respectively.

The interval for which this pump and valve testing program is applicable commences on March 7, 1981, and expires on March 7, 1991.

The pump and valve testing program was developed employing the classification guidelines contained in 10CFR50.2(v) for Quality Group A and Regulatory Guide 1.26, Revision 2, for Quality Groups B and C along with ANSI N18.2, 1973, and N-18.2a, 1975. Quality Groups A, B, and C are the same as ASME Class 1, 2, and 3, respectively.

The List of Drawings identifies the drawings used to develop the pump and valve testing program.

Table 1 lists the codes and symbols used throughout the program.

Table 2 lists all safety related Class 1, 2, and 3 pumps included in the testing program. The test parameters measured and the testing frequency are also listed.

Table 3 lists all safety related Class 1, 2, and 3 valves included in the program. Specifically excluded per IWV-1200 are valves used for operating convenience only, such as manual vent, drain, instrument, test maintenance, pressure regulating, thermal relief, and system control valves. Test methods and frequencies are also listed. Valve maximum stroke times are listed. Valves which cannot be tested during normal operation have the next acceptable frequency listed as allowed by IWV-3412(a), IWV-3415 and IWV-3416.

Table 4 provides additional information concerning testing requirements as they were applied to specific valves.

Cold shutdown testing, when required, will commence 48 hours after initiation of cold shutdown conditions as defined in Technical Specifications, except for refueling outages. Testing will continue until completed or until the plant is ready to return to operation. Completion of all testing will not be a prerequisite to returning to operation. Testing not completed at one shutdown will be continued during subsequent shutdowns.

TABLE 1

H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

CODES AND SYMBOLS

Valve Types

BF Butterfly
 CK Check
 DA Diaphragm
 GA Gate
 GL Globe
 ND Needle
 REG Regulator
 RV Relief/Safety
 3W 3-Way
 VB Vacuum Breaker

Actuator Types

AO Air
 M Manual
 MO Motor
 SA Self Actuate
 SO Solenoid

Valve Position

CL Closed
 O Open
 LC Locked Closed
 LO Locked Open

Valve Test Method

F Observe Failure Mode
 FF Normally closed check valves
 are given a forward flow test
 to verify that disc opens.
 J Category A containment isolation
 valve tested in accordance with
 10CFR50 App. J.
 LT Leak Test
 RF Normally open check valves are
 given a reverse flow test to show
 that disc seats.
 RV Relief Valve (Test per IWW-3510)
 S Full Stroke
 T Measure Time
 VI Verify Remote Indication

Test Intervals

W Weekly
 M Monthly
 Q Quarterly
 C Cold Shutdown
 R Refueling
 A Annual
 X Frequency Determined from
 Table IWW-3510-1
 J Frequency Determined by
 10CFR50 App. J.

Misc. Symbols

NA Not Applicable
 NR Not Required

TA
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2
PUMP TEST PROGRAM

Page 1 of 2

Pump Name & Drawing Number	Pump No.	Test Parameter Measured							Relief Request And Remarks
		Speed n	Inlet Pressure P_i	Differential Pressure ΔP	Flow Rate Q	Vibration Amplitude V	Lubricant Level or Pressure	Bearing Temperature T_b	
Auxiliary Feedwater G-190197	AFW-A*	NR	Q	Q	NR	Q	Q	NR	1,2,4 P.T.
	AFW-B*	NR	Q	Q	NR	Q	Q	NR	1,2,4 22.1A
	AFW-SD	Q	Q	Q	NR	Q	Q	NR	1,2,4 B,C
Safety Injection 5379-1082	SI-A*	NR	Q	Q	NR	Q	Q	NR	1,2,4 P.T.
	SI-B*	NR	Q	Q	NR	Q	Q	NR	1,2,4 2.7A
	SI-C*	NR	Q	Q	NR	Q	Q	NR	1,2,4 B,C
Residual Heat Removal 5379-1484	RHR-A*	NR	Q	Q	NR	Q	Q	NR	1,2,4 P.T.
	RHR-B*	NR	Q	Q	NR	Q	Q	NR	1,2,4 2.8A B,C
Containment Spray 5379-1082	CS-A*	NR	Q	Q	NR	Q	Q	NR	1,2,4 P.T.
	CS-B*	NR	Q	Q	NR	Q	Q	NR	1,2,4 3.4A B,C
Service Water G-190199 Sh. 1	SW-A*	NR	Q	R	NR	Q	Q	NR	1,2,3 P.T.
	SW-B*	NR	Q	R	NR	Q	Q	NR	1,2,3 4.1A
	SW-C*	NR	Q	R	NR	Q	Q	NR	1,2,3 B,C
	SW-D*	NR	Q	R	NR	Q	Q	NR	1,2,3
Component Cooling 5379-376 Sh. 1	CCW-B*	NR	Q	Q	NR	Q	Q	NR	1,2,4 P.T.
	CCW-C*	NR	Q	Q	NR	Q	Q	NR	1,2,4 36.2
Service Water Booster G-190199 Sh. 2	SWBP-A*	NR	Q	Q	Q	Q	Q	NR	1,2 P.T.
	SWBP-B*	NR	Q	Q	Q	Q	Q	NR	1,2 4.1A B,C

*Synchronous or induction motors do not require speed check (IWP-4400).

Page 2 of 2

Pump Name & Drawing Number	Pump No.	Test Parameter Measured							Relief Request And Remarks
		Speed n	Inlet Pressure P_i	Differential Pressure ΔP	Flow Rate Q	Vibration Amplitude V	Lubricant Level or Pressure	Bearing Temperature T_b	
Charging 5379-685 Sh. 2	CVC-B	Q	Q	Q	Q	Q	Q	NR	1,2 P.T.
	CVC-C	Q	Q	Q	Q	Q	Q	NR	1,2 18.2A B,C
Boric Acid Transfer 5379-685 Sh. 3	A*	NR	Q	Q	NR	Q	NR	NR	1,2,4 P.T.
	B*	NR	Q	Q	NR	Q	NR	NR	1,2,4 7.1A
Diesel Fuel Transfer G-190204A Sh. 1	A*	NR	Q	Q	R	Q	NR	NR	1,2,5
	B*	NR	Q	Q	R	Q	NR	NR	1,2,5 P.T. 23.5

*Synchronous or induction motors do not require speed check (IWP-4400).

TABLE 2

H. B. ROBINSON UNIT 2 SPECIFIC REQUESTS FOR RELIEF

This section provides justification for the specific relief requested from Code test requirements as provided for in 10CFR50.55a(g)(5)(iii). Each request is identified by a unique number and identifies the pump(s) for which the request is being made. The specific Code test requirement found to be impractical is defined and the basis for exclusion from Code requirements is presented. Any testing performed in lieu of Code requirements is specified.

1. Specific Relief Request:

Monthly In service Test

Applicable To:

All pumps.

Basis for Relief Request:

Monthly Section XI operability testing has been a plant requirement for most of these pumps since operation began. An analysis of the results of these tests and comparable data from other operating plants has shown no significant changes in performance. Based on this analysis, the continuation of Section XI monthly testing would not significantly increase plant safety.

Monthly pump testing requires a total of at least 250 hours per year of pump operation, at least 575 man-hours per year for data acquisition, and at least 50 man-hours per year for data reduction, analysis, and record keeping. This amounts to a total of 625 man-hours per year. At a conservative total cost of \$20 per man-hour, this amounts to \$12,500 per year. Based upon the average exposure rates in the pump access areas, the total man-rem exposure per year for pump testing is approximately 1.0 man-rem. At the present conservatively estimated cost of \$10,000 per man-rem to plant personnel, this exposure costs an additional \$10,000 per year. Total cost to our customers is approximately \$22,500 per year, for no significant increase in safety.

Alternate Testing:

Pumps will be tested in compliance with ASME Section XI and this program once per quarter. This is in agreement with changes that were implemented in Subsection IWP of the Code in the Winter, 1979, addenda.

TABLE 2

H. B. ROBINSON UNIT 2
SPECIFIC REQUESTS FOR RELIEF

2. Specific Relief Request:

Measuring pump bearing temperature annually.

Applicable To:

All pumps.

Basis for Relief Request:

The referenced Edition of the Code requires bearing temperature to be recorded annually. It has been demonstrated by experience that bearing temperature rise occurs only minutes prior to bearing failure. Therefore, the detection of possible bearing failure by a yearly temperature measurement is extremely unlikely. It requires at least an hour of pump operation to achieve stable bearing temperatures. The small probability of detection of bearing failure by temperature measurement does not justify the additional pump operating time required to obtain the measurements.

Alternate Testing:

NONE. This is in agreement with present changes that are being implemented in Subsection IWP of the Code to delete yearly bearing temperature measurement. Deletion of bearing temperature has been approved and will be included in future Addenda. See minutes of the November 28, 1979 meeting of the Operating and Maintenance Working Group - Testing of Pumps and Valves in San Jose, California, dated January 9, 1980.

3. Specific Relief Request:

A. Flow Rate Measurements as Required by IWP-3000.

B. Differential Pressure Measurements as Required by IWP-3000.

Applicable To:

Service Water Pumps

Basis for Relief Request:

The service water pumps are used for removing heat from certain secondary system components during normal operation. Since heat load varies and inlet temperatures vary, automatic

TABLE 2

H. B. ROBINSON UNIT 2
SPECIFIC REQUESTS FOR RELIEF

temperature control valves will vary the flow rates through the individual components, thus varying pump resistance. The system has no installed flow measuring devices capable of measuring flow from the pumps. The piping is concrete lined which prohibits the use of ultrasonic flow measuring techniques. There is insufficient room on the outlet piping of each individual pump to allow installation of any accurate flow devices.

H. B. Robinson currently verifies service water system operation during refueling by conducting a "dead head" (zero flow) test on each pump. This test provides a point for comparison to determine the condition of the pumps since the previous tests. These tests will be used as an alternative to the monthly Section XI test. If a pump is declared inoperable and maintenance is required on that pump, the pump will be tested in the manner in which the refueling tests are performed. Vibration and normal pump parameters will be checked on a quarterly basis as per the ISI Program requirements.

Alternate Testing:

Verification of system operation during refueling by conducting "dead head" (zero flow) test on each pump.

4. Specific Relief Request:

Measure Flow Rate.

Applicable To:

Auxiliary Feedwater A, B, and SD, Safety Injection A, B, and C, Residual Heat Removal A and B, Containment Spray A and B, Component Cooling A and B, and Boric Acid Transfer A and B.

Basis for Relief Request:

Instrumentation is not installed to measure flow rate for testing.

For the first ISI interval, these pumps (except Boric Acid Transfer A and B) were tested in a fixed resistance configuration so that any change in performance would be indicated by a change in differential pressure. This method of testing has proven satisfactory and will be continued.

TABLE 2
H. B. ROBINSON UNIT 2
SPECIFIC REQUESTS FOR RELIEF

Alternate Testing:

NONE.

5. Specific Relief Request:

Measure Flow Rate.

Applicable To:

Diesel Fuel Oil Transfer Pumps A and B.

Basis for Relief Request:

These pumps discharge through a fixed resistance system of piping into the fuel oil day tanks. There is no flow instrumentation installed in this piping. Differential pressure will be measured quarterly for these pumps.

These pumps are run weekly to restore the level in the day tank after performance of the diesel generator test. This frequency is four times that required by IWP-3400, Summer, 1978 Addenda.

Alternate Testing:

Flow rates will be measured by a separate test procedure using manual calculations at refueling intervals.

TABLE 3 VALVE TEST PROGRAM
 11. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name

Sampling System

P&ID No.

ISI-200-5379-353

Page 1 of 2

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
956A	2	B-5	X					3/8	GL	AO	CL	Y	S F T VI J	Q Q Q Q J	1	60	P.T. 40
956B	2	B-6	X					3/8	GL	AO	CL	Y	S F T VI J	Q Q Q Q J	1	60	P.T. 40
956C	2	C-5	X					3/8	GL	AO	CL	Y	S F T VI J	Q Q Q Q J	1	60	P.T. 40
956D	2	C-6	X					3/8	GL	AO	CL	Y	S F T VI J	Q Q Q Q J	1	60	P.T. 40
956E	2	E-5	X					3/8	GL	AO	CL	Y	S F T VI J	Q Q Q Q J	1	60	P.T. 40

TABLE 3 VALVE TEST PROGRAM
 II. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name Sampling System

PSID No. ISI-200-5379-353

Page 2 of 2

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
956F	2	E-6	X					3/8	GL	AO	CL	Y	S F T VI J	Q Q Q Q Q J	1	60	P.T. 40
956G	2	G-5	X					3/8	GL	AO	CL	Y	S F T VI J	Q Q Q Q Q J	1	60	P.T. 40
956H	2	G-6	X					3/8	GL	AO	CL	Y	S F T VI J	Q Q Q Q Q J	1	60	P.T. 40
959	2	J-4	X					3/8	GL	AO	CL	N	S F T VI	Q Q Q Q Q		60	P.T. 40

TABLE 3 VALVE TEST PROGRAM
 II. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name Auxiliary Coolant Sys. Component P&ID No. ISI-200-5379-376, Sh. 1 of 3

Cooling

Page 1 of 1

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
702A	3	II-5		X				16	CK	SA	O/C	N	FF RF	Q			P.T. 36.2
702B	3	K-5		X				16	CK	SA	O/C	N	FF RF	Q			P.T. 36.2
702C	3	M-5		X				16	CK	SA	O/C	N	FF RF	Q			P.T. 36.2
707	3	B-4		X				3x4	RV	SA	CL	N	RV	X			P.T. 36.1

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

Auxiliary Coolant Sys. Component P&ID No. ISI-200-5379-376, Sh. 3 of 3 Page 1 of 1

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
791D	3	L-10			X			3/4x1	RV	SA	CL	Y	RV	X		P.T. 36.1	
791E	3	I-10			X			3/4x1	RV	SA	CL	Y	RV	X		P.T. 36.1	
791J	3	C-4			X			3/4x1	RV	SA	CL	Y	RV	X		P.T. 36.1	
791K	3	E-5			X			3/4x1	RV	SA	CL	Y	RV	X		P.T. 36.1	

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name Auxiliary Coolant Sys. Component
Cooling

P&ID No. ISI-200-5379-376, Sh. 2 of 3

Page 1 of 2

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
FCV-626	2	K-14	X					3	GA	MO	O	Y	S T VI J	C C C J	1	60	P.T. 42.0
715	2	N-12			X			3x4	RV	SA	CL	Y	RV	X			P.T. 36.1
716A	2	J-3		X				6	GA	MO	O	Y	S T VI	C C C		60	P.T. 42.0
716B	2	J-3	X					6	GA	MO	O	Y	S T J VI	C C J C	1	60	P.T. 42.0
722A	3	M-8			X			B/4x1	RV	SA	CL	Y	RV	X			P.T. 36.1
722B	3	I-8			X			B/4x1	RV	SA	CL	Y	RV	X			P.T. 36.1
722C	3	K-8			X			B/4x1	RV	SA	CL	Y	RV	X			P.T. 36.1
729	3	H-13			X			3x4	RV	SA	CL	Y	RV	X			P.T. 36.1
730	2	I-14	X					6	GA	MO	O	Y	S T J VI	C C J C	1	60	P.T. 42.0

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name Auxiliary Coolant Sys. Component
Cooling

P&ID No. ISI-200-5379-376, Sh. 2 of 3

Page 2 of 2

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
735	2	J-16	X					3	GL	MO	O	Y	S T VI J	C C C J	1	120	P.T. 42.0
737A	2	N-3		X				3	GA	M	O	Y	S	Q			P.T. 36.2
739	2	M-14		X				3	GL	AO	CL	Y	S F T VI	Q Q Q Q		60	P.T. 36.2
749A	3	D-3		X				16	GA	MO	CL	Y	S T VI	Q Q Q		300	P.T. 2.8A
749B	3	D-6		X				16	GA	MO	CL	Y	S T VI	Q Q Q		300	P.T. 2.8A
791A	3	B-15			X			3/4x1	RV	SA	CL	Y	RV	X			P.T. 36.1
791B	3	D-15			X			3/4x1	RV	SA	CL	Y	RV	X			P.T. 36.1

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name CVCS

P&ID No. ISI-200-5379-685, Sh. 1 of 3

Page 1 of 3

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
200A	2	B-9		X				2	GL	AO	C	Y	S F T VI	Q Q Q Q		10	P.T. 18.2A
200B	2	B-11		X				2	GL	AO	C	Y	S F T VI	Q Q Q Q		10	P.T. 18.2A
200C	2	B-10		X				2	GL	AO	O	Y	S F T VI	Q Q Q Q		10	P.T. 18.2A
202A	2	C-15	X					3	GA	M	O	N	S J	C J	1		P.T. 42.0
203	2	A-9			X			2x3	RV	SA	CL	Y	RV	X			P.T. 25.4

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name CVCS

P&ID No. ISI-200-5379-685, Sh. 1 of 3

Page 2 of 3

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
204A	2	A-13	X					2	GL	AO	O	Y	S F T VI	C C C J		10	P.T. 42.0
204B	2	A-13	X					2	GL	AO	O	Y	J S F T VI	C C C J	1	60	P.T. 42.0
282	2	D-14	X					2	GL	M	O	Y	J S J	C J	1 1		P.T. 42.0
292A	2	N-14	X					3/4	GL	M	O	N	S J	C J	1		P.T. 42.0
293A	2	M-14	X					2	GL	M	o/c	N	S J	C J	1		P.T. 42.0
293C	2	L-14	X					2	GL	M	o/c	N	S J	C J	1		P.T. 42.0
295	2	N-15	X					3	GL	M	C	N	S J	C J	1		P.T. 42.0
297A	2	M-1	X					2	ND	M	O	N	S J	C J	1		P.T. 42.0
297B	2	M-6	X					2	ND	M	O	N	S J	C J	1		P.T. 42.0

System Name

CVCS

P&ID No.

ISI-200-5379-685, Sh. 1 of 3

Page 3 of 3

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
297C	2	M-10	X					2	ND	M	O	N	S J	C J	1		P.T. 42.0
309A	2	D-15	X				X	2	GL	M	CL	N	J	J	1		
381	2	G-14	X					3	GA	MO	O	N	S T VI J	C C C J		60	P.T. 42.0
382	3	F-13		X				3	RV	SA	CL	Y	RV	X			P.T. 25.4

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name CVCS

P&ID No. ISI-200-5379-685, Sh. 2 of 3

Page 1 of 2

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
FCV-113A	3	J-13		X				1	GL	AO	C	Y	S F T VI	M M N M		30	P.T. 7.1
LCV-115B	3	K-9		X				4	BF	AO	CL	N	S F T VI	M M M N		30	P.T. 7.1
LCV-115C	3	H-7		X				4	GA	MO	O	Y	S T VI	C C C		30	P.T. 42.0
209	3	B-7			X			2x3	RV	SA	CL	Y	RV	X			P.T. 25.4
257	3	C-8			X			2x3	RV	SA	CL	Y	RV	X			P.T. 25.4
266	3	I-7			X			4	CK	SA	O	Y	FF RF	Q C			FF Verified by normal charging pump flow.
283A	3	J-3			X			3/4x2	RV	SA	CL	Y	RV	X			P.T. 25.4
283B	3	K-3			X			3/4x2	RV	SA	CL	Y	RV	X			P.T. 25.4
283C	3	M-3			X			3/4x2	RV	SA	CL	Y	RV	X			P.T. 25.4

TABLE 3 VALVE TEST PROGRAM
II. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name

CVCS

PSID No.

ISI-200-5379-685, Sh. 2 of 3

Page 2 of 2

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
350	3	L-13		X				2	GA	MO	CL	Y	S T VI	M N M		60	P.T. 7.1
351	3	L-13			X			2	CK	SA	CL	Y	FF	C			G.P. 6
355	3	J-13			X			1	CK	SA	CL	Y	FF	Q			P.T. 18.2A
357	3	K-10			X			4	CK	SA	CL	Y	FF	Q R	10		P.T. 40 (Partial Stroke) G.P. 8

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name

CVCS

P&ID No.

ISI-200-5379-685, Sh. 3 of 3

Page 1 of 1

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
397A	3	I-7			X			2	CK	SA	CL	N	FF	Q			P.T. 18.2A, P.T. 7.1A
397B	3	I-8			X			2	CK	SA	CL	N	FF	Q			P.T. 18.2A, P.T. 7.1A

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name CVCS P&ID No. 5379-686 Sh. 1 of 2

Page 1 of 1

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
1118A	3	B-6			X			2x3	RV	SA	CL	YES	RV	X			P.T. 25.4
1118B	3	E-6			X			2x3	RV	SA	CL	YES	RV	X			P.T. 25.4
1118C	3	G-6			X			2x3	RV	SA	CL	YES	RV	X			P.T. 25.4

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name Waste Disposal P&ID No. ISI-406-5379-920, Sh. 1 of 4 Page 1 of 2

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
1721	2	J-10	X					3	DA	AO	O	Y	S F T VI J	Q Q Q Q J	1	60	P.T. 40
1722	2	J-9	X					3	DA	AO	O	Y	S F T VI J	Q Q Q Q J	1	60	P.T. 40
1723	2	L-9	X					2	DA	AO	O	Y	S F T VI J	Q Q Q Q J	1	60	P.T. 40
1728	2	L-10	X					2	DA	AO	O	Y	S F T VI J	Q Q Q Q J	1	60	P.T. 40
1786	2	F-11	X					1	DA	AO	O	Y	S F T VI J	Q Q Q Q J	1	60	P.T. 40

H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

Waste Disposal

System Name _____

ISI-406-5379-920, SH
P&ID No.

Page 2 of 2

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
1787	2	E-11	X					1	DA	AO	O	Y	S F T VI J	Q Q Q Q J	1	60	P.T. 40
1789	2	F-10	X					3/4	DA	AO	O	Y	S F T VI J	Q Q Q Q J	1	60	P.T. 40
1793	2	E-11		X				1	DA	M	O	Y	S	Q			P.T. 40
1794	2	G-11	X					3/4	DA	AO	O	Y	S F T VI J	Q Q Q Q J	1	60	P.T. 40

TABLE 3 VALVE TEST PROGRAM

H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name

Waste Disposal

P&ID No.

5379-921 Sh. 2 of 2

Page 1 of 1

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
1621	3	C-14		X				1x2	RV	SA	CL	NO	RV	X			P.T. 25.4
1622	3	B-14		X				1x2	RV	SA	CL	NO	RV	X			P.T. 25.4
1623	3	G-14		X				1x2	RV	SA	CL	NO	RV	X			P.T. 25.4
1624	3	E-14		X				1x2	RV	SA	CL	NO	RV	X			P.T. 25.4

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name Safety Injection

P&ID No. ISI-200-5379-1082, Sh. 1

Page 1 of 4

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
RV-842	2	H-1			X			1	RV	SA	CL	N	RV	X			P.T. 25.4
841A	2	D-9		X				1	GL	AO	O	N	S F T VI	Q Q Q Q		30	P.T. 2.7A
841B	2	D-9		X				1	GL	AO	O	N	S F T VI	Q Q Q Q		30	P.T. 2.7A
845A	3	J-7		X				2	GL	MO	C	N	S T VI	C C C		60	P.T. 2.13
845B	3	J-7		X				2	GL	MO	C	N	S T VI	C C C		60	P.T. 2.13
857A	2	D-1			X			3/4x1	RV	SA	CL	Y	RV	X			P.T. 25.4
864A	2	D-16		X				16	GA	MO	O	N	S T VI	C C C		120	P.T. 2.13
864B	2	D-16		X				16	GA	MO	O	N	S T VI	C C C		120	P.T. 2.13

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

Safety Injection

ISI-200-5379-1082, Sh. 1

Page 2 of 4

System Name

P&ID No.

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (Inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
867A	2	F-7		X				4	GA	MO	CL	Y	S T S	Q Q Q Q Q		10	P.T. 2.7A
867B	2	F-7		X				4	GA	MO	CL	Y	VI S T VI	Q Q Q Q Q		10	P.T. 2.7A
869	2	B-1	X					3	GA	MO	O	N	S T VI J	C C C J		60	P.T. 42.0
870A	2	G-1	X					3	GA	MO	CL	N	S T VI J	Q Q Q J		10	P.T. 2.7A
870B	2	G-1	X					3	GA	MO	CL	N	S T VI J	Q Q Q J		10	P.T. 2.7A
871	2	K-14			X			3/4x1	RV	SA	CL	N	RV	X			P.T. 25.4
872	3	H-6			X			3/4x1	RV	SA	CL	N	RV	X			P.T. 25.4
878A	2	F-10		X				4	GA	MO	O	N	S T VI	C C C		120	P.T. 42.0

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name Safety Injection

P&ID No. ISI-200-5379-1082, Sh. 1

Page 3 of 4

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
878B	2	D-10		X				4	GA	MO	O	N	S T VI FF	C C C R		120	P.T. 42.0
879A	2	H-11			X			3	CK	SA	CL	N	FF	R	7		Refueling - P.T. 2.9 (Partial Stroke Quarterly P.T. 2.7A)
879B	2	E-11			X			3	CK	SA	CL	N	FF	R	7		Refueling - P.T. 2.9 (Partial Stroke Quarterly P.T. 2.7A)
879C	2	C-11			X			3	CK	SA	CL	N	FF	R	7		Refueling - P.T. 2.9 (Partial Stroke Quarterly P.T. 2.7A)
880A	2	M-9		X				6	GA	MO	CL	N	S T VI S T VI S T VI	Q Q Q Q Q Q Q Q Q	60		P.T. 3.4A
880B	2	N-9		X				6	GA	MO	CL	N	S T VI S T VI	Q Q Q Q Q Q Q	60		P.T. 3.4A
880C	2	K-9		X				6	GA	MO	CL	N	S T VI S T VI	Q Q Q Q Q Q Q	60		P.T. 3.4A
880D	2	K-9		X				6	GA	MO	CL	N	S T VI S T VI	Q Q Q Q Q Q Q	60		P.T. 3.4A
883L	2	H-2	X				X	1	GL	M	LC	N	J	J	1		
883W	2	G-3	X				X	1	GL	M	LC	N	J	J	1		

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name Safety Injection

P&ID No. ISI-200-5379-1082, Sh. 1

Page 4 of 4

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
889A	2	L-13			X			2	CK	SA	CL	N	FF	Q			P.T. 3.4A
889B	2	L-13			X			2	CK	SA	CL	N	FF	Q			P.T. 3.4A
890A	2	M-8			X			6	CK	SA	CL	N	FF	CR	8		P.T. 42.0 Partial Stroke Full Stroke-Refueling
890B	2	K-8			X			6	CK	SA	CL	N	FF	CR	8		P.T. 42.0 Partial Stroke Full Stroke-Refueling
891A	2	N-5	X					6	GA	M	O	N	SJ	QJ	1		P.T. 3.4A
891B	2	K-5	X					6	GA	M	O	N	SJ	QJ	1		P.T. 3.4A
894	2	F-5			X			1	CK	SA	CL	Y	RF	Q			P.T. 7.1A
895V	2	A-2	X				X	3/4	GL	M	LC	N	J	J	1		
898F	2	A-2	X				X	3/4	GL	M	LC	N	J	J	1		
870C	3	G-5			X			3/4	VB	SA	C	N	S	R	11		
870D	3	G-5			X			3/4	VB	SA	C	N	S	R	11		

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

Safety Injection

ISI-200-5379-1082, Sh. 2

System Name _____

P&ID No. _____

Page 1 of 4

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
858A	2	B-11			X			2x3	RV	SA	CL	Y	RV	X			P.T. 25.4
858B	2	E-11			X			2x3	RV	SA	CL	Y	RV	X			P.T. 25.4
858C	2	H-11			X			2x3	RV	SA	CL	Y	RV	X			P.T. 25.4
859	2	C-1			X			3x4	RV	SA	CL	N	RV	X			P.T. 25.4
860A	2	N-8		X				14	GA	MO	CL	Y	S T VI	Q Q Q		120	P.T. 2.8A
860B	2	N-8		X				14	GA	MO	CL	Y	S T VI	Q Q Q		120	P.T. 2.8A
861A	2	N-9		X				14	GA	MO	CL	Y	S T VI	Q Q Q		120	P.T. 2.8A
861B	2	N-9		X				14	GA	MO	CL	Y	S T VI	Q Q Q		120	P.T. 2.8A

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name Safety Injection

P&ID No. ISI-5379-1082, Sh. 2

Page 2 of 4

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
862A	2	J-16		X				14	GA	MO	O	YES	S T VI	C C C		120	P.T. 42.0
862B	2	K-16		X				14	GA	MO	O	YES	S T VI	C C C		120	P.T. 42.0
863A	2	I-12		X				8	GA	MO	CL	YES	S T VI	C C C		120	P.T. 42.0
863B	2	J-12		X				8	GA	MO	CL	YES	S T VI	C C C		120	P.T. 42.0
855	2	C-16	X					1	GL	AO	CL	NO	S F T VI J	Q O Q Q J		60	P.T. 2.7A

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name Safety Injection

P&ID No. ISI-200-5379-1082, Sh. 2

Page 3 of 4

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
865A	2	D-9		X				10	GA	MO	O	Y	S T VI	C C C		10	P.T. 2.5
865B	2	G-9		X				10	GA	MO	O	Y	S T VI	C C C		10	P.T. 2.5
865C	2	J-9		X				10	GA	MO	O	Y	S T VI	C C C		10	P.T. 2.5
866A	1	G-1		X				2	GA	MO	CL	Y	S T VI	C C C		60	P.T. 42.0
866B	1	G-2		X				2	GA	MO	CL	Y	S T VI	C C C		60	P.T. 42.0
873A	2	H-2			X			2	CK	SA	CL	Y	FF	R	4		P.T. 2.9
873B	2	G-2			X			2	CK	SA	CL	Y	FF	R	4		P.T. 2.9
873C	2	G-3			X			2	CK	SA	CL	Y	FF	R	4		P.T. 2.9
873D	1	L-2			X			2	CK	SA	CL	Y	FF	R	4		P.T. 2.9

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name Safety Injection

P&ID No. ISI-200-5379-1082, Sh. 2

Page 4 of 4

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
873E	1	K-3			X			2	CK	SA	CL	Y	FF	R	4		P.T. 2.9
873F	1	I-4			X			2	CK	SA	CL	Y	FF	R	4		P.T. 2.9
874A	1	H-1			X			2	CK	SA	CL	Y	FF	R	4		P.T. 2.9
874B	1	H-2			X			2	CK	SA	CL	Y	FF	R	4		P.T. 2.9
875A	1	J-3			X			10	CK	SA	CL	Y	FF	C			P.T. 42.0 Full Stroke P.T. 2.5 Partial Stroke
875B	1	K-3			X			10	CK	SA	CL	Y	FF	C			P.T. 42.0 Full Stroke P.T. 2.5 Partial Stroke
875C	1	M-2			X			10	CK	SA	CL	Y	FF	C			P.T. 42.0 Full Stroke P.T. 2.5 Partial Stroke
875D	1	D-7			X			10	CK	SA	CL	Y	FF	C	3		P.T. 2.5 Partial Stroke
875E	1	G-7			X			10	CK	SA	CL	Y	FF	C	3		P.T. 2.5 Partial Stroke
875F	1	J-7			X			10	CK	SA	CL	Y	FF	C	3		P.T. 2.5 Partial Stroke
876A	1	D-6			X			8	CK	SA	CL	Y	FF	C			P.T. 42.0
876B	1	G-6			X			8	CK	SA	CL	Y	FF	C			P.T. 42.0
876C	1	J-6			X			8	CK	SA	CL	Y	FF	C			P.T. 42.0

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name Residual Heat Removal

P&ID No. ISI-200-5379-1484

Page 1 of 1

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
706	2	L-1			X			2x3	RV	SA	CL	Y	RV	X			P.T 25.4
744A	2	M-1		X				10	GA	MO	CL	Y	S T VI	Q Q Q		15	P.T. 2.8A
744B	2	M-3		X				10	GA	MO	CL	Y	S T VI	Q Q Q		15	P.T. 2.8A
750	1	N-16		X				14	GA	MO	CL	Y	S T VI	C C C		300	P.T. 42.0
751	1	M-16		X				14	GA	MO	CL	Y	S T VI	C C C		300	P.T. 42.0
753A	2	G-10			X			10	CK	SA	CL	Y	FF	C			Full Stroke Cold Shutdown (GP-6) Partial Stroke Quarterly (P.T. 2.8A)
753B	2	G-10			X			10	CK	SA	CL	Y	FF	C			Full Stroke Cold Shutdown (GP-6) Partial Stroke Quarterly (P.T. 2.8A)
759A	2	G-5		X				10	GA	MO	O	Y	S T VI	Q Q Q		120	P.T. 2.8A
759B	2	D-5		X				10	GA	MO	O	Y	S T VI	Q Q Q		120	P.T. 2.8A

System Name Reactor Coolant

P&ID No. ISI-100-5379-1971, Sh. 2

Page 1 of 2

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
PCV-455C	1	E-17	X					3	GL	AO	CL	Y	S F T VI	C C C C		2	P.T. 42.0
PCV-456	1	D-17		X				3	GL	AO	CL	Y	S F T VI	C C C C		2	P.T. 42.0
516	2	C-1	X					3/8	GL	AO	CL	Y	S F T VI	Q Q Q Q	1	60	P.T. 40
519A	2	F-1	X					3	DA	AO	CL	Y	S F T VI	Q Q Q Q		60	P.T. 40
DMC-1		F-18	X				X	3/8	GA	M	CL	Y	J	J	1		
DMC-2		F-19	X				X	3/8	GA	M	CL	Y	J	J	1		

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name Reactor Coolant

P&ID No. ISI-100-5379-1971, Sh. 2

Page 2 of 2

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
519B	2	F-2	X					3	DA	AO	CL	Y	S F T VI J	Q Q Q Q J	1	60	P.T. 40
535	1	D-17		X				3	GA	MO	O	Y	S T VI	Q Q C		60	P.T. 40.0 (S,T) P.T. 42 (VI)
536	1	E-17		X				3	GA	MO	O	Y	S T VI	Q Q C		60	P.T. 40 (S,T) P.T. 42 (VI)
550	2	E-2	X					3/4	DA	AO	O	Y	S F T VI J	Q Q Q Q J	1	120	P. T. 40
551A	1	B-11			X			4x6	RV	SA	CL	Y	RV	R			P.T. 25.1
551B	1	B-13			X			4x6	RV	SA	CL	Y	RV	R			P.T. 25.1
551C	1	B-15			X			4x6	RV	SA	CL	Y	RV	R			P.T. 25.1
553	2	C-2	X					3/8	GL	AO	C	Y	S F T VI J	Q Q Q Q J	1	60	P.T. 40

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

Main Extraction & Auxiliary Steam
System Name _____

ISI-G-190196, Sh. 1
P&ID No. _____

Page 1 of 3

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
MS-V1-3A	2	J-16			X			26	CK	SA	O	N	RF	R	2		
MS-V1-3B	2	E-16			X			26	CK	SA	O	N	RF	R	2		
MS-V1-3C	2	A-16			X			26	CK	SA	O	N	RF	R	2		
MS-V1-3A Isol.	2	J-15		X				26	GA	AO	O	N	S F T VI	C C C C		5	P.T. 41
MS-V1-3B Isol.	2	E-15		X				26	GA	AO	O	N	S F T VI	C C C C		5	P.T. 41
MS-V1-3C Isol.	2	A-15		X				26	GA	AO	O	N	S F T VI	C C C C		5	P.T. 41
MS-V1-8A	2	K-15		X				2	GL	MO	C	N	S T VI	Q Q Q		120	P.T. 22.1A
MS-V1-8B	2	G-15		X				2	GL	MO	C	N	S T VI	Q Q Q		120	P.T. 22.1A

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name Main Extraction & Auxiliary Steam

P&ID No. ISI-G-190196, Sh. 1

Page 2 of 3

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
MS-V1-8C	2	C-15		X				2	GL	MO	C	N	S T VI	Q Q Q		120	P.T. 22.1A
MS-V1-9A	3	K-15			X			2	CK	SA	CL	N	FF	Q			P.T. 22.1A
MS-V1-9B	3	G-16			X			2	CK	SA	CL	N	FF	Q			P.T. 22.1A
MS-V1-9C	3	C-16			X			2	CK	SA	CL	N	FF	Q			P.T. 22.1A
SV1-1A	2	J-10			X			6	RV	SA	C	N	RV	R			P.T. 25.2
SV1-2A	2	J-11			X			6	RV	SA	C	N	RV	R			P.T. 25.2
SV1-3A	2	J-12			X			6	RV	SA	C	N	RV	R			P.T. 25.2
SV1-4A	2	J-13			X			6	RV	SA	C	N	RV	R			P.T. 25.2
SV1-1B	2	F-10			X			6	RV	SA	C	N	RV	R			P.T. 25.2
SV1-2B	2	F-11			X			6	RV	SA	C	N	RV	R			P.T. 25.2
SV1-3B	2	F-12			X			6	RV	SA	C	N	RV	R			P.T. 25.2
SV1-4B	2	F-13			X			6	RV	SA	C	N	RV	R			P.T. 25.2
SV1-1C	2	B-10			X			6	RV	SA	C	N	RV	R			P.T. 25.2
SV1-2C	2	B-11			X			6	RV	SA	C	N	RV	R			P.T. 25.2

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name Main Extraction & Auxiliary Steam P&ID No. ISI-G-190196, Sh. 1

Page 3 of 3

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
SV1-3C	2	B-12		X				6	RV	SA	C	N	RV	R			P.T. 25.2
SV1-4C	2	B-13		X				6	RV	SA	C	N	RV	R			P.T. 25.2

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name Feedwater Condensate & Air Evacuation P&ID No. ISI-G-190197, Sh. 2

Page 1 of 3

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
AFW-2	3	I-17			X			6	CK	SA	CL	N	FF RF	C C			Reverse Flow - P.T. 41.0 Partial Stroke Quarterly-P.T. 22.
AFW-19	3	H-11			X			6	CK	SA	CL	N	FF	C			Full Stroke Cold Shutdown-OP-14 Full Stroke Cold Shutdown-OP-14 Partial Stroke Quarterly-P.T. 22.
AFW-20A	3	L-8		X				4	GA	MO	O	N	S T VI	Q Q Q		60	P.T. 22.1A
AFW-20B	3	M-8		X				4	GA	MO	O	N	S T VI	Q Q Q		60	P.T. 22.1A
AFW-24	3	L-14		X				6	GA	M	LC	N	S	Q			P.T. 40
AFW-40	3	L-10			X			4	CK	SA	CL	N	FF	C			Partial Stroke Quarterly-P.T. 22- Full Stroke Cold Shutdown-OP-14
AFW-41	3	N-10			X			4	CK	SA	CL	N	FF	C			Partial Stroke Quarterly-P.T. 22- Full Stroke Cold Shutdown-OP-14
AFW-68	2	M-5			X			4	CK	SA	CL	Y	FF	C			OP-14
AFW-69	2	L-5			X			4	CK	SA	CL	Y	FF	C			OP-14
AFW-70	2	N-5			X			4	CK	SA	CL	Y	FF	C			OP-14
AFW-V2-14A	3	C-10		X				4	GA	MO	CL	Y	S T VI	Q Q Q		60	P.T. 22.1C
AFW-V2-14B	3	E-10		X				4	GA	MO	CL	Y	S T VI	Q Q Q		60	P.T. 22.1C

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

Feedwater Condensate & Air Evacuation

ISI-G-190197, Sh. 2

System Name _____

P&ID No. _____

Page 2 of 3

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
AFW-V2-14C	3	G-10		X				4	GA	MO	CL	Y	S T VI	Q Q Q		60	P.T. 22.1C
AFW-V2-16A	2	M-7		X				4	GA	MO	CL	N	S T VI	Q Q Q		60	P.T. 22.1A
AFW-V2-16B	2	L-7		X				4	GA	MO	CL	N	S T VI	Q Q Q		60	P.T. 22.1B
AFW-V2-16C	2	N-7		X				4	GA	MO	CL	N	S T VI	Q Q Q		60	P.T. 22.1C
DW-19	3	K-17		X				6	GA	M	LC	N	S	Q		NA	P.T. 40
DW-21	3	K-16		X				6	GA	M	LC	N	S	Q		NA	P.T. 40
FCV-479	3	B-11		X				4	GL	AO	CL	Y	S F T VI	C C C C		60	P.T. 41
FCV-489	3	D-11		X				4	GA	AO	CL	Y	S F T VI	C C C C		60	P.T. 41

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name Feedwater Condensate & Air Evacuation P&ID No. ISI-G-190197, Sh. 2

Page 3 of 3

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
FCV-499	3	F-11		X				4	GL	AO	CL	Y	S F T VI	C C C C		60	P.T. 41
FW-V2-6A	3	B-12		X				16	GA	MO	O	N	S T VI	C C C C		120	P.T. 41
FW-V2-6B	3	D-12		X				16	GA	MO	O	N	S T VI	C C C C		120	P.T. 41
FW-V2-6C	3	F-12		X				16	GA	MO	O	N	S T VI	C C C C		120	P.T. 41

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name Service and Cooling Water

P&ID No. ISI-G-190199, Sh. 1

Page 1 of 1

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
374	3	K-2			X			18	CK	SA	O/C	N	FF RF	Q Q			P.T. 4.1A
375	3	K-5			X			18	CK	SA	O/C	N	FF RF	Q Q			P.T. 4.1A
376	3	K-3			X			18	CK	SA	O/C	N	FF RF	Q Q			P.T. 4.1A
377	3	K-6			X			18	CK	SA	O/C	N	FF RF	Q Q			P.T. 4.1A

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

Service and Cooling Water

ISI-G-190199, Sh. 2

System Name _____

P&ID No. _____

Page 1 of 3

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
V6-33A	2	H-8		X				6	BF	MO	O	N	S T VI	Q Q Q		300	P.T. 10.1A
V6-33B	2	H-7		X				6	BF	MO	O	N	S T VI	Q Q Q		300	P.T. 10.1A
V6-33C	2	H-7		X				6	BF	MO	O	N	S T VI	Q Q Q		300	P.T. 10.1A
V6-33D	2	H-6		X				6	BF	MO	O	N	S T VI	Q Q Q		300	P.T. 10.1A
V6-33E	2	H-8		X				6	BF	MO	O	N	S T VI	Q Q Q		300	P.T. 10.1A
V6-33F	2	J-7		X				6	BF	MO	O	N	S T VI	Q Q Q		300	P.T. 10.1A
V6-34A	2	D-16		X				6	BF	MO	O	N	S T VI	Q Q Q		300	P.T. 10.1C

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

Service and Cooling Water

ISI-G-190199, Sh. 2

System Name _____

P&ID No. _____

Page 2 of 3

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
V6-34B	2	C-16		X				6	BF	MO	O	N	S T VI	Q Q Q		300	P.T. 10.1C
V6-34C	2	C-16		X				6	BF	MO	O	N	S T VI	Q Q Q		300	P.T. 10.1C
V6-34D	2	B-16		X				6	BF	MO	O	N	S T VI	Q Q Q		300	P.T. 10.1C
V6-35A	2	B-12		X				1	GL	MO	O	N	S T VI	Q Q Q		300	P.T. 10.1B
V6-35B	2	B-11		X				1	GL	MO	O	N	S T VI	Q Q Q		300	P.T. 10.1B
V6-35C	2	B-11		X				1	GL	MO	O	N	S T VI	Q Q Q		300	P.T. 10.1B
V6-35D	2	B-10		X				1	GL	MO	O	N	S T VI	Q Q Q		300	P.T. 10.1B

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name

Service and Cooling Water

PSID No.

ISI-G-190199, Sh. 2

Page 3 of 3

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
560	3	J-7			X			12	CK	SA	O/C	N	FF	Q			P.T. 4.1A
561	3	J-8			X			12	CK	SA	O/C	N	FF	Q			P.T. 4.1A
562	3	K-11			X			1	CK	SA	O/C	N	FF	Q			P.T. 22.1A
563	3	K-11			X			1	CK	SA	O/C	N	FF	Q			P.T. 22.1A

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON SYSTEM REACTOR PLANT UNIT NO. 2

System Name Service and Cooling Water

P&ID No. ISI-G-190199, Sh. 3

Page 1 of 1

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
V6-16A	3	N-20		X				16	GA	MO	O	N	S T VI	Q Q Q		300	P.T. 4.1A
V6-16B	3	M-20		X				16	GA	MO	O	N	S T VI	Q Q Q		300	P.T. 4.1A
118	3	M-20		X				6	GA	M	LC	N	S	Q		NA	P.T. 40
530	3	L-25			X			1	CK	SA	CL	N	FF	Q			P.T. 22.1A
541	3	I-19			X			30	CK	SA	O/C	N	FF	Q			P.T. 4.1A
542	3	M-19			X			1	CK	SA	CL	N	FF	Q	6		P.T. 22.1A
543	3	M-19			X			1	CK	SA	CL	N	FF	Q	6		P.T. 22.1A
544	3	M-20			X			6	CK	SA	CL	N	FF	Q	5		P.T. 40
545	3	M-20			X			30	CK	SA	O/C	N	FF	Q			P.T. 4.1A

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name Steam Generator Blowdown

P&ID No. ISI-G-190234

Page 1 of 2

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
FCV-1930A	2	B-5	X					3/4	GA	AO	O	N	S F T VI J	Q Q Q J		10	P.T. 40
FCV-1930B	2	B-5	X					3/4	GA	AO	O	N	S F T VI J	Q Q Q J	1	10	P.T. 40
FCV-1931A	2	F-5	X					3/4	GA	AO	O	N	S F T VI J	Q Q Q J	1	10	P.T. 40
FCV-1931B	2	F-5	X					3/4	GA	AO	O	N	S F T VI J	Q Q Q J	1	10	P.T. 40
FCV-1932A	2	K-5	X					3/4	GA	AO	O	N	S F T VI J	Q Q Q J	1	10	P.T. 40
FCV-1932B	2	K-5	X					3/4	GA	AO	O	N	S F T VI J	Q Q Q J	1	10	P.T. 40

TABLE 3 VALVE TEST PROGRAM

H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

Steam Generator Blowdown

ISI-G-190234

System Name _____

P&ID No. _____

Page 2 of 2

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
FCV-1933A	2	C-4	X					3/4	GA	AO	O	N	S F T VI J	Q Q Q J		10	P.T. 40
FCV-1933B	2	D-4	X					3/4	GA	AO	O	N	S F T VI J	Q Q Q J	1	10	P.T. 40
FCV-1934A	2	G-4	X					3/4	GA	AO	O	N	S F T VI J	Q Q Q J	1	10	P.T. 40
FCV-1934B	2	H-4	X					3/4	GA	AO	O	N	S F T VI J	Q Q Q J	1	10	P.T. 40
FCV-1935A	2	K-4	X					3/4	GA	AO	O	N	S F T VI J	Q Q Q J	1	10	P.T. 40
FCV-1935B	2	L-4	X					3/4	GA	AO	O	N	S F T VI J	Q Q Q J	1	10	P.T. 40

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

Penetration Pressurization (PPS)

ISI-G-190261, Sh. 7 of 8

System Name _____

P&ID No. _____

Page 1 of 2

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
EV-H2A	2	E-2	X					1	3W	SO	-	N	S J	Q J	1		P.T. 40
EV-H2B	2	E-5	X					3/8	3W	SO	-	N	S J	C J	1		P.T. 42.0
EV-1722	2	E-9	X				X	1	3W	SO	-	N	J	J	1		
EV-1727	2	D-5	X					3/8	3W	SO	-	N	S J	Q J	1		P.T. 40
EV-1728	2	A-5	X					3/8	3W	SO	-	N	S J	Q J	1		P.T. 40
225C	2	A-5	X				X	3/8	GA	M	CL	N	J	J	1		
226C	2	C-5	X				X	3/8	GA	M	CL	N	J	J	1		

TABLE 3 VALVE TEST PROGRAM

H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name PPSP&ID No. ISI-G-190261, Sh. 7 of 8Page 2 of 2

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
235C	2	E-5	X				X	3/8	GA	M	CL	N	J	J	1		
245A	2	E-9	X				X	3/8	GA	M	CL	N	J	J	1		
251C	2	E-2	X				X	3/8	GA	M	CL	N	J	J	1		

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name Penetration Pressurization (PPS) P&ID No. ISI-G-190261, Sh. 8 of 8

Page 1 of 1

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
EV-1723	2	A-12	X				X	1	3W	SO	-	N	J	J	1		
EV-1724	2	A-16	X				X	1	3W	SO	-	N	J	J	1		
241C	2	A-16	X				X	3/8	GA	N	CL	M	J	J	1		
248A	2	A-12	X				X	3/8	GA	M	CL	N	J	J	1		
274C	2	G-12	X		X		X	3/8	CK	SA	-	N	J	J	1		

TABLE 3 VALVE TEST PROGRAM
 H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name

Isolation Valve Seal Water

PSID No.

ISI-G-190262

Page 1 of 1

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
Check valves at class boundaries	2		X		X			3/8	CK	SA	O/CL	Y	J FF	J R	1		P.T. 2.6

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name HVAC

PSID No. ISI-G-190304, Sh. 1 of 2

Page 1 of 3

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
RMS-1	2	I-19	X					1	GA	AO	0	N	S F T VI J	Q Q Q Q J	1	60	P.T. 40
RMS-2	2	I-19	X					1	GA	AO	0	N	S F T VI J	Q Q Q Q J	1	60	P.T. 40
RMS-3	2	I-19	X					1	GA	AO	0	N	S F T VI J	Q Q Q Q J	1	60	P.T. 40
RMS-4	2	I-19	X					1	GA	AO	0	N	S F T VI J	Q Q Q Q J	1	60	P.T. 40
VI2-6	2	F-10	X				X	42	BF	AO	0	N	J	J	1	60	

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name HVAC P&ID No. ISI-G-190304, Sh. 1 of 2

Page 2 of 3

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
VI2-7	2	F-11	X				X	42	BF	AO	C	N	J	J	1	60	
VI2-8	2	G-18	X				X	42	BF	AO	C	N	J	J	1	60	
VI2-9	2	G-17	X				X	42	BF	AO	C	N	J	J	1	60	
VI2-10	2	H-18	X					6	BF	AO	C	Y	S F T VI J	Q Q Q Q J	1	60	P.T. 40
VI2-11	2	H-17	X					6	BF	AO	C	Y	S F T VI J	Q Q Q Q J	1	60	P.T. 40

TABLE 3 VALVE TEST PROGRAM

H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name

HVAC

P&ID No.

ISI-G-190304, Sh. 1 of 2

Page 3 of 3

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
VI2-12	2	G-10	X				X	6	BF	AO	C	N	J	J	1		
VI2-13	2	G-11	X				X	6	BF	AO	C	N	J	J	1		

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name Post Accident Sampling P&ID No. ISI-HBR2-6490

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
PAS-1	2	C-5	X				X	3/8	GL	N	CL	N	J	J	1		P.T. 51
PAS-2	2	D-5	X				X	3/8	GL	M	CL	N	J	J	1		P.T. 51
PAS-3	2	C-5	X				X	3/8	GL	M	CL	N	J	J	1		P.T. 51
PAS-4	2	D-5	X				X	3/8	GL	M	CL	N	J	J	1		P.T. 51
PAS-5	2	D-5	X				X	3/8	GL	M	CL	N	J	J	1		P.T. 51
PAS-6	2	D-5	X				X	3/8	GL	M	CL	N	J	J	1		P.T. 51

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name Post Accident Cont. Vent & Ins. Gas P&ID No. ISI-IIBR2-6933

Page 1 of 2

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max Stroke Time (sec.)	Remarks
			A	B	C	D											
PCV-1716	2	G-4	X					2	GA	AO	0	N	S F VI T T T C C C	C	1	60	P.T. 42.0
SA-43	2	G-4	X				X	2	DA	M	LC	N	J	J	1		
SA-44	2	G-3	X				X	2	DA	M	LC	N	J	J	1		
VS-5	2	G-3	X		X			2	CK	SA	O/C	N	J	J	1,9		
VI2-14	2	B-1	X					3	DA	AO	C	N	S F T VI T C J C C	C	1	60	P.T. 42.0
VI2-15	2	B-3	X					3	DA	AO	C	N	S F T VI T C J C C	C	1	60	P.T. 42.0

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name

Post Accident Cont. Vent & Ins. Gas

P&ID No.

ISI-HBR2-6933

Page 2 of 2

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
V12-18	2	D-2	X					3	DA	AO	C	Y	S F T VI J	C C C C C C C C	1	60	P.T. 42.0
V12-19	2	D-4	X					3	DA	AO	C	N	S F T VI J	C C C C C C C C	1	60	P.T. 42.0

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name Fire Protection

P&ID No. ISI-SK-1

Page 1 of 1

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
FP-248	2	-	X					4	GA	MO	O	Y	S T VI J	Q Q Q J	1	60	S, T, VI - P.T. 40
FP-249	2	-	X					4	GA	MO	O	Y	S T VI J	Q Q Q J	1	60	S, T, VI - P.T. 40
FP-256	2	-	X					4	GA	MO	O	Y	S T VI J	Q Q Q J	1	60	S, T, VI - P.T. 40
FP-258	2	-	X					4	GA	MO	O	Y	S T VI J	Q Q Q J	1	60	S, T, VI - P.T. 40

TABLE 3 VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name Fuel Transfer Tube

P&ID No. ISI-SK-2

Page 1 of 1

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
FP GATE	2	-	X				X		GA	H	CL	Y	J	J	1		

TABLE 3 VALVE PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2

System Name Emergency Diesel Generator

P&ID No. G-190204A, Sh. 1 of 3

Page 1 of 1

Valve Number	Class	Drawing Coordinates	Valve Category				Passive	Size (inches)	Valve Type	Actuator Type	Normal Position	High Radiation Area	Test Method	Test Frequency	Relief Request	Max. Stroke Time (sec.)	Remarks
			A	B	C	D											
FO-14	3	M-2		X				2	GL	M	CL	N	S	Q			P.T. 40
FO-9B-2	3	G-5		X				2	GA	SO	CL	N	S	Q	12		P.T. 40
FO-10B	3	G-5		X				2	GL	M	CL	N	S	Q			P.T. 40
FO-9B-1	3	F-5		X				2	GA	SO	CL	N	S	Q	12		P.T. 40
FO-10A	3	M-5		X				2	GL	M	CL	N	S	Q			P.T. 40
FO-9A-2	3	N-5		X				2	GA	SO	CL	N	S	Q	12		P.T. 40
FO-9A-1	3	M-5		X				2	GA	SO	CL	N	S	Q	12		P.T. 40
DG-AS-14	3	D-15		X				3/4	GL	M	CL	N	S	Q			P.T. 40
DG-ASA-1	3	F-15			X			3/4	CK	SA	-	N	FF RF	Q Q			P.T. 40
DG-AS-10	3	D-13		X				2	GL	M	CL	N	S	Q			P.T. 40
DG-ASB-1	3	C-15			X			3/4	CK	SA	-	N	FF RF	Q Q			P.T. 40
V9-13 (2 Valves)	3	L-1 L-4				X		2	CK	SA	-	N	FF FF	Q M			P.T. 23.5
Air Start Solenoid Valves (4)	3	C-11 J-11		X				1	GA	SO	CL	N	S	W	12		P.T. 23.1
Air Start Check Valves(4)	3	C-11 J-11			X			1	CK	SA	-	N	FF	W			P.T. 23.1

TABLE 3 - VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT 2
SPECIFIC REQUESTS FOR RELIEF

This section provides justification for specific requests for relief from code requirements as provided for in 10CFR50.55a(g)(5)(iii). Each relief requested is identified by a unique number and identifies the valve(s) for which the relief request is being made. The code test requirement found to be impractical is defined and the basis for exclusion from code requirements is presented. Any alternate testing is specified.

1. Specific Relief Request:

Seat leak testing and Category A valves as required by IWV-3420.

Applicable To:

All Category A valves for which test method is designated as J.

Basis for Relief Request:

10CFR50 Appendix J requires periodic leak testing of Containment Isolation Valves. All Section XI Category A valves for this plant are containment isolation valves and require Section XI leak testing. In order to preclude redundant test requirements on these valves, the Appendix J requirements will be met in lieu of the Section XI requirements.

The H. B. Robinson containment has two features in its design that assure adequate integrity during and following a loss of Coolant Accident. These are the Isolation Valve Seal Water System and the Penetration Pressurization System. These two systems are conservatively designed, seismically qualified, and operated in accordance with Unit Technical Specifications and the requirements of 10CFR50 Appendix J for seal systems that can be used in lieu of local Type C valve testing.

Alternate Testing:

The PPS and IVSW system will be tested as required by 10CFR50 Appendix J.

2. Specific Relief Request:

Exercising of valves as required by IWV-3520.

TABLE 3 - VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT 2
SPECIFIC REQUESTS FOR RELIEF

Applicable To:

MS-V1-3A-C

Basis for Relief Request:

These valves are the Main Steam Check valves downstream of the MSIV's. Normal steam flow verifies the proper opening of the valves. Section XI requires reverse flow seating of the valves. These valves cannot be exercised shut during power operation since this would result in a plant trip. Verifying closure of these valves during cold shutdown could result in delaying start-up due to the complicated test methods needed to verify closure (i.e., valve disassembly or visual inspection from inside the main steam lines). Also, since these valves are non-isolable during power operation, any steam leaks of appreciable size would require a plant shutdown to correct. Therefore, since disassembly on a frequent basis would increase the probability of such leaks, such maintenance is not considered a feasible alternative. These valves will be verified shut during refueling outages by some method such as disassembly or visual inspection from inside the main steam lines.

3. Specific Relief Request:

Full Stroke Testing as Required by IWV-3520

Applicable To:

Valves 875D, 875E, and 875F.

Basis for Relief Request:

These Accumulator Check Valves are partially stroked at cold shutdown by varying reactor coolant system pressure and observing increases and decreases in accumulator level. Stroke verification by passing design flow during cold shutdown is not practical due to the large volume of water that would be added to the Reactor Coolant System. Calculations have shown that a differential pressure of approximately 25 psi will shear any particles that may attempt to prevent the valve from functioning (FSAR Section 6.2.3). Based on this calculation and partial stroke testing presently performed full stroke testing requirements are waived.

TABLE 3 - VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT 2
SPECIFIC REQUESTS FOR RELIEF

4. Specific Relief Request:

Full Stroke Testing as Required by IWV-3520

Applicable To:

Valves 873A, 873B, 873C, 873D, 873E, 873F, 874A, and 874B.

Basis for Relief Request:

These valves cannot be full stroke exercised during normal operation due to the difference in pressure between the RCS (2235 psig) and the discharge head of the SI pumps (1500 psig). Injection into the RCS during cold shutdown is not desirable due to the possibility for low temperature overpressurization of the RCS. At refueling intervals, these valves are fully stroked during the Safety Injection System Test while the reactor vessel head is removed and the refueling cavity can be filled. This constitutes the only practical interval that this test can be performed.

5. Specific Relief Request:

Full Stroke Testing as Required by IWV-3520

Applicable To:

Valve SW-544

Basis for Relief Request:

This valve is partially stroked quarterly by verifying flow through a downstream tell-tale drain. Valve SW-544 is in the service water supply to the Auxiliary Feedwater (AFW) Pump Suction Line. It is a back-up water supply that would only be initiated in emergency conditions (condensate tank level less than 10%). The deep well water system also serves as a back-up AFW pump suction supply source.

Full stroke testing can only be accomplished by adding untreated lake water to the AFW System which has controlled water chemistry. Therefore, system design does not allow full stroke testing. Dismantling the valve at refueling intervals is not considered necessary nor practical since this would disable the service water system. Disassembly for full stroke verification only does not add to the safety margin verified by a quarterly partial stroke test. In fact,

TABLE 3 - VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT 2
SPECIFIC REQUESTS FOR RELIEF

disassembly for full stroke verification may prove detrimental and could possibly add to services water system leakage during operation. The position taken is, considering partial stroke testing now performed quarterly and the redundant role this system shares with the deep well water system, no other testing or periodic disassembly for testing purposes is required.

Alternate Testing: This valve will be disassembled during the Steam Generator Replacement Outage and a report on its internal condition will be submitted.

6. Specific Relief Request:

Individual Full Stroke Verification of Valves

Applicable To:

Valves SW-542 and SW-543.

Basis for Relief Request:

These valves are installed in parallel, non-isolable flowpaths. Therefore, full stroke verification cannot be performed individually on each valve. Flow through these valves is verified collectively at quarterly intervals.

7. Specific Relief Request:

Full Stroke Testing as Required by IWV-3520

Applicable To:

Valves 879A, 879B, and 879C.

Basis for Relief:

These valves cannot be full stroke exercised during normal operation due to the difference in pressure between the RCS (2235 psig) and the discharge head of the SI pumps (1500 psig). Design flow through these valves cannot be achieved with the system aligned for miniflow recirculation.

Injection into the RCS via the SI pumps during cold shutdown is not desirable due to the possibility for low temperature overpressurization of the RCS. These valves pass design flow at refueling outages during the SI system flow test. These valves are partial-stroke exercised quarterly by observing a pressure increase from PT-943 when each safety injection pump is tested.

TABLE 3 - VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT 2
SPECIFIC REQUESTS FOR RELIEF

8. Specific Relief Request:

Full Stroke Testing as Required by IWV-3520

Applicable To:

Valves 890A and 890B.

Basis for Relief Request:

These valves are tested at cold shutdown by injecting air upstream and observing a pressure increase on a temporary test gauge downstream. The cold shutdown test constitutes the only method to verify disk travel short of initiating flow through the spray nozzles or disassembly.

Proper full stroke operation of these valves will be verified at refueling.

9. Specific Relief Request:

Reverse Flow Testing

Applicable To:

Valve V8-5

Basis for Relief Request:

This valve, in the instrument air supply line to containment, cannot be aligned for reverse flow testing during normal operation. Such testing would isolate air to certain valves in containment and would result in a potential plant trip.

Plans are to install connections during the Steam Generator Replacement Outage that will allow seat leakage testing and reverse flow seating verification. Due to the special set-up requirements needed to perform this test - after the valve test connections are installed - relief from reverse flow seating verification at cold shutdown intervals is requested. This testing will be performed at refueling intervals coincident with the seat leakage testing.

TABLE 3 - VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT 2
SPECIFIC REQUESTS FOR RELIEF

10. Specific Relief Request:

Full Stroke Forward Flow Testing

Applicable To:

Valve 357

Basis for Relief Request:

Full stroke exercising valve 357 during power operation would result in over boration of the RCS, which could result in a plant shutdown. During cold shutdown, full stroke exercising this valve could result in a low temperature overpressurization of the RCS. This valve will be partial stroke exercised quarterly and full stroke exercised with flow during refueling outages.

11. Specific Relief Request:

Stroke Test of IWV-3520

Applicable To:

Valves 870C and 870D

Basis for Relief Request:

Due to special techniques that must be performed to ensure the vacuum breaking capability of these valves, the frequency has been set at refueling intervals. A classification of C-active has been chosen for these valves. A modification must be performed to allow bench testing of these valves. This modification is scheduled for the Steam Generator Replacement Outage.

12. Specific Relief Request:

Cycle Timing of Solenoid Actuated Valves

TABLE 3 - VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT 2
SPECIFIC REQUESTS FOR RELIEF

Applicable To:

1. Emergency Diesel "A" Valves
 - A. DG-FO-9A-1: Fuel Oil Day Tank Isolation
 - B. DG-FO-9A-2: Fuel Oil Day Tank Isolation
 - C. Diesel Air Start Solenoid Valves (2 per Diesel)
2. Emergency Diesel "B" Valves
 - A. DG-FO-9B-1: Fuel Oil Day Tank Isolation
 - B. DG-FO-9B-2: Fuel Oil Day Tank Isolation
 - C. Diesel Air Start Solenoid Valves (2 per Diesel)

Basis for Relief Request:

Operators for these valves are designed such that actuation cannot be verified by direct examination. Additionally, these valves are actuated by automatic signals from other diesel generator system components. Specifically, DG-FO-9A-1, 9A-2, 9B-1, and 9B-2 are actuated by the diesel day tank level switches. The diesel air start solenoid valves are actuated in the diesel start sequence.

The design features of these valves and the inability to accurately determine the time of the actuation signals make cycle timing of these valves impractical.

Alternate Testing:

The fuel oil day tank isolation valves are cycled weekly during performance of the diesel generator periodic test. The air start solenoids are also cycled during this test. However, only one air start solenoid valve is tested weekly on each diesel. The periodic test contains instructions to isolate one of these valves per diesel by closing an upstream isolation valve. The selection of which valve to isolate is based on the date of the test. For an odd number test date, one valve per diesel would be isolated. For an even number test date, the other valve would be isolated.

During performance of the periodic test, failure of these valves to operate would be evident by failure to fill the fuel oil day tanks or by failure of the diesel to start.

TABLE 3 - VALVE TEST PROGRAM
H. B. ROBINSON STEAM ELECTRIC PLANT UNIT 2
SPECIFIC REQUESTS FOR RELIEF

The increased test frequency has been determined to be an adequate method of ensuring proper valve operation without cycle timing.

SYSTEM	VALVE	DESCRIPTION	REMARKS
CVCS	LCV-115C	VCT to Charging Pumps Isolation	Testing of this valve during normal operation would disrupt suction to the charging pumps with potential loss of pumps and all RCP seal flow.
CVCS	351	Emergency Boration Flow Path to RCS	This valve is in a flow path used to inject boric acid from the BAST directly to the RCS via the charging pumps. Cycling during normal operation would result in overboration.
CVCS	202A & 282	Charging Line to RCS Manual Isolation	Cycling these valves during normal operation would disrupt charging flow to the RCS. Use of the bypass valve, 309A, as a flow path while cycling 202A and 282, will bypass HCV-121 and effect RCP seal water flow, and this is undesirable.
CVCS	204A & 204B	RCS Letdown Flow Isolation	Testing during normal operation causes loss of letdown flow. Should this occur coincident with normal charging flow and one of these valves fail to reopen, a high RCS level trip would result.
CVCS	297A, B, C 292A, 293A, 293C, 295	RCP Seal Water Injection Isolation	Cycling of these valves during normal operation would disrupt seal flow to the RCP's.
CVCS	381	RCP Seal Water Return Line Isolation	Testing during normal operation would result in disruption of seal flow and raise the potential for seal damage.
CVCS	266	VCT to Charging Pumps Check Valve	Verifying closure of check valve 266 during power operation would result in loss of charging flow and RCP seal flow causing damage to the RCP seals.
CVCS	357	RWST to Charging Pumps Check Valve	See Relief Request 10.
Auxiliary Feedwater	AFW-2	Condensate Storage Tank to AFW Pump Suction Check Valve	<p>This valve is partially stroked quarterly due to the running of AFW pumps on miniflow recirculation. Design flow is passed through the valve at cold shutdown intervals when the AFW pumps feed the steam generators pursuant to OP-14.</p> <p>The AFW pumps are not used to feed the steam generators during normal operation due to the potential for thermal shocking the feedwater nozzles and the feed rings.</p>

SYSTEM	VALVE	DESCRIPTION	REMARKS
Auxiliary Feedwater	AFW-19	Steam Driven AFW Pump Discharge Check Valve	Same as for AFW-2.
Auxiliary Feedwater	AFW-40, 41	Motor Driven AFW Pumps Discharge Check Valves	Same as for AFW-2.
Auxiliary Feedwater	AFW-68, 69, 70	Auxiliary Feedwater to Main Feedwater Check Valves	These valves are not cycled at power due to the practice of not feeding steam generators via the AFW system during normal operation. The AFW pumps are not used in this situation due to the potential for thermal shocking the feedwater nozzles and the feed rings.
RHR	750 & 751	RCS to RHR System Isolation	These valves cannot be opened unless valves 862A & B are closed (interlocked circuitry). Valves 862A & B are opened with A.C. control power removed when RCS pressure is above 1,000 psig (Tech. Spec. 3.3.1.1.h).
RHR	753A, B	RHR Pump Discharge Check Valves	With the plant at power, no flow path for the RHR system exists other than miniflow recirculation line. The flow path will not introduce design flow through 753A and B. These valves pass design flow during cold shutdown while the RHR system is providing core cooling.
Auxiliary Coolant (CCW)	FCV-626 & 735	CCW from RCP Thermal Barrier Isolation Valve	Testing during normal operation would result in loss of cooling water flow to the thermal barrier of the RCP's.
Auxiliary Coolant (CCW)	716A & 716B	Inlet Isolation for CCW Flow to the RCP's	Testing during normal operation would isolate all CCW to all RCP's.
Auxiliary Coolant (CCW)	730	Outlet Isolation for CCW Flow to RCP Upper and Lower Lube Oil Coolers	Testing during normal operation would result in disruption of flow to the lube oil coolers.

SYSTEM	VALVE	DESCRIPTION	REMARKS
Reactor Coolant	PCV-455C & PCV-456	Pressurizer Power Operated Relief Valves	These valves are not taken credit for in any accident analyses. Their design function is for system control. These valves are in the ISI program to provide "information only" testing to ensure operability.
Reactor Coolant	535 & 536	Block Valves for Pressurizer Power Operated Relief Valves	These valves are not taken credit for in any accident analyses. These are maintenance valves with non-Q operators. These valves are in the ISI program due to earlier commitments made in response to IE Inspection Report 82-27.
Main Steam	MS-V1-3A, B, C (Isolation)	Main Steam Isolation Valves	Cycling these valves during normal operation is not possible due to the resulting loss of steam flow and subsequent reactor trip. A partial stroke of these valves during normal operation is not possible since these are stop-check valves and a downward movement of the disk would tend to close the valve. The valve operators are tested weekly to ensure binding does not exist.
Main Steam	MS-V1-3A, B, C (Check)	Main Steam Check Valves	See Relief Request 2.
Feedwater	FCV-479, 489, 499	Main Feedwater Regulating Valve Bypass Valve	Cycling these valves during normal operation could result in a steam flow/feed flow mismatch and subsequent plant trip.
Feedwater	FW-V2-6A, 6B, 6C	Main Feedwater Regulating Valve Block Valve	Same as for FCV-479, 489, and 499.
Post Accident Containment Vent	PCV-1716	Instrument Air to Contain- ment Isolation	This valve closes only on a phase "A" containment isolation signal and can be opened only when the signal is overridden. Also, cycling this valve during normal operation would isolate air to certain valves in containment and would result in a potential plant trip.

SYSTEM	VALVE	DESCRIPTION	REMARKS
Post Accident Containment Vent	V8-5	Instrument Air to Containment Check Valve	See Relief Request 9.
Safety Injection	890A, B	Containment Spray Pumps Discharge Check Valves	See Relief Request 8.
Safety Injection	875A, B, C	Accumulator Discharge Check Valves	These valves cannot be cycled during normal operation due to the pressure differential that exists across the valves with either the SI or RHR pumps running. These valves are cycled during cold shutdown when the RHR system is providing core cooling.
Safety Injection	875D, E, F	Accumulator Discharge Check Valves	See Relief Request 3.
Safety Injection	845A, B	Spray Additive Tank to Containment Spray Pump Isolation	Cycling these valves during normal operation would require closing valves 892A, 892C, or 845C to preclude level reduction in the spray additive tank. Failure of 892A, 892C, or 845C in the closed position would isolate the sodium hydroxide addition flow path. This fact, coupled with the single failure proof design of the valves 845A and 845B, justifies a cold shutdown testing interval. Also per Tech. Spec. 4.5.2.4, valves 844A and 844B must be closed before 845A and 845B are cycled. Closing valves 844A and 844B would render the containment spray system inoperable and can only be done at cold shutdown conditions.
Safety Injection	864A, B	RWST Discharge Isolation	Per Tech. Spec. 3.3.1.1.h, during conditions of operation with reactor coolant pressure in excess of 1,000 psig, the A.C. control power shall be removed from these valves with the valves in the open position. Cycling of these valves during normal operation would violate Tech. Spec.
Safety Injection	862A, B	RWST to RHR Pumps Isolation	Same as for 864A, B.

SYSTEM	VALVE	DESCRIPTION	REMARKS
Safety Injection	865A, B, C	Accumulator Discharge Isolation	Same as for 864A, B.
Safety Injection	878A, B	SI Pump Discharge Header Cross Connect	Same as for 864A, B.
Safety Injection	873A, B, C, D, E, F	High Head SI to RCS Cold Legs Check Valves	See Relief Request 4.
Safety Injection	874A, B	High Head SI to RCS Hot Legs Check Valves	See Relief Request 4.
Safety Injection	863A, B	RHR Pumps Discharge to SI Pumps Suction Isolation	Per Tech. Spec. 3.3.1.1.h, during conditions of operation with reactor coolant pressure in excess of 1,000 psig, the A.C. control power shall be removed from these valves with the valves in the closed position. Cycling of these valves during normal operation would violate Tech. Spec.
Safety Injection	866A, B	High Head SI to RCS Hot Legs Isolation	Same as for 863A, B.
Safety Injection	869	High Head SI to RCS Hot Legs Containment Isolation	Testing during normal operation would momentarily take the hot legs SI flow path out of service. Failure of valve 869 in the closed position would render the SI flow path to the RCS hot legs out of service.
Safety Injection	879A, B, C	SI Pumps Discharge Check Valves	See Relief Request 7.
Safety Injection	876A, B, C	RHR Pump Discharge to RCS Loop Cold Leg Check valves	These valves cannot be full stroke exercised during normal operation due to the difference in the pressure between the RCS (2235 psig) and the discharge head of the RHR pumps (160 psig).
Safety Injection	870C, D	Spray Additive Tank Vacuum Breakers	See Relief Request 11.

SYSTEM	VALVE	DESCRIPTION	REMARKS
Penetration Pressurization	EV-H2A, EV-H2B, EV-1727, & EV-1728	Penetration Pressurization Air Supply and Bleed Off Valves For V12-10 & V12-11, V12-18 & V12-19, RMS-1 & RMS-2, and RMS-3 & RMS-4 Innerspaces, respectively.	These valves are normally de-energized, i.e., in the failed position, during normal operation with air being supplied to the penetration innerspace. Therefore, a failure mode test does not apply to these valves. A full stroke open timing test does not apply to these valves since they are enclosed and stem travel cannot be visually verified. Remote indication for valve position does not exist. The primary safety consideration is the operation of the valves listed in the description.
Isolation Valve Seal Water (IVSW)	Check valves on each branch line off four main headers	Containment Isolation Valves Seal Water Source Check Valves	The isolation valve seal water system is not taken credit for in the FSAR as reducing any calculated offsite dose. Containment integrity is verified during an ILRT with this system depressurized. Therefore, failure of this system to function would not result in any unreviewed safety question. The testing at refueling intervals pursuant to Technical Specification 4.4.2.c is adequate to assess proper system operation.
Post Accident Containment Vent	V12-14, V12-15, V12-18, & V12-19	Containment Vent Valves	At conditions above cold shutdown, these valves are required to be closed per Tech. Spec. 1.7.a to maintain containment integrity. Therefore, quarterly valve testing would violate technical specifications. These valves will be exercised during cold shutdowns.
Service Water	SW-544	Redundant Auxiliary Feedwater Pump Suction Source Check Valve	See Relief Request 5.
Service Water	SW-542, SW-543	Service Water to Auxiliary Feedwater Pump Check Valves	See Relief Request 6.
Emergency Diesel Generator	DG-FO-9A-1, DG-FO-9A-2, DG-FO-9B-1, DG-FO-9B-2, & 4 Air Start Solenoid Valves	Fuel Oil Day Tank Isolation Valves; Diesel Air Start Solenoid Valves	See Relief Request 12.